

Well Owner: Andrew Canham
Business Name: _____
Address: 35920 Canham Pl.
City, State, Zip: Miller, S. Dak 57362

A 3x3 grid with dashed lines. A solid 'X' is drawn in the center. The letter 'W' is to the left of the middle row, and the letter 'E' is to the right of the middle row.

Nov 3 2016

A scale bar consisting of a horizontal line with arrows at both ends. The text "1 Mile" is centered above the line.

? _____ ft. from _____ (identify source)

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring
 well

Forward Rotary

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
200 LB/FT	5 IN	0 FT	45 FT	8 $\frac{3}{4}$ IN
250 LB/FT	5 IN	45 FT	55 FT	8 $\frac{3}{4}$ IN
LB/FT	IN	FT	FT	IN

Grout Type	No. of Sacks	Grout Weight	From	To
<i>Gem surf</i>	<i>6</i>	<i>6</i> Lb/gal	<i>0</i> Ft	<i>30</i> Ft
		Lb/gal	Ft	Ft

Describe grouting procedure line to 30 feet
and pumped in slurry of cement

☐ Perforated pipe ☒ Manufactured
5 Inches Length 10 Feet
2.2 Set From 45 Feet to 55 Feet

Describe packer(s) and location

☒ Yes, How? Clonidine tablets

☐ No, Why Not?

Pierre

Please return **WHITE COPY** to: DENR Water Rights

City, State, Zip:

DEPTH

TO

Black	0	3
Yellow - blue	3	20
blue	20	45
Good Sand	45	55

25 FEET

PSI

Controlled by ☐ Valve ☐ Reducers ☐ Other

Can well be completely shut in?

☒ Pumped Describe: *Q c h*

☐ Other

Pumping Level Below Land Surface

50 Ft. After 4 Hrs. pumped 36+ GPM

Ft. After	Hrs. pumped	GPM
-----------	-------------	-----

If pump installed, pump rate: Solar pump GPM

REMARKS

This well was drilled under license #

And this report is true and accurate.

Drilling firm:

Signature of License Representative:

Signature of Well Owner or Equitable Property Holder:

Date:

523 E Capitol Ave. Pierre SD 57501

~~RECEIVED~~

JAN 30 2017

**WATER RIGHTS
PROGRAM**