


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location S/W 1/4 Sec 1 Twp 91N Rg 62WCounty
DouglasPlease mark well
location with
an "X"

Well Owner:

Name Loralee FinkAddress 409 Embassy CourtSergeant Bluff, IA 51054

Plugging completion

Date 12-18-18

CHECK APPROPRIATE BOX

EXISTING WELL



TEST HOLE



Well depth

368

Casing material

Steel

Casing size(s)

11 3/4"

Casing condition

Good

Hole depth

Hole size

Describe plugging procedure:

Trimming Pipe Pumped Bentonite From
368 To 60 ft Cement But 60. 8 ft well Top of
Casing is 8 ft Below ground level

Describe grout or plugging material:

Bentonite

Type of non-slip plug:

Bentonite

This well or test hole was plugged under license #

42

And this report is true and accurate.

Drilling firm

Gross Drilling Co

Signature of Licensed Representative

[Signature]

Signature of Well Owner

[Signature]

Date

12-18-18

RECEIVED

FEB 02 2018

RIGHTS