

SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02

Location N 1/4 SE 1/4 Sec 4 Twp 99 Rg 64W Well Owner: Noteboom Implement

County _____ Name: Noteboom Implement

Please mark well location with an "X" Address: 525 So. Hwy 28

City, State, Zip: Corsica, SD 57320

Comments: TH-2
TH-1

Plugging Completion Date 9/18/2018

CHECK APPROPRIATE BOX

EXISTING WELL ☒	TEST HOLE ☒
Well depth <u>12</u>	Hole depth <u>12 ft.</u>
Casing material <u>1/2" PVC (Temp.)</u>	Hole size <u>1.0 inch.</u>
Casing size(s) <u>1/2" PVC (Temp.)</u>	
Casing condition <u>Good</u>	

Describe plugging procedure:

Cement grout was utilized to plug the test well from total depth to grade. Well was a 1/2" PVC monitor well casing that was pulled before grouting procedure completed.

Describe grout or plugging material:

The cement grout mixture consisted of high sulfate resistant portland cement and no more than 6 gallons of water for each 94-pound sack of cement.

Type of non-slip plug:

This well or test hole was plugged under license # 653 and this report is true and accurate.

Drilling firm: Prairie Consulting Group, Inc.

Signature of Licensed Representative: [Signature]

Signature of Well Owner: [Signature]

Date: 9/18/2018

RECEIVED

JAN 31 2019

WATER RIGHTS PROGRAM