


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02Location SW ¼ SW ¼ Sec 19 Twp 112N Rg 50W

Well Owner:

County BrookingsPlease mark well
location with an "X"Name: Brookings-Deuel Rural Water SystemAddress: PO Box 340City, State, Zip: Toronto SD 57268

Comments:

44.4887 Lat
96.8861 LongPlugging Completion Date June 12, 2018**CHECK APPROPRIATE BOX**EXISTING WELL ☒TEST HOLE ☐Well depth 47' 10"Casing material steelCasing size(s) 12"Casing condition good

Hole depth _____

Hole size _____

Describe plugging procedure:

Filled the well from the bottom to the static water level with pea rock/gravel then a two foot bentonite plug then to ground level with dirt.

Describe grout or plugging material:

Bentonite medium chips

Type of non-slip plug: _____

This well or test hole was plugged under license # 796 and this report is true and accurate.Drilling firm: T & J Redder Well and Electric, Inc.Signature of Licensed Representative: Thomas J. RedderJoint Well Field Inc.Signature of Well Owner: Gene P. WulffDate: 7-23-18**RECEIVED****JAN 31 2019****WATER RIGHTS
PROGRAM**