

SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02


Location N6 1/4 SE 1/4 Sec 29 Twp 123N Rg 27W Well Owner: Charles Belcher

County

Edmunds

North

Please mark well location with an "X"



Well completion Date

10-4-18

Distance to nearest potential pollution source (Septic tank, abandoned well, feed lot, etc.)

? N/A ft. from N/A (identify source)

PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring

METHOD OF DRILLING:

forward Rotary

CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
LB/FT	<u>5</u> IN	<u>0</u> FT	<u>20</u> FT	<u>7 3/4</u> IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>Brick</u>	<u>2</u>	Lb/gal	<u>0</u> Ft	<u>20</u> Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

SCREEN:

☐ Perforated pipe ☐ Manufactured
 Diameter 5 Inches Length 10 Feet
 Material PVC
 Slot Size 016 Set From 20 Feet to 30 Feet
 Other information

WAS A PACKER OR SEAL USED?

☐ Yes ☒ No

If so, what material?

Describe packer(s) and location

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? Bleach
☐ No, Why Not?

Lab sample sent to for water quality analysis

Business Name:

Address:

City, State, Zip:

13439 325th Ave
Bowdle SD 57428

WELL LOG:

DEPTH

FORMATION

FROM

TO

Top Soil12Sand gravel230

STATIC WATER LEVEL

10

FEET

If flowing: closed in pressure

PSI

GPM flow

through

Inch pipe

Controlled by

☐ Valve☐ Reducers☐ Other

Reduced flow rate

GPM

Can well be completely shut in?

WELL TEST DATA:

☐ Pumped Describe:☐ Bailed☐ Other

Pumping Level Below Land Surface

20

Ft. After

1

Hrs. pumped

20

GPM

Ft. After

Hrs. pumped

GPM

If pump installed, pump rate:

GPM

REMARKS

This well was drilled under license # 432

And this report is true and accurate.

Drilling firm:

K&K well drilling

Signature of License Representative:

RECEIVED

FEB 07 2019

Signature of Well Owner or Equitable Property Holder:

WATER RIGHTS PROGRAM

Date:

Please return WHITE COPY to: DENR Water Rights

523 E Capitol Ave. Pierre SD 57501