


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02Location N $\frac{1}{4}$ W $\frac{1}{4}$ Sec 17 Twp 100 Rg 050County LincolnPlease mark well
location with an "X"Plugging Completion Date August 1, 2019

Well Owner:

Name: City of Sioux FallsAddress: 224 W Ninth StCity, State, Zip: Sioux Falls SD 57104

Comments:

Attn: Kari Johnson
Engineering Project Manager

CHECK APPROPRIATE BOXEXISTING WELL ☒TEST HOLE ☐Well depth 50'Casing material ConcreteCasing size(s) 26"Casing condition Average

Hole depth _____

Hole size _____

Describe plugging procedure:

Filled with clean sand to a level 12 feet below grade and the next 5 feet with a cement grout and the remaining 7 feet of sand.

Describe grout or plugging material:

Cement

Type of non-slip plug: _____

This well or test hole was plugged under license # 296 and this report is true and accurate.Drilling firm: Chase Drilling

Signature of Licensed Representative: _____

Signature of Well Owner: Chad L. HoweDate: 8/5/19

RECEIVED

AUG 07 2019

WATER RIGHTS
PROGRAM