


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location SE 1/4 SW 1/4 Sec 35 Twp 100 Rg 56County HUTCHINSONPlease mark well
location with
an "X"

Well Owner:

Name DELORTS STALL LIVING TRUSTAddress FREEWAY S.D. 57029Plugging completion Date 8-15-20

CHECK APPROPRIATE BOX

EXISTING WELL ☒TEST HOLE ☐

Well depth

220

Casing material

STEEL

Casing size(s)

2"

Casing condition

FAIL

Hole depth

Hole size

Describe plugging procedure:

RAN TREMIE LINE
TO BOTTOM WELL PUMP HILL
GROUT PUT PORTLAND GRADE TO
10'

Describe grout or plugging material:

D.F.

RECEIVED

OCT 05 2020

WATER RIGHTS
PROGRAM

Type of non-slip plug:

None

This well or test hole was plugged under license #

515

And this report is true and accurate.

Drilling firm

MARTON WELL DRILLING

Signature of Licensed Representative

[Signature]

Signature of Well Owner

[Signature] Trustee for Deloris Stahl Trust

Date

9/25/2020