


8406-3

SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location NW ¼ SW ¼ Sec 11 Twp 122N Rg 75WCounty WalworthPlease mark well
location with an "X"

Well Completion Date

1-22-2021

← 1 Mile →

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?

2000 ft. from Septic (identify source)

PROPOSED USE:

☐ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes
☒ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

Forward Rotary

CASING DATA: ☐ Steel ☒ Plastic ☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
<u>Opsi</u> LB/FT. <u>6</u> IN <u>+1.5</u> FT <u>59</u> FT <u>9.5</u> IN				
LB/FT. IN FT FT IN				
LB/FT. IN FT FT IN				

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>bentonite</u>	<u>5</u>	<u>9.5</u> Lb/gal	<u>0</u> Ft	<u>45</u> Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

Mixed with paddle mixer andPumped into annulus with 1" tremie hoseSCREEN: ☐ Perforated pipe ☒ ManufacturedDiameter 6 Inches Length 24 FeetMaterial PVCSlot Size .025 Set From 59 Feet to 83 Feet

Other information

WAS A PACKER OR SEAL USED? ☐ Yes ☒ No

If so, what material?

Describe packer(s) and location

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? Back flushed with 300 gal
☐ No, Why Not? 100 ppm Sterilene solution
 Lab to which water quality sample sent for analysis
Well Owner: Justin BieberBusiness Name: J D Enterprises Inc.Address: P.O. Box 340City, State, Zip: Bowdle SD 57428

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
Topsoil	0	1
Sandy yellow clay	1	10
Yellow clay	10	45
Fine to med tan colored sand.	45	65
Cleaner, better color fine to med sand	65	83
Shale	83	100

STATIC WATER LEVEL _____ FEET

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced flow rate: _____ GPM

Can well be completely shut in?

WELL TEST DATA:

☒ Pumped Describe: Pumped with 5 hp 95 gpm
Submersible
☐ Bailed☐ Other

Pumping Level Below Land Surface

56.5 Ft. After 1 Hrs. pumped 127 GPM

_____ Ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate: _____ GPM

REMARKS

This well was drilled under license # 285 and this report is true and accurate.Drilling firm: Manikowski Well Drilling Inc

Signature of License Representative:

Byron Manikowski

Signature of Well Owner or Equitable Property Holder

RECEIVED

FEB 01 2021

Date: 1-27-2021WATER RIGHTS
PROGRAM