


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02

Location NW 1/4 NW 1/4 Sec 22 Twp 32N Rg 41ECounty CLAYPlease mark well
location with an "X"Plugging Completion Date 12/8/21

Well Owner:

Name: LEWIS & CLARK RURAL WATERAddress: 31474 SD. HIGHWAY 19City, State, Zip: VERMILION, SD. 57069

Comments:

THIS WAS A TEST WELL CONSTRUCTED
DURING THE COLLECTOR WELL PROJECT.

CHECK APPROPRIATE BOX

TEST EXISTING WELL ☒		TEST HOLE ☐	
Well depth	<u>48'</u>	Hole depth	_____
Casing material	<u>CARBON STEEL</u>	Hole size	_____
Casing size(s)	<u>12"</u>		
Casing condition	<u>GOOD</u>		

Describe plugging procedure:

CLEAN, CHLORINATED SAND WAS INSTALLED FROM THE BOTTOM OF THE WELL TO THE STATIC WATER LEVEL OF 19'. 19' TO 3' BELOW GRADE WAS FILLED WITH BENTONITE GROUT. ALL MATERIAL WAS PLACED THROUGH A TREMBIE PIPE. TOP 3' WAS COMPACTED CLAY AFTER THE CASING WAS CUT OFF.

Describe grout or plugging material:

- CHLORINATED SAND
- WYOMING 30% HIGH SOLIDS GROUT.

Type of non-slip plug: _____

This well or test hole was plugged under license # 513 and this report is true and accurate.Drilling firm: LAYNE CHRISTENSEN CO.Signature of Licensed Representative: Dwight HansenSignature of Well Owner: J. AllenDate: 1-7-2022

RECEIVED


JAN 12 2022

WATER RIGHTS
PROGRAM

SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02

Location NW 1/4 NW 1/4 Sec 22 Twp 32N Rg 41E

Well Owner:

County CLAYPlease mark well
location with an "X"Name: LEWIS & CLARK RURAL WATERAddress: 3147A SD HIGHWAY 19City, State, Zip: VERMILLION, S.D. 57069

Comments:

THIS WAS A TEST WELL CONSTRUCTED
DURING THE COLLECTOR WELL PROJECT.

Plugging Completion Date 12/9/21

CHECK APPROPRIATE BOX

EXISTING WELL ☐TEST HOLE ☐Well depth 89'Casing material CARBON STEELCasing size(s) 12"Casing condition GOOD

Hole depth _____

Hole size _____

Describe plugging procedure:

CLEAN, CHLORINATED SAND WAS INSTALLED FROM THE BOTTOM
OF THE WELL TO THE STATIC WATER LEVEL OF 20'. 20' TO 3' BELOW
GRADE WAS FILLED WITH BENTONITE GROUT. ALL MATERIAL WAS PLACED
WITH A TREMIE PIPE. TOP 3' WAS COMPACTED CLAY AFTER THE CASING
WAS CUT OFF.

Describe grout or plugging material:

- CHLORINATED SAND
- WYOMEN 30% HIGH SOLIDS GROUT.

Type of non-slip plug: _____

This well or test hole was plugged under license # 513 and this report is true and accurate.Drilling firm: LAYNE CHRISTENSEN CO.Signature of Licensed Representative: [Signature]Signature of Well Owner: [Signature]Date: 1-7-2022

RECEIVED

JAN 12 2022

WATER RIGHTS
PROGRAM