SOUTH DAKOTA WATER WELL COMPLETION REPORT

10-85

Location NW ¼ NE ¼ Sec 21 Twp 128 Rg 49

County Roberts

Please mark well location with an "X"



Well Completion Date Sept. 30 2022

PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Test Holes
☐ Irrigation ☐ Industrial ☐ Stock

Method of Drilling:
Rotary

CASING DATA:
☐ Steel ☒ Plastic ☐ Other
If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
2 LB/FT	4 IN	0 FT	62 FT	6½ IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUT:
Was the well grouted? ☒ YES ☐ NO
To what depth? 55 FEET
What is grouting material? Neat cement + Bentonite
If cement, number of sacks? 6 per driller AM 11/9/22
Describe grouting procedure 1" temie line fill bottom toward top

What was grout weight? LB/GAL

SCREEN: ☐ Perforated pipe ☒ Manufactured
Diameter 3 IN Length 10 FEET
Material 304 Stainless
Slot Size 15 Set From 62 Feet To 72 Feet
Slot Size Set From Feet To Feet
Slot Size Set From Feet To Feet
Other information 3x4 Stainless K-P

Was a packer or seal used? ☒ **YES** ☐ **NO**
If so, what material? 304 SS
Describe packer(s) and location? 62'

Was well disinfected upon completion? ☒ YES ☐ NO
Explain
Bacteriological analysis ☒ YES ☐ NO
Laboratory sent to DENR

Well Owner:
Name D+B Farmland GP
Address Rosholt, S.D. 57260

Well Log: Depth 72'

Formation	From	To
Top soil	0	2
yellow clay - Med	2	25
Grey clay - hard	25	55
Grey Sand - Med	55	72

STATIC WATER LEVEL 15 Feet
If flowing: closed in pressure PSI
GPM flow through inch pipe
Controlled by ☐ Valve ☐ Reducers ☐ Other
If other; specify
Can well be completely shut in?

WELL TEST DATA:
☐ Pumped
☐ Bailed Describe: air development
☐ Other
Pumping Level Below Land Surface
40 ft. After 4 Hrs. pumped 15 GPM
ft. After Hrs. pumped GPM
ft. After Hrs. pumped GPM

REMARKS:

This well was drilled under license # 602
And this report is true and accurate.
Drilling firm Reinart Bros Well
Signature of License Representative: Joe Reinart

RECEIVED
OCT 03 2022
OFFICE OF WATER

Signature of Well Owner:
Date Sept 30 2022