

Location NW ¼ SE ¼ Sec 14 Twp 2N Rg 6E

Please mark well
location with an "X"

3-2-2023

1 Mile

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?
 750 ft. from Septic (identify source)

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

Dear Mabel Hingray

If other describe ☐ Steel ☒ Plastic ☐ Other

PIPEWEIGHT	DIAMETER		FROM		TO		HOLE DIAMETER	
LB/FT	5	IN	42	FT	159	FT	7 7/8	IN
LB/FT		IN		FT		FT		IN
LB/FT		IN		FT		FT		IN

Grout Type	No. of Sacks	Grout Weight	From	To
Grout Cast	6	Lb/gal	0 Ft	90 Ft
		Lb/gal	0 Ft	90 Ft

Describe grouting procedure

~~Pressure~~ Pressure granted

SCREEN: ☒ Perforated pipe ☐ Manufactured _____

Diameter 5 ¹/₄ Inches Length 40 Feet

Material PVC

Slot Size .250 Set From 109 Feet to 159 Feet

Other information

If so, what material? *Asoprene*

If so, what material? Asph/Flt
Describe packer(s) and location
Packer set at 90'

☐ Yes. How?

Lab to which water quality sample sent for analysis ☒ No, Why Not?

Pump not installed

Well Owner: Coway Davis

Business Name:

Address: 650 Florman St.

City, State, Zip: Reynolds City, SD 57701

[illegible]

STATIC WATER LEVEL *85'* FEET

If flowing: closed in pressure PSI

GPM flow	through	Inch pipe
----------	---------	-----------

Controlled by ☐ Valve ☐ Reducers ☐ Other

Reduced flow rate GPM

Can well be completely shut in?

☐ Pumped Describe:

11

☐ Bailed☒ Other

Pumping Level Below Land Surface

120 Ft. After 1 Hrs. pumped 15 GPM

155 Ft. After 1 Hrs. pumped 20 plus GPM

If pump installed, pump rate: _____ GPM

REMARKS

This well was drilled under license # 511 and this report is true and accurate.

Drilling firm: CRJ Drilling LLC

Signature of License Representative:

Signature of Well Owner or Equitable Property Holder:

~~RECEIVED~~

APR 11 2023

Date: 3-25-2023

**OFFICE OF
WATER**