

721-3


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02

Location SE 1/4 NE 1/4 Sec 12 Twp 113N Rg 50W

Well Owner:

County Grant

Please mark well location with an "X"



Name:

Town of Strandburg

Address:

Box 13City, State, Zip: Strandburg SD 57265

Comments:

Plugging Completion Date 9-23-2024

CHECK APPROPRIATE BOX

West well EXISTING WELL ☒	TEST HOLE ☐
Well depth <u>150</u> Casing material <u>steel</u> Casing size(s) <u>4"</u> Casing condition <u>good/fair</u>	Hole depth _____ Hole size _____

Describe plugging procedure: tremmie line from bottom to top. Removed casing 5' below grade.

Describe grout or plugging material: 5 Groutwell DF
1 Neat cement

Type of non-slip plug: _____

This well or test hole was plugged under license # 598 and this report is true and accurate.

Drilling firm: Kranz Well & Excav LLCSignature of Licensed Representative: Charles King

Signature of Well Owner: _____

Date: 9-24-2024
RECEIVED
SEP 25 2024
**OFFICE OF
WATER**

721-3


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02

Location SE 1/4 NE 1/4 Sec 12 Twp 110N Rg 50W

Well Owner:

County Grant

Please mark well location with an "X"



Name:

Town of Strandburg

Address:

Box 13

City, State, Zip: Strandburg SD 57265

Comments:

Plugging Completion Date 9-17-2024

CHECK APPROPRIATE BOX

<u>East well</u> EXISTING WELL ☒	TEST HOLE ☐
Well depth <u>151'</u>	Hole depth _____
Casing material <u>Steel</u>	Hole size _____
Casing size(s) <u>5"</u>	
Casing condition <u>Fair</u>	

Describe plugging procedure: Removed pump & drop pipe. Tremmie line from bottom to top

Describe grout or plugging material: 6 bags Groutwell DF
1 bag Neat cement

Type of non-slip plug: _____

This well or test hole was plugged under license # 598 and this report is true and accurate.

Drilling firm: Kranz Well & Excav LLC

Signature of Licensed Representative: Charles King

Signature of Well Owner: _____

Date: 9-17-24

RECEIVED

SEP 25 2024

OFFICE OF
WATER