


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02

Location NW 1/4 NE 1/4 Sec 8 Twp 118N Rg 49W

Well Owner:

County GrantPlease mark well
location with an "X"Name: Donald DeVoeAddress: 47324 162nd StrCity, State, Zip: Strandburg SD 57265

Comments:

Plugging Completion Date 9-17-2024

CHECK APPROPRIATE BOX

EXISTING WELL ☒TEST HOLE ☐Well depth 130'Casing material steelCasing size(s) 3"Casing condition Poor

Hole depth _____

Hole size _____

Describe plugging procedure: Tremmie line from bottom to topDescribe grout or plugging material: 1 Groutwell DF
1 Neat cement

Type of non-slip plug: _____

This well or test hole was plugged under license # 598 and this report is true and accurate.Drilling firm: Kranz Well & Excav LLCSignature of Licensed Representative: Charles Kranz

Signature of Well Owner: _____

Date: 9-17-2024

RECEIVED

SEP 25 2024

OFFICE OF
WATER