


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location SW 1/4 NE 1/4 Sec 23 Twp 122 Rg 47County RobertsPlease mark well
location with
an "X"Cabin Lake Well
13904 Goose Lake Rd
Bigstone City SD

Well Owner:

Name Denny LawAddress P.O. Box 307Wall, S.D. 57790Plugging completion Date 7-10-24

CHECK APPROPRIATE BOX

EXISTING WELL



TEST HOLE



Well depth

55 ft.

Casing material

steel

Casing size(s)

4"

Casing condition

fair

Hole depth

Hole size

Describe plugging procedure:

grout pumped thru 1" plug grout line
bottom to top

Describe grout or plugging material:

Bentonite 50 lbw mixed 25 gal water

Type of non-slip plug:

This well or test hole was plugged under license #

602

And this report is true and accurate.

Drilling firm

Reinart Bros Well Drilling

RECEIVED

Signature of Licensed Representative

Goe Reinart

Signature of Well Owner

Date

8-1-24

AUG 08 2024

OFFICE OF
WATER