


SOUTH DAKOTA WELL

PLUGGING REPORT

11-02

Location N 44 1/4 NW 1/4 Sec 7 101 Twp 149 Rg 533County MinnehahaPlease mark well
location with
an "X"Plugging Completion Date 6-15-25

Well Owner:

Name:

Address:

City, State, Zip:

Comments:

Soukup Construction701 W Eisenhower AveSioux Falls SD

RECEIVED

JUL 14 2025

OFFICE OF
WATER

CHECK APPROPRIATE BOX

EXISTING WELL ☒TEST HOLE ☐

Well depth

32'

Casing material

Concrete

Casing size(s)

30"

Casing condition

Bad

Hole depth

Hole size

Describe plugging procedure:

Fill IN w/ Fine sand to 6'
Bentonite seal - chips - cover to 5"
Cover w/ Black Dirk

Describe grout or plugging material:

Type of non-slip plug:

This well or test hole was plugged under license # 4139 and this report is true and accurate.Drilling firm: Dave Putzke well Drilling, repair, incSignature of Licensed Representative: Dave Putzke

Signature of Well Owner: _____

Date: _____