

SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02


Location SE 1/4 SW 1/4 Sec 34 Twp 12N Rg 54WCounty Day

Please mark well location with an "X"

45°14'22" N,
97°17'54" W

W

E

45.2395, -97.2983 -T5
1/29

Well Completion Date

11-5-25

1 Mile

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?
1000 ft. from Feed lot (identify source)

PROPOSED USE:

☒ Domestic/Stock
☐ Irrigation
☐ Municipal
☐ Industrial
☐ Business
☐ Institutional
☐ Test holes
☐ Monitoring well

METHOD OF DRILLING:

Forward Rotary

CASING DATA:

☐ Steel
☒ Plastic
☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
<u>SDR-21</u> LB/FT	<u>4</u> IN	<u>0</u> FT	<u>62</u> FT	<u>8 3/4</u> IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>Grout-Well</u>	<u>5</u>	<u>0</u> Lb/gal	<u>0</u> Ft	<u>62</u> Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

Tremie line pressure grouted from bottom to top
 SCREEN: ☐ Perforated pipe ☒ Manufactured
 Diameter 4 Inches Length 10 Feet

 Material PVC
 Slot Size 0.030 Set From 62 Feet to 72 Feet

Other information

WAS A PACKER OR SEAL USED? ☐ Yes ☒ No

If so, what material?

Describe packer(s) and location

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? Chlorine☐ No, Why Not?

Lab to which water quality sample sent for analysis

Well Owner: Landon Davis

Business Name:

Address: 44540 148th StCity, State, Zip: Waubay, SD 57273

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
<u>Topsoil</u>	<u>0</u>	<u>2</u>
<u>Yellow Clay</u>	<u>2</u>	<u>6</u>
<u>Fine Yellow Sand</u>	<u>6</u>	<u>16</u>
<u>Coarse Gray Sand</u>	<u>16</u>	<u>17</u>
<u>Blue Clay</u>	<u>17</u>	<u>65</u>
<u>Coarse Gray Sand</u>	<u>65</u>	<u>70</u>
<u>Blue Clay</u>	<u>70</u>	<u>76</u>

STATIC WATER LEVEL

4 FEET

If flowing: closed in pressure

GPM flow through PSIControlled by ☐ Valve ☐ Reducers ☐ Other Inch pipeReduced flow rate GPM

Can well be completely shut in?

RECEIVED

WELL TEST DATA:

JAN 20 2026

☐ Pumped Describe: Air☐ Bailed☒ Other

Pumping Level Below Land Surface

8 Ft. After 4 Hrs. pumped 25 GPM Ft. After Hrs. pumped GPMIf pump installed, pump rate: GPM

REMARKS

This well was drilled under license # 839 and this report is true and accurate.Drilling firm: Wieber Drilling LLC

Signature of License Representative:

Deek Wieber

Signature of Well Owner or Equitable Property Holder:

Date: 11-30-25

P60 Aquatic - T.J.