

SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02


Location SE 1/4 SW 1/4 Sec 30 Twp 125N Rg 52WCounty Roberts

Please mark well location with an "X"

North

W

E



45° 34' 25" N,
97° 13' 10" W

45.5736, -97.2195 -TJ
1/29

Well Completion Date

10-1-25

1 Mile

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.):

150 ft. from Septic Tank (identify source)

PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

Forward Rotary

CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
<u>SPR-21</u> LB/FT	<u>4</u> IN	<u>0</u> FT	<u>35</u> FT	<u>8 3/4</u> IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>Grout-Well</u>	<u>3</u>	Lb/gal	<u>0</u> Ft	<u>35</u> Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

Tremie line pressure grouted from bottom to topSCREEN: ☐ Perforated pipe ☒ ManufacturedDiameter 4 Inches Length 10 FeetMaterial PVCSlot Size 0.030 Set From 35 Feet to 45 Feet

Other information

WAS A PACKER OR SEAL USED? ☐ Yes ☒ No

If so, what material?

Describe packer(s) and location

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? Chlorine☐ No, Why Not?

Lab to which water quality sample sent for analysis

Well Owner: Dustin Cleveland

Business Name:

Address: 44938 125th StCity, State, Zip: Sisseton, SD 57262

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
<u>Topsoil</u>	<u>0</u>	<u>2</u>
<u>Yellow Sandy Clay</u>	<u>2</u>	<u>13</u>
<u>cobbles</u>	<u>13</u>	<u>15</u>
<u>Hard Yellow Clay</u>	<u>15</u>	<u>20</u>
<u>Sand lens</u>	<u>20</u>	<u>22</u>
<u>Blue Clay</u>	<u>22</u>	<u>36</u>
<u>Coarse Gray Sand</u>	<u>36</u>	<u>48</u>
<u>(cleaner up top)</u>		
<u>Sea Mud</u>	<u>48</u>	<u>53</u>

STATIC WATER LEVEL

8

FEET

If flowing: closed in pressure

PSI

GPM flow

through

Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other

Reduced flow rate

GPM

Can well be completely shut in?

RECEIVED

JAN 20 2026

WELL TEST DATA:

☐ Pumped Describe: Air☐ Bailed☒ Other

OFFICE OF WATER

Pumping Level Below Land Surface

26 Ft. After 4 Hrs. pumped 15 GPM

Ft. After Hrs. pumped GPM

If pump installed, pump rate: GPM

REMARKS

This well was drilled under license # 839 and this report is true and accurate.Drilling firm: Wieber Drilling LLC

Signature of License Representative:

Deek Wieber

Signature of Well Owner or Equitable Property Holder:

Date: 10-10-25