


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02Location NE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec 6 Twp 105 Rg 51County LAKEPlease mark well
location with an "X"Plugging Completion Date July 23, 2025

Well Owner:

Name: BIG SIOUX RURAL WATERAddress: 23343 479TH AVECity, State, Zip: EGAN SD 57024

Comments:

OLD WELL # 5**RECEIVED****DEC 29 2025****OFFICE OF
WATER****CHECK APPROPRIATE BOX**EXISTING WELL ☒TEST HOLE ☐Well depth 37'6"Casing material STEELCasing size(s) 12

Casing condition _____

Hole depth _____

Hole size _____

Describe plugging procedure:

TERMMIE PIPED

Describe grout or plugging material:

90 PACK GRAVEL 37' 6" TO 23', BENTONITE GROUT 23' TO SURFACE

Type of non-slip plug: _____

This well or test hole was plugged under license # 475 and this report is true and accurate.Drilling firm: THEIN WELL COMPANY, INC.

Signature of Licensed Representative: _____

Michael Rhein

Signature of Well Owner: _____

Date: _____

100

100

100

100

100