


SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location SE 1/4 NW 1/4 Sec 14 Twp 122N Rg 57WCounty Day

North

Please mark well location with an "X"

45° 22' 51" N,
97° 38' 39" W

Well Completion Date

10-24-25

1 Mile

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?

1000 ft. from Feed lot (identify source)

PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

Forward Rotary

CASING DATA:

☐ Steel ☒ Plastic ☐ Other
 If other describe _____

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
<u>SDR-21</u> LB/FT	<u>4</u> IN	<u>0</u> FT	<u>248</u> FT	<u>6 3/4</u> IN
<u>SDR-17</u> LB/FT	<u>4</u> IN	<u>248</u> FT	<u>348</u> FT	<u>6 3/4</u> IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>Grout-Well</u>	<u>14</u>	<u>0</u> Lb/gal	<u>0</u> Ft	<u>346</u> Ft

Describe grouting procedure

Trémie line pressure grouted from bottom to top
 SCREEN: ☐ Perforated pipe ☒ Manufactured
 Diameter 4 Inches Length 20 Feet

 Material PVC
 Slot Size 0.030 Set From 348 Feet to 368 Feet

Other information

WAS A PACKER OR SEAL USED? ☐ Yes ☒ No

If so, what material?

Describe packer(s) and location

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? Chlorine☐ No, Why Not?

Lab to which water quality sample sent for analysis

PierreWell Owner: Leigh Johnson

Business Name:

Address: 13818 428th AveCity, State, Zip: Webster, SD 57274

WELL LOG:

DEPTH

FORMATION	FROM	TO
<u>Topsoil</u>	<u>0</u>	<u>2</u>
<u>Yellow Clay</u>	<u>2</u>	<u>35</u>
<u>Blue Clay</u>	<u>35</u>	<u>251</u>
<u>Dirty Fine Sand</u>	<u>251</u>	<u>263</u>
<u>Hard Blue Clay</u>	<u>263</u>	<u>269</u>
<u>Shale</u>	<u>269</u>	<u>345</u>
<u>Medium Gray Sand</u>	<u>345</u>	<u>368</u>
<u>Shale</u>	<u>368</u>	<u>370</u>

STATIC WATER LEVEL

174

FEET

If flowing: closed in pressure

PSI

GPM flow _____ through _____

Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other

Reduced flow rate

GPM

Can well be completely shut in?

WELL TEST DATA:

☒ Pumped Describe:☐ Bailed☐ Other

Pumping Level Below Land Surface

180 Ft. After 4 Hrs. pumped 30 GPM

_____ Ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate: _____ GPM

REMARKS

RECEIVED

DEC 03 2025

OFFICE OF
WATERThis well was drilled under license # 839 and this report is true and accurate.Drilling firm: Wieber Drilling LLC

Signature of License Representative:

Delek Wieber

Signature of Well Owner or Equitable Property Holder:

Date: 12-3-25