

SOUTH DAKOTA WATER WELL COMPLETION REPORT

2024

RECEIVED

Location NW ¼ NW ¼ Sec 18 Twp 125N Rg 51W

County Roberts

GPS Coordinates
 Lat: 45.61573
 Lon: -97.10198

Please mark well location with an "X" on section grid

Well Completion Date
10-10-25

Distance from nearest potential pollution source (Septic tank, abandoned well, feed lot, etc.)
635 ft. from Septic Tank (identify source)

Well Owner: Larry Becker

Business Name: _____

Address: 12199 455th Ave

City, State, Zip: Sisseton, SD 57262

OFFICE OF WATER

WELL LOG:	DEPTH	
	FROM	TO
Topsoil	0.0	1.0
Medium Yellow Sand	1.0	11.0
Coarse Yellow Sand	11.0	16.0
Dirty Fine Sand	16.0	17.0
Medium Gray Sand	17.0	21.0
Pea Rock	21.0	24.0
Coarse Gray Sand	24.0	32.0
Blue Clay	32.0	36.0

STATIC WATER LEVEL 11.0 FEET

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced flow rate _____ GPM

Can well be completely shut in? _____

WELL TEST DATA:

☒ Pumped Describe: _____

☐ Bailed ☐ Air

☐ Other _____

Pumping Level Below Land Surface
21.0 Ft. After 4.0 Hrs. pumped 5.0 GPM

_____ Ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate: _____ GPM

REMARKS

This well was drilled under license # 839

And this report is true and accurate.

Drilling firm: Wieber Drilling LLC

Signature of License Representative: _____

Signature of Well Owner or Equitable Property Holder: _____

Date: 11-30-25

PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Monitoring Well

☐ Irrigation ☐ Industrial ☐ Institutional ☐ Test Hole

☐ Dewatering Well ☐ Geothermal ☐ Other _____

METHOD OF DRILLING: Forward Rotary

CASING DATA: ☐ Steel ☒ Plastic ☐ Other

If other describe _____

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
SDR-21 LB/FT	5 IN	0 FT	21 FT	8.75 IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
Grout-Well	2	Lb/gal	0.0 Ft	21.0 Ft
		Lb/gal	Ft	Ft

Describe grouting procedure Tremie line pressure grouted from bottom to top

SCREEN: ☐ Perforated pipe ☒ Manufactured

Diameter 5 Inches Length 10.0 Feet

Material PVC

Slot Size 0.040 Set From 21.0 Feet to 31.0 Feet

Other information _____

WAS A PACKER OR SEAL USED? ☐ Yes ☒ No

If so, what material? _____

Describe packer(s) and location _____

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? Chlorine

☐ No, Why Not? _____

Lab sample sent to for water quality analysis _____

Please return White Copy to DANR Water Rights 523 E. Capitol Ave., Pierre SD 57501