



SOUTH DAKOTA WATER WELL COMPLETION REPORT

2024

Location <u>SW</u> $\frac{1}{4}$ <u>NW</u> $\frac{1}{4}$ Sec <u>25</u> Twp <u>112</u> Rg <u>64</u> County <u>Beadle</u> GPS Coordinates Lat: <u>44.48209 N</u> Lon: <u>98.47734 W</u> Please mark well location with an "X" on section grid  Well Completion Date <u>1/25/2025</u> Distance from nearest potential pollution source (Septic tank, abandoned well, feed lot, etc.) ? _____ ft. from _____ (identify source)		Well Owner: <u>Brett Kahre</u> Business Name: _____ Address: <u>20026 387 Ave</u> City, State, Zip: <u>Wolsey SD 57384</u>																																	
PROPOSED USE: ☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Monitoring Well ☐ Irrigation ☐ Industrial ☐ Institutional ☐ Test Hole ☐ Dewatering Well ☐ Geothermal ☐ Other _____		WELL LOG: <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">FORMATION</th> <th colspan="2">DEPTH</th> </tr> <tr> <th>FROM</th> <th>TO</th> </tr> </thead> <tbody> <tr> <td>Yellow Clay</td> <td>0.0</td> <td>15.0</td> </tr> <tr> <td>Blue Clay</td> <td>15.0</td> <td>38.0</td> </tr> <tr> <td>Sand</td> <td>38.0</td> <td>60.0</td> </tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>		FORMATION	DEPTH		FROM	TO	Yellow Clay	0.0	15.0	Blue Clay	15.0	38.0	Sand	38.0	60.0																		
FORMATION	DEPTH																																		
	FROM	TO																																	
Yellow Clay	0.0	15.0																																	
Blue Clay	15.0	38.0																																	
Sand	38.0	60.0																																	
METHOD OF DRILLING: <u>Forward</u> CASING DATA: ☐ Steel ☒ Plastic ☐ Other If other describe _____ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>PIPEWEIGHT</th> <th>DIAMETER</th> <th>FROM</th> <th>TO</th> <th>HOLE DIAMETER</th> </tr> </thead> <tbody> <tr> <td>SdR21 LB/FT</td> <td>5 IN</td> <td>0 FT</td> <td>40 FT</td> <td>8.75 IN</td> </tr> <tr> <td>LB/FT</td> <td>IN</td> <td>FT</td> <td>FT</td> <td>IN</td> </tr> <tr> <td>LB/FT</td> <td>IN</td> <td>FT</td> <td>FT</td> <td>IN</td> </tr> </tbody> </table>		PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER	SdR21 LB/FT	5 IN	0 FT	40 FT	8.75 IN	LB/FT	IN	FT	FT	IN	LB/FT	IN	FT	FT	IN	STATIC WATER LEVEL <u>40.0</u> FEET If flowing: closed in pressure _____ PSI GPM flow _____ through _____ Inch pipe Controlled by ☐ Valve ☐ Reducers ☐ Other _____ Reduced flow rate _____ GPM Can well be completely shut in? _____													
PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER																															
SdR21 LB/FT	5 IN	0 FT	40 FT	8.75 IN																															
LB/FT	IN	FT	FT	IN																															
LB/FT	IN	FT	FT	IN																															
GROUTING DATA: Grout Type No. of Sacks Grout Weight From To <u>DF</u> <u>4</u> <u>Lb/gal</u> <u>0.0 Ft</u> <u>30.0 Ft</u> _____ Describe grouting procedure _____		WELL TEST DATA: ☒ Pumped Describe: <u>W/air</u> ☐ Bailed ☐ Air ☐ Other _____ Pumping Level Below Land Surface <u>38.0</u> Ft. After <u>2.0</u> Hrs. pumped <u>100.0</u> GPM _____ Ft. After _____ Hrs. pumped _____ GPM If pump installed, pump rate: _____ GPM																																	
SCREEN: ☐ Perforated pipe ☒ Manufactured Diameter <u>5</u> Inches Length <u>20.0</u> Feet Material <u>PVC</u> Slot Size <u>.2</u> Set From <u>30.0</u> Feet to <u>60.0</u> Feet Other information _____		REMARKS RECEIVED FEB 03 2025 OFFICE OF WATER																																	
WAS A PACKER OR SEAL USED? ☒ Yes ☐ No If so, what material? <u>Sand Packed</u> Describe packer(s) and location <u>sand @30-60</u>		This well was drilled under license # <u>440</u> And this report is true and accurate. Drilling firm: <u>Pullman Well Drilling</u> Signature of License Representative: 																																	
DISINFECTION: Was well disinfected upon completion? ☒ Yes, How? <u>Chlorine</u> ☐ No, Why Not? _____ Lab sample sent to for water quality analysis _____		Signature of Well Owner or Equitable Property Holder: _____ Date: _____																																	

Please return White Copy to DANR Water Rights 523 E. Capitol Ave., Pierre SD 57501