

SOUTH DAKOTA WATER WELL COMPLETION REPORT

RECEIVED

Location SW 1/4 SW 1/4 Sec 8 Twp 1N Rg 7E


County
Pennington

GPS Coordinates

Lat: 44.056004

Lon: -103.307006

Please mark well location
with an "X" on section grid



Well completion Date

4/9/2026

Distance from nearest potential pollution source (Septic tank, abandoned well, feed lot, etc.)

? 150.0 ft. from septic (identify source)

PROPOSED USE:

- ☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Monitoring Well
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Test Hole
☐ Dewatering Well ☐ Geothermal ☐ Other _____

METHOD OF DRILLING: Air Rotary

CASING DATA: ☐ Steel ☒ Plastic ☐ Other

If other describe _____

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
LB/FT	<u>5.00</u> IN	<u>0.0</u> FT	<u>163.0</u> FT	<u>7.88</u> IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>PORTLAND</u>	<u>18</u>	<u>Lb/gal</u>	<u>0.0</u> Ft	<u>95.0</u> Ft
<u>per driller AWM 04/17/2026</u>		<u>Lb/gal</u>	<u>Ft</u>	<u>Ft</u>

Describe grouting procedure

SCREEN: ☐ Perforated pipe ☒ Manufactured

Diameter 5.00 Inches Length _____ Feet

Material PVC

Slot Size _____ Set From 123.0 Feet to 163.0 Feet

Other information

WAS A PACKER OR SEAL USED? ☒ Yes ☐ No

If so, what material? Neoprene

Describe packer(s) and location 95ft 100ft

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? Chlorine pellets

☐ No, Why Not? _____

Lab sample sent to for
water quality analysis

Well Owner: Tim and Vickie Griffin

Business Name: _____

Address: 5245 Power St

City, State, Zip: Rapid City South Dakota 57702

APR 17 2026

OFFICE OF
WATER

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
Till	0.0	15.0
Gravel	15.0	25.0
Boulders	25.0	29.0
Minnelusa	29.0	163.0

STATIC WATER LEVEL 76.0 FEET

If flowing: closed in pressure _____ PSI

GPM flow _____ through _____ Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced flow rate _____ GPM

Can well be completely shut in?

WELL TEST DATA:

☐ Pumped Describe: Blew with Air

☐ Bailed ☒ Air

☐ Other

Pumping Level Below Land Surface

115.0 Ft. After 2.0 Hrs. pumped 25.0 GPM

95.0 Ft. After 0.5 Hrs. pumped 10.0 GPM

If pump installed, pump rate: _____ GPM

REMARKS

This well was drilled under license # 752

And this report is true and accurate.

Drilling firm: Geo Enterprises, Inc.

Signature of License Representative:

Caron Marshall

Signature of Well Owner or Equitable Property Holder:

Date: _____

Please return White Copy to DANR Water Rights 523 E. Capitol Ave., Pierre SD 57501