


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location SE 1/4 NE 1/4 Sec 13 Twp 102-N Rg 50-WCounty
MinnehahaPlease mark well
location with
an "X"

Well Owner:

Name Runge EnterprisesAddress 4801 No. Velocity AvePO Box 86490Sidney Falls So Dak. 57118Plugging completion Date 3-30-26

CHECK APPROPRIATE BOX

EXISTING WELL ☒TEST HOLE ☐Well depth 152'Casing material SteelCasing size(s) 4"Casing condition Good

Hole depth _____

Hole size _____

RECEIVED

MAY 04 2026

OFFICE OF
WATERDescribe plugging procedure: Removed pump jack & all the pipe - hole cleanedDescribe grout or plugging material: Termie Gravel from 80' to 152' 835W250-80' Termie Bentonite then fill dirt to 3' belowground - then yellow muddy clay to cover cut off

Type of non-slip plug: _____

This well or test hole was plugged under license # 111 And this report is true and accurate.Drilling firm Lacey Well Drilling Inc.Signature of Licensed Representative Joan Rader-Lacey

Signature of Well Owner _____

Date 4/14/26