


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02Location NE 1/4 NE 1/4 Sec 23 Twp 2N Rg 8ECounty PenningtonPlease mark well
location with an "X"Plugging Completion Date 7/14/2026

Well Owner:

Name: Albert GiffordAddress: 735 Halsey Dr.City, State, Zip: Box Elder SD 57719

Comments:

Gifford Well

Physical Address of Well Location:

735 Halsey Dr.

Box Elder, SD 57719

CHECK APPROPRIATE BOXEXISTING WELL ☒TEST HOLE ☐Well depth 37 ft.Casing material PVC and concrete tileCasing size(s) 6" & 36"Casing condition OK

Hole depth _____

Hole size _____

Describe plugging procedure:

Backfill with clean 3/4" gravel from 37 ft up to static water level 17.5 feet. Concrete cement from 17.5 ft up to 3 ft.
Removed casing at 3 ft below ground level. Backfilled with native soil to ground level.

Describe grout or plugging material:

Redi-Mix concrete cement

Type of non-slip plug: _____

This well or test hole was plugged under license # 331 and this report is true and accurate.Drilling firm: Taylor Drilling Co.Signature of Licensed Representative: K 5L

Signature of Well Owner: _____

Date: _____

RECEIVED**JUL 22 2026****OFFICE OF
WATER**