

RECEIVED

JAN 20 2026

SD EForm - 1622LD V1


SOUTH DAKOTA WELL AND TEST HOLE LOGGING REPORT, 11-02

Location NW ¼ NW ¼ Sec 8 Twp 25 Rg 6ECounty PENNINGTON

Please mark well location with an "X"

43.89506 N

103.43654 W

Plugging Completion Date 8-20-2025

Well Owner:

Name:

Address:

City, State, Zip:

Comments:

K Bar S Resort
634 Old Hill City Rd
Keystone SD 57751

CHECK APPROPRIATE BOX

EXISTING WELL ☒	TEST HOLE ☐
Well depth <u>106'</u>	Hole depth _____
Casing material <u>Steel</u>	Hole size _____
Casing size(s) <u>6"</u>	
Casing condition <u>Fair</u>	

Describe plugging procedure:

pumped grout through tremy line from bottom (106') to surface

Describe grout or plugging material:

Baroid Quick Grout and Portland Cement

Type of non-slip plug: _____

This well or test hole was plugged under license # 705 and this report is true and accurate.

Drilling firm:

Signature of Licensed Representative:

Signature of Well Owner: _____

Date: _____