


## SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT

10-85

Location SW 1/4 SW 1/4 Sec 116 Twp 102-N Rg 51-W

County

MinnehahaPlease mark well  
location with  
an "X"

Well Owner:

Name

MARCIA KASOWKI

Address

46248 S.D Hwy 38Hartford, S.Dak 57033

Plugging completion

Date

2-10-26

RECEIVED

APR 10 2026

## CHECK APPROPRIATE BOX

EXISTING WELL



TEST HOLE

OFFICE OF  
WATER

Well depth

180'

Casing material

Steel

Casing size(s)

4"

Casing condition

Good

Hole depth

Hole size

Describe plugging procedure:

Removed stroke pump - 1416'Gravy from 180-150' 150' to 10' Below groundBentonite tremied - pipe cut off &Bentonite on Top

Describe grout or plugging material:

Gravel in water - 150'Bentonite tremied from 10' Below groundto 150'

Type of non-slip plug:

This well or test hole was plugged under license #

111

And this report is true and accurate.

Drilling firm

Lacey Well Drilling Inc.

Signature of Licensed Representative

Signature of Well Owner

Date

4-28-2026