


SOUTH DAKOTA WELL AND TEST HOLE PLUGGING REPORT 11-02

Location NW ¼ NE ¼ Sec 24 Twp 2N Rg 8E

County Pennington

Please mark well
location with an "X"

Plugging Completion Date 7/17/2026

Well Owner:

Name: SD Ellsworth Development Authority

Address: PO Box 447

City, State, Zip: Rapid City SD 57709

Comments:

E.D.A Well

Physical Address of Well Location:

14751 County Rd.

Box Elder, SD 57719

RECEIVED

AUG 12 2026

OFFICE OF
WATER

CHECK APPROPRIATE BOX

EXISTING WELL ☒TEST HOLE ☐

Well depth 41 ft.

Casing material PVC

Casing size(s) 16"

Casing condition Good

Hole depth

Hole size

Describe plugging procedure:

Backfill with clean 3/4" gravel from 41 ft up to static water level 15 feet. Concrete cement from 15 ft up to 3 ft.

Removed casing at 3 ft below ground level. Backfilled with native soil to ground level.

Describe grout or plugging material:

Redi-Mix concrete cement

Type of non-slip plug:

This well or test hole was plugged under license # 331 and this report is true and accurate.

Drilling firm: Taylor Drilling Co.

Signature of Licensed Representative: *K. L.*

Signature of Well Owner:

Date: