


SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location NW 1/4 NW 1/4 Sec 13 Twp 103 Rg 71County Brule

Please mark well location with an "X"



Well Completion Date

1-31-26

1 Mile

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?

None ft. from

(Identify source)

PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

Mud Rotary

CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
<u>200</u> LB/FT	<u>5</u> IN	<u>0</u> FT	<u>200</u> FT	<u>2 1/8</u> IN
<u>400</u> LB/FT	<u>2</u> IN	<u>200</u> FT	<u>960</u> FT	<u>4 1/2</u> IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
		Lb/gal	Ft	Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

SCREEN:

☐ Perforated pipe ☒ Manufactured
 Diameter 2" Inches Length 140 Feet
Material PVCSlot Size 1025 Set From 820 Feet to 960 Feet

Other information

WAS A PACKER OR SEAL USED?

☒ Yes ☐ No

If so, what material?

Describe packer(s) and location Rubber
96000 Screen

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How?Chlorine☐ No, Why Not?

Lab to which water quality sample sent for analysis

Well Owner:

Garnett Christensen

Business Name:

Address:

25206 344th Ave

City, State, Zip:

Chamberlain SD 57325

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
<u>Top Soil</u>	<u>0</u>	<u>1</u>
<u>Yellow Clay</u>	<u>1</u>	<u>35</u>
<u>Shale</u>	<u>35</u>	<u>260</u>
<u>Chalk</u>	<u>260</u>	<u>360</u>
<u>Shale</u>	<u>360</u>	<u>550</u>
<u>Greenshorn</u>	<u>550</u>	<u>570</u>
<u>Shale</u>	<u>570</u>	<u>820</u>
<u>Dakota</u>	<u>820</u>	<u>960</u>

STATIC WATER LEVEL

70

FEET

If flowing: closed in pressure

PSI

GPM flow

through

Inch pipe

Controlled by

☐ Valve☐ Reducers☐ Other

Reduced flow rate

GPM

Can well be completely shut in?

WELL TEST DATA:

☒ Pumped Describe: Air☐ Bailed☐ Other

Pumping Level Below Land Surface

70 Ft. After 14 Hrs. pumped 20 GPM

Ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate: _____ GPM

REMARKS

This well was drilled under license # 722 and this report is true and accurate.

Drilling firm:

Stretch's Well Service Inc.

Signature of License Representative:

Tom Rathjen

Signature of Well Owner or Equitable Property Holder:

RECEIVED

Date:

MAY 08 2026OFFICE OF
WATER