

WATER PERMIT NO. 1687-1

Name of Applicant: Lone Star Campground

Address: 4911 Haverwood Lane, Unit 2617, Dallas TX

Phone: 972-738-8978

Amount of Water Claimed: 0.151 cfs (68 gpm)

Total Acres: NA

Source of Water Supply: groundwater (one well)

Water to be used for: commercial County: Meade

Type of Waste Disposal System: septic

Location: 4 miles northeast of Sturgis near Bear Butte

PRIORITY Date Received: 5-7-1999

Fee: \$150


Corrected Application Received:

Period of Annual Use: August 1 – August 31

Remarks: temporary campground

Diversion Point: SW ¼ NE ¼ Sec 18-T6N-R6E

Land to be Irrigated: NA



Depth of Well: 134 feet deep

Well Driller: Heaton Drilling

Remarks: no well log available

Type of Map: aerial

Prepared by: Kirk J Chaffee, Dir of Equalization

Reviewed and the Number Assigned on: 5-11-1999

By: **Karen Schlaak**

Notice of Hearing - date to intervene: _____

**SOUTH DAKOTA
WATER PERMIT NO. 1687-1**

Date of first receipt of application May 7, 1999.

The Chief Engineer, on behalf of the Water Management Board, issues Water Permit No. 1687-1 to Lone Star Campground Inc., c/o Marylyn K Tysdal, 4911 Haverwood Lane, Unit #2617, Dallas TX 75287 authorizing the water use system and the placing of water to beneficial use subject to the following limitations, conditions and qualifications:

1. Water Permit No. 1687-1 appropriates 0.15 cubic feet of water per second (68 gallons per minute) from one well (Sundance Formation) 134 feet deep located in the SW ¼ NE ¼ Section 18-T6N-R6E.
2. The water appropriated shall be used for the purpose of supplying water for commercial use at a campground and may not exceed the amount of water needed for beneficial use.
3. The water is to be used during the following described annual period: June 1 – September 30.
4. The date of approval of Permit No. 1687-1 is June 14, 1999.
5. The date from which applicant may claim right is May 7, 1999.
6. Water rights obtained in compliance with the laws of the State of South Dakota may not be unlawfully impaired by this appropriation.

QUALIFICATION

The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.

WATER MANAGEMENT BOARD

By: _____

John Hatch
John Hatch, Chief Engineer
Water Rights Program
Department of Environment and Natural Resources

JUN 22 1999

date



Mail to: Water Rights Program Joe Foss Building 523 E. Capitol Pierre, SD 57501-3181 (605) 773-3352	No. <u>1687-1</u>	(office use only) Hydrologic Unit <u>10/20202</u>
	Basin <u>Belle Fourche River</u>	
	Newspaper <u>Meade Co. Times-Tribune, Sturgis, SD</u>	



Application For Permit To Appropriate Water Within The State Of South Dakota

Check use(s) of water:

☐ Municipal	☐ Suburban Housing	☐ Recreational	☐ Institutional
☐ Rural Water System	☒ Commercial	☐ Fish & Wildlife	☐ Geothermal Heat
☐ Domestic (over 18 gpm)	☐ Industrial	☐ Other	

Type of Application: ☒ New ☐ Vested Right (Use predates Mar 2, 1955) ☐ Future Use Reservation
(check one) Place to Beneficial Use Water Reserved by Future Use Permit No. _____
Amendment/Correction to Permit No. _____

Description of amendment/correction: (i.e. change diversion point(s), add diversion point(s), change use, etc.) _____

1. Name of Applicant LONG STAR CAMPGROUND, INC. Phone 605-347-2437
(check one) ☒ Owner ☐ Tenant/lessee 972-738-8978
Mailing Address 4911 Haverwood Ln #617, Dallas State TX Zip Code 75287
(Street, RR, or Box)

2. Amount of water claimed 0.151 *CFS or 68 **GPM ***AF
(*Cubic Feet per Second) (**Gallons per Minute) (**Acre Feet - storage capacity of dam/dugout or annual use if applicable)

3. Source of water supply WELL

4. Location of point of diversion (example - 3 wells in SW1/4 NE1/4 section 12-T104N-R53W) 1 well
SW 1/4 NE 1/4 of Sec 18, Town 56N, Range 6 of the 13th
T6N, R6E County Meade

5. County or counties where water will be used MEADE

6. Annual period during which water is to be used Aug - Two weeks June 1 Sept 30

7. Give a description of the project. When available include any preliminary engineering report or other reports or information that will help explain the project. (Attach sheet if more space is needed)

Temporary Campground, located 7 miles from
Sturgis, So. Dak. on Highway 79 - at base of
Bear Butte -

STATE OF SOUTH DAKOTA)

County of Meade SS

Attachments: Attach Form 2A if diversion is from a well or dugout, or if storage of water is proposed. Attach map and any other technical information. (see instructions)

I, MARY LYNN K. TYSON, the applicant, certify that I have read this application, have examined the attached map and that the matters stated are true and that I intend, and am able to complete the necessary construction.

Signed Mary Lynn K. Tyson
Subscribed and sworn to before me this 5th day of May 19 99

Buddie M. Kusser
Notary Public
My Commission Expires
February 23, 2002

Form 2A

Supplemental Information

(Complete applicable portions only)

well drilled in 1990 - Driller David Hunter Drilling
(type or print in ink)
no longer in Bus.

1. Well Information - Proposed Construction

- a) Drill Hole Diameter 8" Depth 134
- b) Casing Type PLASTIC Diameter 5 1/2 Thickness 3/8"
- c) Screen Type PERFORATED Diameter 5 1/2 Thickness 3/8"
- d) Gravel Pack YES Length of Gravel Pack 134 ft
- e) Depth to Top of Water Bearing Material 100'
- f) Depth to Water (ground surface to water level) 34'
- g) Distance to nearest existing domestic well:

On applicants property APPROX 1 mile On property owned by others UNK

2. Wastewater Disposal System Information.

- a) Type of System (i.e. septic tank, drain field) SEPTIC
- b) System Capacity (gallons) 1400 Year Constructed 1990
- c) Connected to the City of grey water only Sanitary System


3. Dugout Information

- a) Surface Dimensions _____ Depth _____
- b) Depth to water (ground surface to water level) _____

4. Water Storage Dams This info. is from previous owner

If the proposed water use system contains one or more storage dams, please furnish the information requested below for each dam. The locations of the dams need to be shown on the map submitted with the application.

- a) If a private engineering firm or government agency was involved in the design of this dam, please give their name and address:



- b) Freeboard _____
- c) Crest Width _____
Crest Length _____
- d) Height _____
- e) Primary Outlet Capacity _____
If pipe, diameter _____
- f) Secondary Spillway Capacity _____
Spillway Width _____
- g) X & Y Slope _____
Upstream _____
Downstream _____
- h) Surface Area of Impoundment _____
- i) Storage _____ Acre Feet
- j) Drainage Area Above Dam _____ Acres



RECEIPT

Water Rights Program

South Dakota Department of Environment and Natural Resources

№ 416115

Pierre, _____ May 7, 1999

RECEIVED OF Lonestar Campground, 4911 Haverwood Lane, Unit 2617, Dallas, TX 75287
the following amount in fees for services rendered as provided for by law:

Fee for Application for Permit No. 1687-1 to Appropriate Water, to construct
and to put water to beneficial use _____

150 00

Fee for Application for Permit No. _____ to Appropriate Water, for Future
Use _____

Fee to retain Future Use Permit No. _____ after period of seven years.

Fee for Inspecting Constructed Works, confirming beneficial use and issuing Water
License No. 1687-1 _____

50 00

Fee for Filing Transfer Form _____

Fee for Filing Extension Request _____

Fee for _____

(Any Other Work Provided by Law)

Total

200 00

By


Chief Engineer

John S.

Marilyn
Tysdal



Section 18
T6-R6



Estimated well location of Lone Star Campground
SW 1/4 of the NE 1/4 of Section 18, Township 6, Range 6, of the BHM

Kirk J. Chaffee

Kirk J. Chaffee May 3, 1999
Director of Equalization &
Meade County Planning



16871

REPORT ON WATER PERMIT APPLICATION NO. 1687-1
for Lone Star Campground
May 12, 1999

Application No. 1687-1 proposes to appropriate 0.151 cfs (68 gpm) from one well approximately 134 feet deep located in the SW 1/4 NE 1/4 of Section 18, T6N-R6E in Meade County. The water is for commercial use in a campground.

AQUIFER - SUNDANCE FORMATION (SNDC)

The Sundance Formation is a sandstone, white, fine to medium grained, glauconitic, with interbedded shale and gray, green and brown in color. The Sundance lies directly upon the Spearfish Formation and underlies the Morrison Formation in the Black Hills. The aquifer underlies 2.143 million acres and contains an estimated 22.5 million acre feet of water in storage in Meade County (Allen, 1984). The aquifer outcrops in the immediate area as it is exposed by the Bear Butte uplift. The aquifer is probably under artesian conditions although a well log is not available to make this determination. Information on other domestic wells in Section 18, indicate confined conditions and water levels 15 to 47 feet below land surface.

The Water Rights Program does not monitor any observation wells completed into the Sundance Formation in the area. Information concerning water levels records is not available.

REVIEW OF EXISTING WATER PERMITS/RIGHTS

There are no other existing water permits/rights which obtain water from the Sundance Formation in this area. There are domestic wells in the area which obtain water from this source. Interference is not expected to be a concern. This diversion rate is relatively small and drawdown is not expected to be significant. The application is for 68 gpm, however, it is doubtful that this well is pumped at that rate. When this application is inspected and licensed the amount of water actually used will be determined.

CONCLUSIONS

1. Water is available from the Sundance Formation.
2. Interference is not expected to be a problem.
3. Water is used for a temporary campground which is usually only a couple of weeks per year during the motorcycle rally.
4. Wastewater is disposed of through septic tank and drainfield which was constructed in 1990.
5. No well log is available and it cannot be determined if the well is constructed in accordance with SD Well Construction Standards.



James A Goodman
Natural Resources Engineer

BIBLIOGRAPHY

Allen, J.C., D.L. Iles, A.K. Petres, 1984, Analysis of Groundwater and Streamflow Data Western Dakotas Region of South Dakota, for US Army Corps of Engineers, SDGS, Vermillion, SD, 57069.

**RECOMMENDATION OF CHIEF ENGINEER FOR WATER PERMIT
APPLICATION NO. 1687-1, Lone Star Campground**

Pursuant to SDCL 46-2A-2, the following is the recommendation of the Chief Engineer, Water Rights Program, Department of Environment and Natural Resources concerning Water Permit Application No. 1687-1, Lone Star Campground, c/o Marylyn K. Tysdal, 4911 Haverwood Lane Unit #2617, Dallas TX 75287.

The Chief Engineer is recommending APPROVAL of Application No. 1687-1 because 1) there is reasonable probability that there is unappropriated water available for the applicant's proposed use, 2) the proposed diversion can be developed without unlawful impairment of existing rights, 3) the proposed use is a beneficial use and 4) it is in the public interest with the following qualification:

The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.

See report on application for additional information.

A handwritten signature in black ink, appearing to read "John Hatch", written in a cursive style.

JOHN HATCH, Chief Engineer
May 19, 1999



**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3181
www.state.sd.us/denr

NOTE: TO BE SURE OF PUBLICATOIN ON
THE CORRECT DATES, CONTACT
THE NEWSPAPER RIGHT AWAY.

May 20, 1999

Lone Star Campground
%Marylyn K. Tysdal
4911 Haverwood Lane, Unit 2617
Dallas, TX 75287

Dear Ms. Tysdal:

Water Permit Application No. 1687-1 for commercial use has been examined and found to comply with the South Dakota Water Laws and applicable rules. A notice of hearing has been sent to the Publisher of the Meade Co. Times-Tribune printed at Sturgis, SD (Ph # (605) 347-2503). For your information, a copy of the notice, the recommendation of the Chief Engineer and a report on the application are enclosed. Please review the notice prior to publication and notify this office, if you have any corrections or questions.

Be sure to contact the above newspaper to authorize publication of your Notice of Hearing and to arrange for payment. Early contact with the paper can eliminate delays. The publisher has been instructed to publish your notice once each week for two consecutive weeks with the last publication to occur twenty days before the board meeting. The newspaper has been instructed to send us the Proof of Publication. We must receive Proof of Publication before action can be taken on the application.

Sincerely,

Eric Gronlund
Natural Resources Engineer
(605) 773-3352

enclosures

NOTE: If you plan to contest any part of the Chief Engineer's recommendation, you must file a petition pursuant to the procedures outlined in the attached notice of hearing. The Water Management Board will then consider your concerns during a hearing on the application.



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3181
www.state.sd.us/denr

May 20, 1999

Meade Co. Times-Tribune
Box 69
Sturgis, SD 57785-0069

ATTENTION: Legal Public Notice

Enclosed is a Notice of Hearing on Application No. 1687-1 to Appropriate Water to be published twice. Please publish the first notice on June 2, 1999, with the second publication 7 days later.

The applicant must verify to you that the notice is to be published, before you make the first publication. **Please BILL the APPLICANT for the cost of publication.** The APPLICANT is Lone Star Campground, %Marylyn K. Tysdal, 4911 Haverwood Lane, Unit 2617, Dallas, TX 75287 (Ph # (972) 738-8978).

Please send the Water Rights Program the first publication immediately. The publication is checked for accuracy so any corrections can be made in the second publication. You may use the form below or fax a copy of the first publication. Any fax should be sent to the attention of Karen Schlaak at (605) 773-4068. Publication errors can invalidate the public notice.

After the second publication, **please send us an affidavit or use the enclosed Proof of Publication form.** The applicant pays the cost of publication, but the Water Rights Program records require an affidavit or Proof of Publication. Delays in receiving the affidavit can be costly to the applicant.

Sincerely,

Eric Gronlund
Natural Resources Engineer
605 773-3352

enclosures

-----CU T HERE-----

No. 1687-1

TO: Eric Gronlund
Water Rights Program
Joe Foss Building
Pierre SD 57501-3181

Date _____

We are in receipt of your letter of May 20, 1999, enclosing Notice of Hearing to Appropriate Water by Application No. 1687-1 which was first published in our issue of _____. ENCLOSED IS A COPY OF THIS FIRST PUBLICATION.

Name

Newspaper

Instruction to Newspaper - Publish first Notice on June 2, 1999, with the second publication 7 days later. The applicant is responsible for payment.

NOTICE OF APPLICATION NO. 1687-1 to Appropriate Water

Notice is given that Lone Star Campground, c/o Marylyn K Tysdal, 4911 Haverwood Lane Unit #2617, Dallas TX 75287 has filed an application for a water permit to appropriate 0.15 cubic feet of water per second (68 gallons per minute) from one well (Sundance Formation) 134 feet deep located in the SW ¼ NE ¼ Section 18-T6N-R6E. The water is for commercial use in a campground.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application No. 1687-1 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water, and 4) it is in the public interest. In accordance with SDCL 46-2A-23, the Chief Engineer will act on the application, as recommended, unless a petition is filed opposing the application or the applicant files a petition contesting the Chief Engineer's recommendation. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled and the Water Management Board will consider the application. Notice of the hearing will be given to the applicant and any person filing a petition.

Any person interested in opposing or supporting this application or recommendation must file a written petition with BOTH the applicant and Chief Engineer. The applicant must file a petition if contesting the Chief Engineer's recommendation. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by June 21, 1999.

The petition may be informal, but must include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. Contact Eric Gronlund at the above Water Rights Program address to request copies of information pertaining to this application. Nettie H. Myers, Secretary, Department of Environment and Natural Resources.

PROOF OF PUBLICATION

STATE OF SOUTH DAKOTA)
) SS
 County of Meade)

I, Joan M. Lewis

certify that the attached printed Notice was taken

from the Meade County Times

printed and published in Sturgis

County of Meade and

state of South Dakota. The notice was published

in the newspaper on the following two dates:

May 26, 1999

June 2, 1999

Cost of Printing 35.03

Joan M. Lewis
 (Signature)

Bookkeeper
 (Title)

June 2, 1999
 (Date Signed)

Appropriate water

NOTICE OF APPLICATION NO. 1687-1 to Appropriate Water

Notice is given that Lone Star Campground, c/o Marilyn K Tysdal, 4911 Haverwood Lane Unit #2617, Dallas, TX 75287 has filed an application for a water permit to appropriate 0.15 cubic feet of water per second (68 gallons per minute) from one well (Sundance Formation) 134 feet deep located in the SW 1/4 NE 1/4 Section 18 T6N-R6E. The water is for commercial use in a campground.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application No. 1687-1 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water, and 4) it is in the public interest. In accordance with SDCL 46-2A-23, the Chief Engineer will act on the application, as recommended, unless a petition is filed opposing the application or the applicant files a petition contesting the Chief Engineer's recommendation. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled and the Water Management Board will consider the application. Notice of the hearing will be given to the applicant and any person filing a petition.

Any person interested in opposing or supporting this application or recommendation must file a written petition with BOTH the applicant and Chief Engineer. The applicant must file a petition if contesting the Chief Engineer's recommendation. The Chief Engineer's address is "Water Rights Program, Foss Building, 583 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by June 14, 1999.

The petition may be informal, but must include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. Contact Eric Gronlund at the above Water Rights Program address to request copies of information pertaining to this application. Nettie H. Myers, Secretary, Department of Environment and Natural Resources.

**Publ May 26 and June 2 1999
 Meade County Times- Tribune**





**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3181
www.state.sd.us/denr

JUN 22 1999

Lone Star Campground, Inc.
%Marylyn K. Tysdal
4911 Haverwood Lane, Unit #2617
Dallas, TX 75287

Dear Ms. Tysdal:

Enclosed is Water Permit No. 1687-1 authorizing your water diversion system and beneficial use of the water, not exceeding the limits as specified in the Water Permit.

We will schedule an inspection so that the Water License may be issued to you, thus completing your acquisition of a Water Right.

Very truly yours,

JOHN HATCH, Chief Engineer
Water Rights Program
605 773-3352

enclosures

Permit No. 1687-1
Belle Fourche River - Water District

Report of Examination of Works and/or Application of Water to Beneficial Use

TO: Chief Engineer, Water Rights Program, DENR, Foss Bldg., Pierre, SD 57501

I have this day, July 14, 1999, made a thorough examination of the water use system constructed by Lone Star Campground Inc. c/o Marylyn K Tysdal of 4911 Haverwood Lane, Unit #2617 Dallas TX 75287 holder of Permit No. 1687-1, bearing the priority of May 7, 1999 authorizing the diversion of 0.15 cu. ft. per second of the waters of Sundance Formation for commercial purposes, in Meade County.

I have to report on the conditions of the same as follows:

A. Works used to divert the water:

Pump\Motor:

- 1) Make Unknown submersible
- 2) Capacity ≈ 68 GPM

B. Works used to transport\apply water to place of use:

Water is diverted to a 2,500 gallon storage tank and is then distributed to the camp area for sanitary and drinking/cooking purposes.

The system is in the following condition good. The point of diversion is located Well: ≈ 2,175 feet S and ≈ 1,700 feet W from the NE corner section 18-T6N-R6E (SW¼NE¼). The works are capable of diverting and conveying to the place of use 0.15 cu. ft. per second of water which is to be used for commercial purposes. Water has been put to beneficial use to the maximum extent and the license should be issued for 0.15 cfs.

Applicable permit qualifications have been complied with: Yes X No

Exceptions to compliance are: none Date report completed: September 1, 1999



Ron Duvall
Natural Resources Engineer
DENR, Water Rights Program

FIELD INVESTIGATION REPORT FOR PERMIT NO. 1687-1

DATE OF INVESTIGATION	July 14, 1999
NAME & ADDRESS OF INVESTIGATION CONTACT/ RELATIONSHIP TO PERMIT HOLDER, IF APPLICABLE	Kevin Lucero
NAME & ADDRESS OF PERMIT HOLDER	Lone Star Campground Inc. c/o Marylyn K Tysdal 4911 Haverwood Lane, Unit #2617 Dallas TX 75287
DIVERSION POINT LEGAL LOCATION	Well: $\approx$ 2,175 feet S and $\approx$ 1,700 feet W from the NE corner section 18-T6N- R6E (SW $\frac{1}{4}$ NE $\frac{1}{4}$)

Other permit(s) associated with the project: none

WELL INFORMATION:

1) Well Drilling Firm: Heaton Drilling

Screen:

2) No. of Wells 1

1) Type perforated

3) Depth(s) 134 feet

2) Static water level 34 feet

4) Well log is available N

Pump/Motor:

5) Comment: driller no longer in business

1) Make Unknown submersible

Casing:

2) Capacity $\approx$ 68 GPM

1) Diameter 5.5 inches

2) Type Plastic

DISTRIBUTION LINES OR CANALS:


Water is diverted to a 2,500 gallon storage tank and is then distributed to the camp area for sanitary and drinking/cooking purposes.

PERMIT QUALIFICATIONS:

1) Special qualifications to permit being abided by Y

2) All structures, wells and lands on map Y

1000 0 1000 Feet



South Dakota
Department of Environment
& Natural Resources
Water Rights

Ron Duvall, Nat Res Engineer

9/1/99

Water Right No. 1687-1

STATE OF SOUTH DAKOTA


WATER LICENSE NO. 1687-1

(1) Lone Star Campground, Inc, %Marylyn K Tysdal, 4911 Haverwood Lane, Unit #2617, Dallas, TX 75287 made Application No. 1687-1, May 7, 1999 for a water permit to divert 0.15 cubic feet of water per second from ground water (one well – Sundance Formation), Meade County, South Dakota for commercial purposes. Permit No. 1687-1, with a priority date of May 7, 1999 was approved June 14, 1999 and issued to the applicant for diversion of water with construction of the described water supply system completed and the application to beneficial use of said water completed.

(2) It is certified that the permit holder has complied with the provisions of South Dakota State Law relating to completion of the construction of the water supply system and is entitled to divert 0.15 cubic feet of water per second for beneficial use. The location of the diversion point is approximately 2,175'S and 1,700'W of the NE corner of Section 18, T6N, R6E (SW ¼ NE ¼).

(3) The permit holder has complied with the provisions of South Dakota State Law relating to the application of water to beneficial use in a campground area for sanitary and drinking/cooking purposes.

(4) Pursuant to South Dakota Water Law 46-5-30.1 Lone Star Campground, Inc, %Marylyn K Tysdal, 4911 Haverwood Lane, Unit #2617, Dallas, TX 75287 the holder and/or owner of Water Right No. 1687-1 is issued a license to appropriate water, the right to use 0.15 cubic feet of water per second from ground water (one well – Sundance Formation) with a priority date of May 7, 1999 from the location specified in (2) of this license. The water is used for commercial use purposes. This license is subject to any limitations or qualifications listed in Water Right No. 1687-1 and subject to South Dakota State Law.



JOHN HATCH, Chief Engineer
Water Rights Program
Department of Environment and Natural Resources

SEP 7 1999

date





**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3181
www.state.sd.us/denr

SEP 7 1999

1687-1

Lone Star Campground, Inc.
%Marylyn K. Tysdal
4911 Haverwood Lane, Unit #2617
Dallas, TX 75287

Dear Ms. Tysdal:

Enclosed is Water License No. 1687-1. This is the final water right document completing your process of obtaining a Water Right.

For your information SDCL 46-6-27 requires that if the owner of an existing well, such as the well authorized by Water Right No. 1687-1, constructs a replacement well and does not plan to use the old well, the old well is considered abandoned and must be plugged. Also, any well that is being used or is not considered abandoned must be valved and controlled, if flowing, or sealed and capped so that no leaking occurs either underground or at the surface.

As long as you use the water beneficially, as stated in the Water License, the State Water Laws provide that you have a continuing right to use the water. If you have any questions, please contact our office.

Very truly yours,

JOHN HATCH, Chief Engineer
Water Rights Program
(605) 773-3352

gm
enclosures