

WATER PERMIT NO. 1876A-3

Name of Applicant: **Glendale Hutterian Brethren**

Address: **17866 Glendale Drive, Frankfort SD 57440**

Phone: **605-472-1247**

Amount of Water Claimed: **No Add'l**

Total Acres: **No Add'l**

Source of Water Supply: **Groundwater**

Water to be used for: **Irrigation**

County: **Spink**

Type of Waste Disposal System:

Location: **Approx. 6 miles southeast of Frankfort**

PRIORITY Date Received: **01-27-25**

Application/License Fee: **\$300.00**

Corrected Application Received: **02-12-25**

Period of Annual Use: **April 1 – October 31**

Remarks: **No additional acres or diversion rate, relocating acres and adding a well.**

Diversion Point: **Near center of SE 1/4 Sec 2 –
T115N-R62W**


Land to be Irrigated: **NW 1/4, W 1/2 NE 1/4, Sec
11 and SE 1/4 Sec 2; all in T115N-R62W**

Depth of Well: **140**

Well Driller:

Remarks:

Type of Map: **aerial**



Reviewed and the Number Assigned on: **02-24-25**

By: **Rachel Rodriguez**

Notice of Hearing - date to intervene: _____

**SOUTH DAKOTA
WATER PERMIT NO. 1876A-3**

Date of first receipt of application January 27, 2025.

Date of return to applicant for corrections, amendments or changes February 3, 2025.

Date of receipt of corrected application February 24, 2025.

The Acting Chief Engineer, on behalf of the Water Management Board, issues Water Permit No. 1876A-3 to Glendale Hutterian Brethren, 17866 Glendale Drive, Frankfort SD 57440, authorizing the construction of the water use system and the placing of water to beneficial use subject to the following limitations, conditions and qualifications:

1. Water Permit No. 1876A-3 amends Water Right No. 1876-3 by changing the location of a portion of the irrigated acres, adding an existing well, and adding a proposed well with no increase in irrigated acres or diversion rate authorized by No. 1876-3. Water Right No. 1876-3 appropriates 3.55 cubic feet of water per second (cfs) from one well completed into the Tulare: East James Aquifer located in the NW 1/4 NE 1/4 Section 11 for irrigation of 272 acres located in the SW 1/4, E 1/2 NW 1/4, W 1/2 NE 1/4 Section 11; all in T115N-R62W. This permit relocates 136 acres from the SW 1/4 Section 11 to the SE 1/4 Section 2 and moves the center pivot in the N 1/2 Section 11 to the west which will then also cover a portion of the W 1/2 NW 1/4 Section 11; all in T115N-R62W. This permit also amends Water Right No. 1876-3 to add an existing Tulare: East James Aquifer well located in the NW 1/4 NE 1/4 Section 11 and a new well to be completed into the Tulare: East James Aquifer (140 feet deep), located near the center of the SE 1/4 Section 2; all in T115N-R62W. This amendment does not authorize any increase in either the 3.55 cfs diversion rate, or 272 acres, authorized by Water Right No. 1876-3. This site is located approximately seven miles southeast of Frankfort SD.
2. The amount of the appropriation may not exceed 2 acre feet annually for each acre of land to which water is actually and beneficially applied for irrigation. The water is to be used during the following described annual period: April 1 – October 31.
3. The date from which applicant may claim right is May 3, 1971.
4. The date of approval of Permit No. 1876A-3 is May 19, 2025.
5. One-fifth of the construction is to be completed on or before November 19, 2027.
6. All construction is to be completed on or before May 19, 2030.
7. Water is to be put to beneficial use on or before May 19, 2034.
8. Water rights obtained in compliance with the laws of the State of South Dakota may not be unlawfully impaired by this appropriation.

QUALIFICATIONS

1. The wells approved under Water Permit No. 1876A-3 are located near domestic wells and other wells which may obtain water from the same aquifer. The well owner, under this Permit must control withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
2. The proposed well authorized by Permit No. 1876A-3 must be constructed by a licensed well driller and construction of the well and installation of the pump must comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.
3. This Permit is approved subject to the irrigation water use questionnaire being submitted each year.

WATER MANAGEMENT BOARD

By: _____

Mark Mayer
Mark Mayer, PE
Director of Office of Water
Department of Agriculture and Natural Resources

6/11/25
date



FORM 2: Application for irrigation in South Dakota
(type or print)

Mail to: SD DANR, Water Rights 523 E Capitol Ave Pierre, SD 57501-3182 ph. (605) 773-3352	No. <u>1876A-3</u> Hydrologic Unit <u>10160006</u> Basin <u>James R</u> Newspaper <u>Redfield Press</u> <u>Huron Plainsman</u> (office use only)
---	---

PAID

JAN 27 2025

Ck# 42699

Rec't# _____

Application for Permit to Appropriate Water for Irrigation

Type of Application: ☐ New ☐ Vested Right ☒ Amendment/Correction to Permit No. 1876-3
(Use predates Mar 2, 1955)

Description of amendment/correction: (i.e. change diversion point(s), add diversion point(s), change use, etc.)
relocate the pivot & 1.775 cfs from the SW 1/4 Sec 11 to the SE 1/4 Sec 2; all in T115N-R62W and shift the pivot in the E 1/2 NW 1/4, W 1/2 NE 1/4 Sec 11 west, to include the W 1/2 NW 1/4 Sec 11-T115N-R62W

1. Name to Appear on Irrigation Permit Glendale Hutterian Brethren

Note: The "Name to Appear on Irrigation Permit" must be the name in which the property to be irrigated is held in.

Mailing Address 17866 Glendale Dr Frankfort SD 57440
(Address) (City) (State) (Zip Code)

Phone 605.472.1247 Mobile 605.460.0013 Email _____

2. Amount of water claimed N/A *CFS or N/A **GPM N/A ***AF Total Acreage N/A
(*Cubic Feet per Second) (**Gallons per Minute) (***)Acre Feet - storage capacity of dam/dugout or annual use if applicable)

3. Source of water supply 3 wells (T:EJ) (center SE 1/4)

4. Location of point of diversion 2 existing wells located in the NW 1/4 NE 1/4 Sec 11 & 1 new well to be
(example - 3 wells in SW 1/4 NE 1/4 section 12-T104N-R53W)
located in the center Sec 2; all in T115N-R62W County Spink

5. County or counties where water will be used Spink

6. Annual period during which water is to be used April 1 - October 31

7. List below each forty-acre division, or lot, or fraction thereof and show number of acres to be irrigated in each.
(Attach sheet if more space is needed)

Land Description	Acres	Land Description	Acres
NW 1/4 & W 1/2 NE 1/4 Sec 11	136		
SE 1/4 Sec 2	136		
ALL IN T115N-R62W			

8. Give a description of the project. (Attach sheet if more space is needed)

2 existing wells in the NW 1/4 NE 1/4 Sec 11 & 1 new well in the center Sec 2; all in T115N-R62W to provide water at a rate of 1.775 cfs to each 136 ac pivot system (3.55 cfs total) which is already authorized under Water Right No. 1876-3. No additional acres or diversion rate are being requested. Acres are being relocated and diversion points are being added.

I, John H. Klemm Bres, the applicant, certify under
Name of Person Title (if applicable)

penalty of perjury that I have read this application, examined the attached map, and that the matters stated are true. I further certify, if acting on behalf of an entity or individual other than myself, that I am authorized to submit this application.

2021-08

Attachments: Attach Form 2A if diversion is from a well or dugout, or if storage of water is proposed. Also, attach map and any other technical information. (see instructions)

RECEIVED

JAN 27 2025

OFFICE OF
WATER

Supplemental Information

(type or print)

1. Well Information (check one or both as applicable)

☒ Drilling new well(s) ☒ Using existing well(s)

a) If new wells, how many 1 Have test holes been drilled? ☐ Yes ☒ No Drilled by _____
(if yes, please provide copies of logs)

b) If existing wells, how many 2 Provide copy of log(s), if available. Drilled by _____

For either existing or proposed wells:

c) Well Depth (required) 140 Depth to Top of Water Bearing Material _____ Depth to Water from Surface _____

d) Distance to nearest domestic well on applicant's property _____ Property owned by others _____

2. Wastewater Disposal System Information

a) Type of System (i.e. septic tank, drain field) _____

b) System Capacity (gallons) _____ Year Constructed _____

c) Connected to the City of _____ Sanitary System

3. Dugout Information


a) Surface Dimensions _____ Depth _____

b) Depth to water (ground surface to water level) _____

4. Water Storage Dams

If the proposed water use system contains one or more storage dams, please furnish the information requested below for each dam. The locations of the dams need to be shown on the map submitted with the application.

a) If a private engineering firm or government agency was involved in the design of this dam, please give their name and address:



b) Freeboard _____

c) Crest Width _____

Crest Length _____

d) Height _____

e) Primary Outlet Capacity _____

If pipe, diameter _____

f) Secondary Spillway Capacity _____

Spillway Width _____

g) X & Y Slope (e.g. 3 to 1 is a typical slope)

Upstream _____

Downstream _____

h) Area of Impoundment _____

i) Storage _____ Acre Feet


j) Drainage Area Above Dam _____ Acres

RECEIVED

JAN 27 2025

OFFICE OF
WATER

RECEIVED
JAN 27 2025
OFFICE OF
WATER



115N 62W
Section: 04
Glendale
Colony

115N 62W
Section: 03

115N 62W
Section: 02

115N 62W
Section: 01

115N 62W
Section: 09

115N 62W
Section: 10

115N 62W
Section: 11

115N 62W
Section: 12

115N 62W
Section: 16

115N 62W
Section: 15

115N 62W
Section: 14

115N 62W
Section: 13

Lincoln

James River

Section: 85

398th Ave

115N 62W
Section: 02

399th Ave

179th St

398th Ave

115N 62W
Section: 11

399th Ave

RECEIVED
JAN 27 2025
OFFICE OF
WATER

115N 62W
Section: 02

115N 62W
Section: 01

See file documentation dated February 24, 2055

Proposed well

115N 62W

479 ST

Two wells side-by-side about 10 feet apart

115N 62W
Section: 11

115N 62W
Section: 12

396 AVE

116N 62W
Section: 27

116N 62W
Section: 26

116N 62W
Section: 25

116N 62W
Section: 34

116N 62W
Section: 35

116N 62W
Section: 36

115N 62W
Section: 03

10160006 Middle James

James


115N 62W
Section: 02

115N 62W
Section: 01

115N 62W
Section: 10

115N 62W
Section: 11

115N 62W
Section: 12



RECEIPT

WATER RIGHTS PROGRAM

South Dakota Department of Agriculture and Natural Resources

Date January 30th 2025

RECEIVED OF Glendale Hutterian Brethren 17866 Glendale Drive Frankfort SD 57440

The following amount in fees for services rendered as provided for by law:

Fee for Application for Permit No. <u>1876 A-3</u> to Appropriate Water, to construct and to put water to beneficial use	\$ <u>100.00</u>
Fee for Application for Permit No. _____ to Appropriate Water for Future use	\$ _____
Fee to retain Future Use Permit No. _____ after period of seven years.	\$ _____
Fee for Inspecting Constructed Works, confirming beneficial use and issuing Water License No. <u>1876 A-3</u>	\$ <u>200.00</u>
Fee for Filing Transfer Form _____	\$ _____
Fee for _____	\$ _____
Fee for Issuing New Well Driller's License No. _____	\$ _____
Fee for Renewal of Well Driller's License No. _____	\$ _____
Fee for Issuing Well Pump Installer's License No. _____	\$ _____
Fee for Renewal of Well Pump Installer's License No. _____	\$ _____
(Any Other Work Provided by Law) TOTAL	\$ <u>300.00</u>

By

Eric Gronlund
Chief Engineer

Sec



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 E. CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

Applications to Amend Nos. 1876-3 and 3748-3

WATER RIGHTS PROGRAM -- FILE DOCUMENTATION

NAME: John Kleinsasser, Glendale Hutterian Brethren

ADDRESS: 17866 Glendale Drive, Frankfort SD

DATE: February 24, 2025

PHONE: 605.460.0013

RE: Existing well locations, proposed well location, and depth of proposed well

COMMENTS:

I contacted Mr. Kleinsasser concerning two applications to change the location of irrigated acreage covered by Water Right Nos. 3748-3 and 1876-3 and add a second, existing well to the well identified on Water Right No. 1876-3, plus a proposed new well in the center of the SE1/4 section 2-T115N-R62W.

Mr. Kleinsasser indicated the second, existing well was drilled about 10 feet from the well covered by No. 1876-3. It was intended to be a replacement well but, after drilling, it was discovered the original well was still functional so they can use either, existing well. Concerning the proposed well to be completed near the center of the SE1/4 section 2-T115N-R62W, Mr. Kleinsasser estimated the depth to range from 110 to 140 feet deep.

I prepared a map showing the location of the two existing wells and the proposed well in the SE1/4 section 2-T115N-R62W.

Ron Duvall, Engineer
SD DANR, Water Rights Program



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 E. CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

February 3, 2025

Glendale Hutterian Brethren
John Kleinsasser
17866 Glendale Drive
Frankfort SD 57440

RE: Amending Permit 1876-3

Dear Mr. Kleinsasser:

In reviewing your application, the following items are required:

- The map you returned has an X in the center of the SE 1/4 SE 1/4 Sec 2-T115N-R62W. However, the application states the diversion point will be in the center of Sec 2-T115-R62W. Enclosed is a map, please mark the well location with an "X".
- Form 2A, Supplemental Information, please provide the well depth. Your well driller should be able to give you an estimate depth for your proposed well location.

Once I receive the items above, I can begin processing your application.

Sincerely,

Rachel Rodriguez

Rachel Rodriguez
Water Rights Program
605 773-3352
rachel.rodriquez@state.sd.us

enclosure



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 E. CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

**RECOMMENDATION OF ACTING CHIEF ENGINEER FOR WATER PERMIT
APPLICATION NO. 1876A-3, Glendale Hutterian Brethren**

Pursuant to SDCL 46-2A-2, the following is the recommendation of the Acting Chief Engineer, Water Rights Program, Department of Agriculture and Natural Resources concerning Water Permit Application No. 1876A-3, Glendale Hutterian Brethren, 17866 Glendale Drive, Frankfort SD 57440.

The Acting Chief Engineer is recommending APPROVAL of Application No. 1876A-3 because 1) the proposed diversion can be developed without unlawful impairment of existing domestic water uses and water rights, 2) the proposed use is a beneficial use and 3) it is in the public interest as it pertains to matters of public interest within the regulatory authority of the Water Management Board with the following qualifications:

1. The wells approved under Water Permit No. 1876A-3 are located near domestic wells and other wells which may obtain water from the same aquifer. The well owner, under this Permit must control withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
2. The proposed well authorized by Permit No. 1876A-3 must be constructed by a licensed well driller and construction of the well and installation of the pump must comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.
3. This Permit is approved subject to the irrigation water use questionnaire being submitted each year.

See report on application for additional information.

Mark Mayer, PE
Director of Office of Water
April 28, 2025

*Report to the Chief Engineer
Water Permit Application No. 1876A-3
Glendale Hutterian Brethren
03/25/2025*

Water Permit Application No. 1876A-3 proposes to amend Water Right No. 1876-3 by changing the location of a portion of the irrigated acres, adding an existing well, and adding a proposed well, with no increase in irrigated acres or diversion rate as authorized by No. 1876-3. Water Right No. 1876-3 appropriates 3.55 cubic feet of water per second (cfs) from one well completed into the Tulare: East James aquifer located in the NW $\frac{1}{4}$ NE $\frac{1}{4}$ of Section 11 for the irrigation of 272 acres located in the SW $\frac{1}{4}$, the E $\frac{1}{2}$ NW $\frac{1}{4}$, and the W $\frac{1}{2}$ NE $\frac{1}{4}$ of Section 11, all in T115N-R62W. This application proposes to relocate 136 acres from the SW $\frac{1}{4}$ of Section 11 to the SE $\frac{1}{4}$ of Section 2 and move the center pivot in the SW $\frac{1}{4}$ of Section 11 to the SE $\frac{1}{4}$ of Section 2, and move the center pivot in the N $\frac{1}{2}$ of Section 11 to the west which will then also cover a portion of the W $\frac{1}{2}$ NW $\frac{1}{4}$ of Section 11; all in T115N-R62W. This application also amends Water Right No. 1876-3 by adding an existing Tulare: East James aquifer well located in the NW $\frac{1}{4}$ NE $\frac{1}{4}$ of Section 11 and a new well to be completed into the Tulare: East James aquifer (140 feet deep) located near the center of the SE $\frac{1}{4}$ of Section 2, all in T115N-R62W. This application to amend Water Right No. 1876-3 does not authorize any increase in either the 3.55 cfs diversion rate or the 272 total acres authorized by Water Right No. 1876-3. This site is located in Spink County approximately seven miles southeast of Frankfort, South Dakota.

Water Source: Tulare: East James (T:EJ) aquifer

South Dakota Codified Law (SDCL) 46-2A-12

“An amendment of an existing permit or license may be granted for a change in use, a change in point of diversion or other change only if the change does not unlawfully impair existing rights and is for a beneficial use and in the public interest.”

This application is for the amendment of Water Right No. 1876-3. This report will not address water availability for Water Permit Application No. 1876A-3 because water availability was considered during the original review and recommendation of the Chief Engineer for Water Right No. 1876-3. This report will only address the potential for unlawful impairment of existing domestic water uses and water rights within the Tulare: East James aquifer.

SDCL 46-5-30.4

“Subject to the limitations in SDCL 46-5-33 and 46-5-34 governing changes in irrigation rights from one parcel of land to another, any water permit or right holder may apply for a change of use of the water, a change of location of the use or other amendment to the permit or right. Permits or rights may be amended pursuant to the procedure contained in chapter 46-2A. Priority shall be retained upon amendment. An amendment of a water permit or right may not increase the rate of diversion or increase the volume of water to be appropriated under the original water permit or right. The amendment may not impair existing rights.”

Pursuant to SDCL 46-5-30.4, Water Permit Application No. 1876A-3 shall have the same May 3, 1971, priority date as Water Right No. 1876-3 upon amendment. This application is not requesting an

increase in the rate of diversion or an increase to the volume of water appropriated under Water Right No. 1876-3.

SDCL 46-5-34

“All water used in this state for irrigation purposes shall remain appurtenant to the land upon which it is used. However, if for any reason it should become impractical to use all or any part of the water beneficially or economically for irrigation of any land to which the right of its use is appurtenant, all or any part of the right may be severed from the land and simultaneously transferred and become appurtenant to other land without losing priority of right previously established, subject to existing rights, upon approval of an application for an amended permit. No increase in total acres irrigated may be allowed under this section.”

This application is not requesting an increase in total acres irrigated; however, the applicant is requesting a relocation of acres without a change in use type or ownership. Reported irrigation use is available for Water Right No. 1876-3 since 1979. **Table 1** below shows the amount pumped in acre-feet from the T:EJ aquifer by No. 1876-3 for each year since 1979. The average annual pumping for this period of record is approximately 137 acre-feet (Water Rights, 2025a). Water Right No. 1876-3 is not currently subject to cancellation.

Table 1. Reported pumping by Water Right No. 1876-3 since 1979, in acre-feet (Water Rights, 2025a).

1979	99.43	1994	0	2009	49.5
1980	518.37	1995	0	2010	0
1981	116.00	1996	20.11	2011	0
1982	165.72	1997	0	2012	409.44
1983	53.04	1998	49.72	2013	0
1984	232	1999	111.36	2014	275.76
1985	0	2000	116.67	2015	92.8
1986	142	2001	261.62	2016	401.93
1987	118	2002	487.88	2017	116
1988	0	2003	282.83	2018	142.52
1989	232	2004	183.84	2019	37.56
1990	190	2005	187.37	2020	94.13
1991	106	2006	325.25	2021	77.19
1992	0	2007	148.49	2022	126.68
1993	0	2008	56.57	2023	131.99

Background

The original well associated with Water Right No. 1876-3 is located in the NW ¼ NE ¼ of Section 11 and is permitted to operate two center pivots, one located in the SW ¼ of Section 11 for the irrigation of a 136-acre circle and the second pivot located in the E ½ NW ¼ and W ½ NE ¼ for the irrigation of a 136-acre circle, all in T115N-R62W.

This amendment to Water Right No. 1876-3 seeks to change the location of 136 acres to be irrigated from the SW ¼ of Section 11 to the SE ¼ of Section 2, and the other center pivot in the E ½ NW ¼ and W ¼ NE ¼ to the west, which will also then irrigate a 136 acre circle that will cover a portion of the W ½ NW ¼ of Section 11; all in T115N-R62W.

The second existing well in the NW ¼ NE ¼ of Section 11 was drilled about 10 feet from the original well covered by No. 1876-3. However, after drilling the replacement well it was discovered that the original well was still functional and either of the wells could be used for the pivot located in the E ½ NW ¼ and W ½ NE ¼ of Section 11. The new proposed well is to be located near the center of the SE ¼ of Section 2; all in T115N-R62W. The wells to be used for each pivot are licensed to operate at 1.775 cfs each, for a total maximum diversion rate of 3.55 cfs to irrigate a total of 272 acres. **Figure 1** below shows a map with the new pivot locations and acres to be irrigated for Water Right No. 1876-3 as per this amendment and the three wells to be associated with Water Right No. 1876-3 as per this amendment.




Figure 1. Proposed diversion points and acreage to be relocated and developed pursuant to Application No. 1876A-3 for the amendment of Water Right No. 1876-3. This map also shows nearby T:EJ water rights/permits and observation wells completed into the T:EJ aquifer (Water Rights, 2025b and 2025d).

Well completion reports for the existing wells are unavailable; however, other well reports within 1.5 miles completed into the T:EJ aquifer indicate that the top of aquifer materials occur at a depth of 32 to 60 feet below ground surface, and the aquifer thickness ranging from 28 to 110 feet. Static water levels for nearby well completion reports range between 15 to 21 feet below the ground surface (Water Rights, 2025c). The aquifer is likely under confined conditions at the existing and proposed well locations. There were no well completion or test hole reports submitted with this application for the new proposed well in the SE $\frac{1}{4}$ of Section 2; however, the applicant estimated that the well depth will range between 110 to 140 feet below the ground (Water Rights, 2025b).

Potential for Unlawful Impairment

There are currently 95 active water rights/permits authorized to appropriate water from the Tulare: East James aquifer (Water Rights, 2025b), all for irrigation use. The nearest water rights to the proposed diversion point, not belonging to the applicant, are No. 4714-3 (located approximately one mile northwest and held by WIPT Inc.) and No. 1894-3 (located approximately 1.3 miles southeast and held by Maendl Living Trust) (**Figure 1**).

There are domestic wells on file with the Water Rights Program that are completed into the T:EJ aquifer, with the closest domestic well on file completed into the T:EJ located approximately three miles northeast. There could potentially be domestic wells completed into the Tulare: East James aquifer near the well the applicant proposes to use that are not on file with the Water Rights Program. The location of the domestic wells in the well completion report database maintained by the Water Rights Program is based on the location listed by the driller on the well completion report.

Before this amendment, the single well associated with Water Right No. 1876-3 was pumping the full 3.55 cfs by itself which is expected to cause more drawdown compared to two wells (approximately 0.4 miles between the wells) pumping around 1.775 cfs each. The applicant has stated that each pivot system will be operated with one well each, the pivot in the N $\frac{1}{2}$ of Section 11 can be operated using the existing well or the replacement well located approximately 10 feet from the existing well.

SD DANR observation well SP-79E is completed into a confined portion of the T:EJ aquifer and is located approximately $\frac{1}{2}$ mile northwest of the nearest water right (No. 4714-3) to the proposed well (**Figure 1**) (Water Rights, 2025b and 2025d). The hydrograph for that well is shown below. Static water level elevations are referenced to the top of the casing.




Figure 2. Hydrograph for observation well SP-79E (Water Rights, 2025d).

Figure 2 shows stable to increasing water levels overall. Water levels in this aquifer are representative of the available head in a confined aquifer and while they don't represent the amount of water in storage; they are indicative of nearby pumping and climatic conditions at that location. This observation well responds well to climatic conditions; for example, the multi-year drought in the late 1970s and late 1980s, the wet period during the mid- to late 1990s, another dry period in the early to mid- 2000s, as well as short-term flooding events that occurred in 2011 and 2019. Water levels for the aquifer at this location have not decreased back to the levels that existed prior to the flooding in the 1990s (Water Rights, 2025d).

The nearest water rights and wells with the greatest risk of impairment are the applicant's own. Furthermore, the existing well for Water Right No. 1876-3 has been in use since the mid-1970s and this application is not requesting a greater diversion rate or additional acreage. The T:EJ aquifer can be monitored for changes in water levels with observation well SP-79E, which is close to the nearest water right not belonging to the applicant. There are no complaints in Spink County for well interference (Water Rights, 2025e). There is a reasonable probability that this application can relocate acreage, add the existing well, and develop a new well without unlawfully impairing existing appropriative users or domestic users with adequate wells.

Conclusions

1. Water Permit Application No. 1876A-3 proposes to amend Water Right No. 1876-3 held by Glendale Hutterian Brethren by transferring the location of 136 acres from the SW $\frac{1}{4}$ of Section 11 to the SE $\frac{1}{4}$ of Section 2, and a portion of 136 acres to the W $\frac{1}{2}$ NW $\frac{1}{4}$ of Section 11; all in T115N-R62W.
2. Water Right No. 1876-3 appropriates a total of 3.55 cfs from one well to irrigate 272 acres. This application proposes to add an existing well located in the NW $\frac{1}{4}$ NE $\frac{1}{4}$ of Section 11 and a new well to be completed into the Tulare: East James aquifer near the center of the SE $\frac{1}{4}$ of Section 2; all in T115N-R62W. This application does not seek to increase the diversion rate authority, nor the volume of water appropriated, nor the number of irrigated acres under Water Right No. 1876-3.
3. The water has already been appropriated as authorized by Water Right No. 1876-3 and therefore water availability is not an issue.
4. The proposed diversions and acreage authorized by Water Right No. 1876-3 can be relocated and developed without unlawful impairment of existing domestic water uses and water rights as allowed by SDCL 46-2A-12, 46-5-30.4 and 46-5-34.


Brittan R. Hullinger
Natural Resources Engineer I
SD DANR Water Rights Program

Reviewed By:


Adam Mathiowetz, P.E.
Natural Resources Engineer IV
SD DANR Water Rights Program

References

- Water Rights, 2025a. "1979-2023 Irrigation Summaries by Aquifer." SD DANR Water Rights Program. Joe Foss Building. Pierre, South Dakota.
- Water Rights, 2025b. Water Right/Permit Files. SD DANR Water Rights Program. Joe Foss Building. Pierre, South Dakota.
- Water Rights, 2025c. Well Completion Reports. SD DANR Water Rights Program. Joe Foss Building. Pierre, South Dakota.
- Water Rights, 2025d. Observation Well Data. SD DANR Water Rights Program. Joe Foss Building. Pierre, South Dakota.
- Water Rights, 2025e. County Files. SD DANR Water Rights Program. Joe Foss Building. Pierre, South Dakota.



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 E CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

**NOTE: TO BE SURE OF PUBLICATION ON
THE CORRECT DATES, CONTACT
THE NEWSPAPERS RIGHT AWAY.**

April 29, 2025

Glendale Hutterian Brethren
c/o John Kleinsasser
17866 Glendale Drive
Frankfort SD 57440

Dear Mr. Kleinsasser:

Water Permit Application No. 1876A-3 for irrigation use have been examined and found to comply with the South Dakota Water Laws and applicable rules. A notice has been sent to the Redfield Press printed at Redfield SD (Ph # 605 472-0822) and the Plainsman printed at Huron SD (Ph # 605 353-7414). You will need to contact the newspapers and authorize publication of this notice. For your information, a copy of the notice, the recommendation of the Acting Chief Engineer and report on the application are enclosed. Please review the notice prior to publication and notify this office, if you have any corrections or questions.

Be sure to contact the above newspapers to authorize publication of your Notice and to arrange for payment. Early contact with the papers can eliminate delays. Upon receiving authorization from you, the publishers have been instructed to publish your notice. The newspapers have also been instructed to send us the Proof of Publication. We must receive Proof of Publication before action can be taken on the application.

Sincerely,

Rachel Rodriguez

Rachel Rodriguez
Water Rights Program
(605) 773-3352

enclosures

NOTE: If you plan to contest any part of the Acting Chief Engineer's recommendation, you must file a petition pursuant to the procedures outlined in the attached notice of hearing. The Water Management Board will then consider your concerns during a hearing on the application.

NOTICE OF APPLICATION NO. 1876A-3 to Amend Water Right No. 1876-3

Notice is given that Glendale Hutterian Brethren, 17866 Glendale Drive, Frankfort SD 57440, has filed an application to amend Water Right No. 1876-3 by changing the location of a portion of the irrigated acres, adding an existing well, and adding a proposed well with no increase in irrigated acres or diversion rate authorized by No. 1876-3. Water Right No. 1876-3 appropriates 3.55 cubic feet of water per second (cfs) from one well completed into the Tulare: East James Aquifer located in the NW 1/4 NE 1/4 Section 11 for irrigation of 272 acres located in the SW 1/4, E 1/2 NW 1/4, W 1/2 NE 1/4 Section 11; all in T115N-R62W. This application proposes to relocate 136 acres from the SW 1/4 Section 11 to the SE 1/4 Section 2 and move the center pivot in the N 1/2 Section 11 to the west which will then also cover a portion of the W 1/2 NW 1/4 Section 11; all in T115N-R62W. This application also amends Water Right No. 1876-3 to add an existing Tulare: East James Aquifer well located in the NW 1/4 NE 1/4 Section 11 and a new well to be completed into the Tulare: East James Aquifer (140 feet deep), located near the center of the SE 1/4 Section 2; all in T115N-R62W. This application to amend Water Right No. 1876-3 does not authorize any increase in either the 3.55 cfs diversion rate, or 272 acres, authorized by Water Right No. 1876-3. This site is located approximately seven miles southeast of Frankfort SD.

Pursuant to SDCL 46-2A-2, the Acting Chief Engineer recommends APPROVAL of Application No. 1876A-3 because 1) the proposed diversion can be developed without unlawful impairment of existing domestic water uses and water rights, 2) the proposed use is a beneficial use and 3) it is in the public interest as it pertains to matters of public interest within the regulatory authority of the Water Management Board. The Acting Chief Engineer's recommendation with qualifications, the application, and staff report are available at <https://danr.sd.gov/public> or contact Ron Duvall for this information, or other information, at the Water Rights Program address provided below.

Any person interested in opposing this application or recommendation shall allege that the application, upon approval, will cause injury to the person that is unique from any injury suffered by the public in general. The injury must concern a matter either within the regulatory authority found in SDCL 46-2A-9 for approval or denial of the application, or other matter concerning the application within the regulatory authority of the board to act upon as defined by SDCL 46-2-9 and 46-2-11, or both. Any person meeting the petitioner requirements and wishing to be a party of record in a contested case hearing shall file a written petition to oppose the application with BOTH the applicant and Acting Chief Engineer. A petition opposing the application shall be filed on a form provided by the Acting Chief Engineer. The petition form is available online at <https://danr.sd.gov/public> or by contacting the Acting Chief Engineer. The Acting Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501" or call (605) 773-3352. The applicant's mailing address is given above. If contesting the Acting Chief Engineer's recommendation, the applicant shall also file a petition. A petition filed by either an interested person or the applicant must be filed by May 19, 2025.

The petition shall include a statement describing the unique injury upon approval of the application on the petitioner, the petitioner's reasons for opposing the application, and the name and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained.

Any interested person may file a comment on the application with the Acting Chief Engineer. The comment shall be filed on a form provided by the Acting Chief Engineer and is available online at <https://danr.sd.gov/public> or by calling (605) 773-3352 or writing the Acting Chief Engineer at the address provided above. Filing a comment does not make the commenter a party of record or a participant in any hearing that may be held. Any comment must be filed by May 19, 2025.

If the applicant does not contest the recommendation of the Acting Chief Engineer and no petition to oppose the application is received, the Acting Chief Engineer shall act on the application pursuant to the recommendation with no hearing held before the Water Management Board. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled, and the Water Management Board will consider this application. Notice of the hearing will be given to the applicant and any person filing a petition.

Published once at the total approximate cost of_

Rodriguez, Rachel

From: Rodriguez, Rachel
Sent: Monday, April 28, 2025 3:24 PM
To: Redfield Office
Subject: 1876A-3 Glendale Hutterian Brethren - Public Notice
Attachments: 1876A-3 public.short_final.docx; FORM8.FRM.doc

Attached is a notice to be published on May 7, 2025.

Glendale Hutterian Brethren, 17866 Glendale Drive, Frankfort SD 57440, 605-472-1247 has been notified to contact you to authorize publication and arrange for payment.

Please send the affidavit or return the attached Proof of Publication form ASAP to the Water Rights Program, 523 E Capitol Ave, Pierre SD 57501.

Let me know if you have questions. Please acknowledge receipt of this email.

Thank you,

Rachel Rodriguez
DANR | Program Assistant
Rachel.Rodriguez@state.sd.us



Rodriguez, Rachel

From: Rodriguez, Rachel
Sent: Monday, April 28, 2025 3:26 PM
To: Ruby Crandall
Subject: 1876A-3 Glendale Hutterian Brethren - Public Notice
Attachments: 1876A-3 public.short_final.docx; FORM8.FRM.doc

Attached is a notice to be published on May 7, 2025.

Glendale Hutterian Brethren, 17866 Glendale Drive, Frankfort SD 57440, 605-472-1247 has been notified to contact you to authorize publication and arrange for payment.

Please send the affidavit or return the attached Proof of Publication form ASAP to the Water Rights Program, 523 E Capitol Ave, Pierre SD 57501.

Let me know if you have questions. Please acknowledge receipt of this email.

Thank you,

Rachel Rodriguez
DANR | Program Assistant
Rachel.Rodriguez@state.sd.us



Affidavit of Publication

STATE OF SOUTH DAKOTA,
County of Spink: ss.

I, Cindy Crook, being duly sworn on oath, say that THE REDFIELD PRESS is a weekly newspaper as defined in Sec. 65.0508 South Dakota Code 1939, as amended by Chapter 298 of the Session of Laws of 1939, printed and published in the English language in the City of Redfield, in said County and State, by THE REDFIELD PRESS. I, Cindy Crook, am Legal Advertising Coordinator of said newspaper and know the facts herein state. The annexed notice headed:

#7825 NOTICE OF APPLICATION

was printed and published in said newspaper in 1 issue, to wit: The first publication being made on May 7th, That Forty-Six and 30/100 dollars insures to the benefit of the publisher of THE REDFIELD PRESS, that no agreement or understanding for the division thereof has been made with any other person, and that no part thereof has been agreed to be paid to any person whomsoever.

Cindy Crook

Subscribed and sworn to before me this 7th, day of May, 2025

Kayla Jessen

Notary Public, South Dakota

My commission expires 09/26/2030



Notice of Application

#7825

NOTICE OF APPLICATION NO. 1876A-3 to Amend Water Right No. 1876-3

Notice is given that Glendale Hutterian Brethren, 17886 Glendale Drive, Frankfort SD 57440, has filed an application to amend Water Right No. 1876-3 by changing the location of a portion of the irrigated acres, adding an existing well, and adding a proposed well with no increase in irrigated acres or diversion rate authorized by No. 1876-3. Water Right No. 1876-3 appropriates 3.55 cubic feet of water per second (cfs) from one well completed into the Tulare: East James Aquifer located in the NW 1/4 NE 1/4 Section 11 for irrigation of 272 acres located in the SW 1/4, E 1/2 NW 1/4, W 1/2 NE 1/4 Section 11; all in T115N-R62W. This application proposes to relocate 136 acres from the SW 1/4 Section 11 to the SE 1/4 Section 2 and move the center pivot in the N 1/2 Section 11 to the west which will then also cover a portion of the W 1/2 NW 1/4 Section 11; all in T115N-R62W. This application also amends Water Right No. 1876-3 to add an existing Tulare: East James Aquifer well located in the NW 1/4 NE 1/4 Section 11 and a new well to be completed into the Tulare: East James Aquifer (140 feet deep), located near the center of the SE 1/4 Section 2; all in T115N-R62W. This application to amend Water Right No. 1876-3 does not authorize any increase in either the 3.55 cfs diversion rate, or 272 acres, authorized by Water Right No. 1876-3. This site is located approximately seven miles southeast of Frankfort SD.

Pursuant to SDCL 46-2A-2, the Acting Chief Engineer recommends APPROVAL of Application No. 1876A-3 because 1) the proposed diversion can be developed without unlawful impairment of existing domestic water uses and water rights, 2) the proposed use is a beneficial use and 3) it is in the public interest as it pertains to matters of public interest within the regulatory authority of the Water Management Board. The Acting Chief Engineer's recommendation with qualifications, the application, and staff report are available at <https://danr.sd.gov/public> or contact Ron Duval for this information, or other information, at the Water Rights Program address provided below.

Any person interested in opposing this application or recommendation shall allege that the application, upon approval, will cause

injury to the person that is unique from any injury suffered by the public in general. The injury must concern a matter either within the regulatory authority found in SDCL 46-2A-9 for approval or denial of the application, or other matter concerning the application within the regulatory authority of the board to act upon as defined by SDCL 46-2-9 and 46-2-11, or both. Any person meeting the petitioner requirements and wishing to be a party of record in a contested case hearing shall file a written petition to oppose the application with BOTH the applicant and Acting Chief Engineer. A petition opposing the application shall be filed on a form provided by the Acting Chief Engineer. The petition form is available online at <https://danr.sd.gov/public> or by contacting the Acting Chief Engineer. The Acting Chief Engineer's address is "Water Rights Program, Fees Building, 523 E Capitol, Pierre SD 57501" or call (605) 773-3352. The applicant's mailing address is given above. If contesting the Acting Chief Engineer's recommendation, the applicant shall also file a petition. A petition filed by either an interested person or the applicant must be filed by May 19, 2025.

The petition shall include a statement describing the unique injury upon approval of the application on the petitioner, the petitioner's reasons for opposing the application, and the name and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained.

Any interested person may file a comment on the application with the Acting Chief Engineer. The comment shall be filed on a form provided by the Acting Chief Engineer and is available online at <https://danr.sd.gov/public> or by calling (605) 773-3352 or writing the Acting Chief Engineer at the address provided above. Filing a comment does not make the commenter a party of record or a participant in any hearing that may be held. Any comment must be filed by May 19, 2025.

If the applicant does not contest the recommendation of the Acting Chief Engineer and no petition to oppose the application is received, the Acting Chief Engineer shall act on the application pursuant to the recommendation with no hearing held before the Water Management Board. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled, and the Water Management Board will consider this application. Notice of the hearing will be given to the applicant and any person filing a

petition.

Published once at the total approximate cost of \$46.30 and may be viewed free of charge at www.sdpublicnotices.com. (May 7)

RECEIVED

JUN 02 2025

OFFICE OF
WATER

Proof Of Publication

Huron Plainsman
49 3rd Street SE
Huron, SD 57350
605-353-7402
Legal Notice Number: 3097

I, Shelly Ames, being duly sworn on oath say that the Plainsman is a daily paper published at Huron, Beadle County South Dakota, and that said newspaper has a bona fide circulation of at least 250 copies daily; that said newspaper has been published within said county for fifty-two consecutive weeks immediately prior to this date, that said newspaper is printed in whole or in part, in an office maintained at said place of publication; that I am a Legal Advertising Glendale Hutterian Brethren - Water No. 1876A-3 was published for one day, in said newspaper and not in any supplement of the said newspaper, the publication was on 5/07/2025. The full amount of the fee charged for publishing \$48.92 is to the benefit of the publisher of said newspaper; that no agreement or understanding of the division thereof has been made with any other person, and that no part thereof has been agreed to be paid to any person whomever.


Shelly Ames

Subscribed and sworn to me before this date 5/29/25.

Mark E. Davis

Notary Public, South Dakota

My Term Expires 12/27/2030



F. P. 05-07-25

**NOTICE OF
APPLICATION
NO. 1876A-3 to
Amend Water Right
No. 1876-3**

Notice is given that Glendale Hutterian Brethren, 17866 Glendale Drive, Frankfort SD 57440, has filed an application to amend Water Right No. 1876-3 by changing the location of a portion of the irrigated acres, adding an existing well, and adding a proposed well with no increase in irrigated acres or diversion rate authorized by No. 1876-3. Water Right No. 1876-3 appropriates 3.55 cubic feet of water per second (cfs) from one well completed into the Tulare: East James Aquifer located in the NW 1/4 NE 1/4 Section 11 for irrigation of 272 acres located in the SW 1/4, E 1/2 NW 1/4, W 1/2 NE 1/4 Section 11; all in T115N-R62W. This application proposes to

above.

Acting Chief Engineers recommendation, the applicant shall also file a petition. A petition filed by either an interested person or the applicant must be filed by May 19, 2025.

The petition shall include a statement describing the unique injury upon approval of the application on the petitioner, the petitioner's reasons for opposing the application, and the name and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained.

Any interested person may file a comment on the application with the Acting Chief Engineer. The comment shall be filed on a form provided by the Acting Chief Engineer and is available online at <https://danr.sd.gov/public> or by calling (605) 773-3352 or writing the Acting Chief Engineer at the address provided above. Filing a comment does not make the commenter a party of record or a participant in any hearing that may be held. Any comment must be filed by May 19, 2025.

If the applicant does not contest the recommendation of the Acting Chief Engineer and no petition to oppose the application is received, the Acting Chief Engineer shall act on the application pursuant to the recommendation with no hearing held before the Water Management Board. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled, and

application within the regulatory authority of the board to act upon as defined by SDCL 46-2-9 and 46-2-11, or both.

Any person meeting the petitioner requirements and wishing to be a party of record in a contested case hearing shall file a written petition to oppose the application with BOTH the applicant and Acting Chief Engineer. A petition opposing the application shall be filed on a form provided by the Acting Chief Engineer. The petition form is available online at <https://danr.sd.gov/public> or by contacting the Acting Chief Engineer. The Acting Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501" or call (605) 773-3352. The applicant's mailing address is given below. If contesting the

2000 - Legals

2000 - Legals

relocate 136 acres from the SW 1/4 Section 11 to the SE 1/4 Section 2 and move the center pivot in the N 1/2 Section 11 to the west which will then also cover a portion of the W 1/2 NW 1/4 Section 11; all in T115N-R62W. This application also amends Water Right No. 1876-3 to add an existing Tulare: East James Aquifer well located in the NW 1/4 NE 1/4 Section 11 and a new well to be completed into the Tulare: East James Aquifer (140 feet deep), located near the center of the SE 1/4 Section 2; all in T115N-R62W. This application to amend Water Right No. 1876-3 does not authorize any increase in either the 3.55 cfs diversion rate, or 272 acres, authorized by Water Right No. 1876-3. This site is located approximately seven miles southeast of Frankfort SD.

Pursuant to SDCL 46-2A-2, the Acting Chief Engineer recommends APPROVAL of Application No. 1876A-3 because 1) the proposed diversion can be developed without unlawful impairment of existing domestic water uses and water rights, 2) the proposed use is a beneficial use and 3) it is in the public interest as it pertains to matters of public interest within the regulatory authority of the Water Management Board. The Acting Chief Engineer's recommendation with qualifications, the application, and staff report are available at <https://danr.sd.gov/public> or contact Ron Duvall for this information, or other information, at the Water Rights Program address provided below.

Any person interested in opposing this application or recommendation shall allege that the application, upon approval, will cause injury to the person that is unique from any injury suffered by the public in general. The injury must concern a matter either within the regulatory authority found in SDCL 46-2A-9 for approval or denial of the application, or other matter concerning the

the Water Management Board will consider this application. Notice of the hearing will be given to the applicant and any person filing a petition.

No. 3097 (adv.)

Published once at the total approximate cost of \$48.92 and may be viewed free of charge at www.sdpublicnotices.com.



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 E. CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

JUN 11 2025

Glendale Hutterian Brethren
c/o John Kleinsasser
17866 Glendale Drive
Frankfort SD 57440

Dear Mr. Kleinsasser:

Enclosed is Water Permit No. 1876A-3 authorizing construction of the water diversion system and beneficial use of the water, not exceeding the limits as specified in the Water Permit.

Form 10, *Notice of Completion of Works and Application of Water to Beneficial Use*, is enclosed. Please return this completed form after you have finished the system and have put the water to beneficial use. An investigation can then be scheduled so the water license may be issued, thus completing the acquisition of a water right.

An informational sheet *Common Water Right Questions?* is also enclosed. This sheet is intended to answer some of the questions associated with obtaining and keeping a water right.

Sincerely,

Mark Mayer, PE
Director of Office of Water

enclosures



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 E. CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

STATE OF SOUTH DAKOTA)
) SS
COUNTY OF HUGHES)

**Affidavit of Public Notice
Posting on DANR Website**

Pursuant to SDCL § 46-2A-4, public notice of the following application was posted on the DANR web site at <https://danr.sd.gov/public>. The posted public notice is the same notice as published in the pertinent newspaper(s) and a copy of the public notice is maintained in the application file. If the application is contested, the posting is moved to the DANR contested case website at <https://danr.sd.gov/public/ContestedCase.aspx> until final action is taken on the application pursuant to SDCL § 46-2A-4.

Application No.: 1876A-3

Name of Applicant: Glendale Hutterian Brethren, John Kleinsasser

Date of Posting: 5/5/2025

Date of Removal: 6/11/2025



Ron Duvall, Engineer III

6/11/2025

Date

Subscribed and sworn to before me, a notary public, this 11th day of June, 2025.



Notary Public - South Dakota
My commission expires:

**Rachel Rodriguez
My Commission Expires
May 16, 2029**

(SEAL)



1876A-3

SOUTH DAKOTA WATER WELL COMPLETION REPORT

2024

Location <u>SW</u> $\frac{1}{4}$ <u>SE</u> $\frac{1}{4}$ Sec <u>2</u> Twp <u>115</u> Rg <u>62</u>		Well Owner: <u>Glendale Colony</u>																																	
County <u>Spink</u>		Business Name: _____																																	
GPS Coordinates _____		Address: <u>17866 Glendale Drive</u>																																	
Lat: _____ Lon: _____		City, State, Zip: <u>Frankfort, SD 57440</u>																																	
Please mark well location with an "X" on section grid		WELL LOG:																																	
Well Completion Date <u>5/6/2025</u>		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">FORMATION</th> <th colspan="2">DEPTH</th> </tr> <tr> <th>FROM</th> <th>TO</th> </tr> </thead> <tbody> <tr> <td>Top Soil</td> <td>0.0</td> <td>2.0</td> </tr> <tr> <td>Yellow Clay</td> <td>2.0</td> <td>20.0</td> </tr> <tr> <td>Blue Clay w/Sand</td> <td>20.0</td> <td>35.0</td> </tr> <tr> <td>Sand</td> <td>35.0</td> <td>70.0</td> </tr> <tr> <td>Sand & Gravel</td> <td>70.0</td> <td>77.0</td> </tr> <tr> <td>Shale</td> <td>77.0</td> <td>80.0</td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>		FORMATION	DEPTH		FROM	TO	Top Soil	0.0	2.0	Yellow Clay	2.0	20.0	Blue Clay w/Sand	20.0	35.0	Sand	35.0	70.0	Sand & Gravel	70.0	77.0	Shale	77.0	80.0									
FORMATION	DEPTH																																		
	FROM	TO																																	
Top Soil	0.0	2.0																																	
Yellow Clay	2.0	20.0																																	
Blue Clay w/Sand	20.0	35.0																																	
Sand	35.0	70.0																																	
Sand & Gravel	70.0	77.0																																	
Shale	77.0	80.0																																	
Distance from nearest potential pollution source (Septic tank, abandoned well, feed lot, etc.) ? None _____ ft. from _____ (identify source)		STATIC WATER LEVEL <u>21.7</u> FEET If flowing: closed in pressure _____ PSI GPM flow _____ through _____ inch pipe Controlled by ☐ Valve ☐ Reducers ☐ Other _____ Reduced flow rate _____ GPM Can well be completely shut in? _____																																	
PROPOSED USE: ☐ Domestic/Stock ☐ Municipal ☐ Business ☒ Monitoring Well ☐ Irrigation ☐ Industrial ☐ Institutional ☒ Test Hole ☐ Dewatering Well ☐ Geothermal ☐ Other _____		WELL TEST DATA: ☒ Pumped Describe: <u>submersible</u> ☐ Bailed ☐ Air ☐ Other _____ Pumping Level Below Land Surface <u>23.6</u> Ft. After <u>4.0</u> Hrs. pumped <u>30</u> GPM _____ Ft. After _____ Hrs. pumped _____ GPM If pump installed, pump rate: _____ GPM																																	
METHOD OF DRILLING: Mud Rotary		REMARKS																																	
CASING DATA: ☐ Steel ☒ Plastic ☐ Other If other describe _____		RECEIVED JUN 24 2025 OFFICE OF WATER																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>PIPEWEIGHT</th> <th>DIAMETER</th> <th>FROM</th> <th>TO</th> <th>HOLE DIAMETER</th> </tr> </thead> <tbody> <tr> <td>200 LB/FT</td> <td>4 IN</td> <td>0 FT</td> <td>35 FT</td> <td>6 3/4 IN</td> </tr> <tr> <td>250 LB/FT</td> <td>4 IN</td> <td>35 FT</td> <td>75 FT</td> <td>6 3/4 IN</td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>		PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER	200 LB/FT	4 IN	0 FT	35 FT	6 3/4 IN	250 LB/FT	4 IN	35 FT	75 FT	6 3/4 IN						This well was drilled under license # <u>722</u>													
PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER																															
200 LB/FT	4 IN	0 FT	35 FT	6 3/4 IN																															
250 LB/FT	4 IN	35 FT	75 FT	6 3/4 IN																															
GROUTING DATA: Grout Type <u>#20</u> No. of Sacks <u>2</u> Grout Weight <u> </u> Lb/gal From <u>0.0</u> Ft To <u>35.0</u> Ft Describe grouting procedure <u>Tremie Pipe</u>		And this report is true and accurate. Drilling firm: <u>Stretch's Well Service, Inc.</u>																																	
SCREEN: ☐ Perforated pipe ☒ Manufactured Diameter <u>4</u> Inches Length <u>40.0</u> Feet Material <u>PVC</u> Slot Size <u>0.025</u> Set From <u>35.0</u> Feet to <u>75.0</u> Feet Other information _____		Signature of License Representative: _____ Signature of Well Owner or Equitable Property Holder: <u>Zachy Waldner</u> Date: <u>6/16/2025</u>																																	
WAS A PACKER OR SEAL USED? ☒ Yes ☐ No If so, what material? <u>Enviro Plug</u> Describe packer(s) and location <u>Above Screen</u>		DISINFECTION: Was well disinfected upon completion? ☒ Yes, How? <u>Chlorine</u> ☐ No, Why Not? _____ Lab sample sent to for water quality analysis _____																																	

Please return White Copy to DANR Water Rights 523 E. Capitol Ave., Pierre SD 57501