

1. Considered JULY 24 1980
2. Name of Applicant WILBUR J. & EUGENE SLABA
3. Post Office Address WAGNER, S.D.
4. Amount of Water Claimed 2.2
5. Source of Water Supply 240' WELL (ADD'L DIVERSION 2218-3)
6. Water to be used for IRR.
7. Acres to be irrigated 160 maximum acre feet
8. Water to be diverted and used in CHARLES MIX County about 1W, 5 miles NORTH of WAGNER
9. PROOF OF PUBLICATION Received (1st) 6-30-80

Not Received _____
 Approved 7-24-80

Subject Land covered under this
 Not Approved WT & IQ #
 Action deferred _____


Priority 5-8-80? Date Received 5-8-80 Application Complete (yes) no FEE 150.00
 OR 2-20-75? Remarks ADD well on 2218-3, well on NE⁴ not producing sufficient water

R² 18-3 has undisputed

WATER QUALITY Date information and/or fee or corrected Application received Period of Annual use April thru September

Received (yes) 3/20/75 no (APPROVED)/CONDITIONAL (circle one)

WI-1 Description same as application yes no Remarks WA approved on orig. appl. 2218-3, protest was in deep well was not approved. Then came before SCC for extra land. SCC would not approve add'l acreage so Slaba decided to go just for the add'l well on old Permit, to be used only on 2218-3
 Disapproved _____ Returned _____



Diversion Point approx center NW⁴ Section 8-96-63

Lands to be irrigated NW⁴, Section 8-T96-R63

WELL LOG

Remarks _____
 Driller Sargent Irrigation Licensed (yes) no
 Depth 240' deep

MAP

Map No. 1614-3 Map located In Water Right X Map file _____

Type of Map Drawn Prepared by Harlan W. Meyer

+++++

REVIEWED

This Application was reviewed within 30 days of date received, accepted as complete. Number assigned and written up for advertisement before the Board on July 24, 1980. Betty Westlund
(Signed)

+++++

PROTESTS

Letters/Petitions in File - yes _____ no _____ Remarks _____

REMARKS


F.F. & C
OF LAW,
FINAL
DECISIONS
ETC.

Date _____
Final Decision, including F.F. & C of Law were adopted _____
Date _____
Final Decision mailed to parties and/or parties notified that Final Decision was adopted _____
Remarks: _____

* at the SCC meeting Mr. Slaba decided not to go ahead with applying for NW 2 SW 4, to delete that portion of land from the application because it would be disapproved as a conditional permit issued. Since he already has approved WA for NW 4 to be irrigated from this 235' well. Only has WA approval for this well on NW 4. This was agreed to by Mr. Slaba & Westlund. to use this well on NW 4 only.

No. 4526-3Map No. 3747-3 Water Division No. 3 MISSOURI RIVER District

Above for Office Use

10170101

12:30pm

APPLICATION FOR PERMIT To Appropriate Water within the State of South Dakota

Check one of the following:

New ☐ Vested Right ☐ Future Use ☐Change in Diversion ☐ Additional Diversion ☒ on Permit No. 2218-3Change in Acreage ☐ Additional Acreage ☐

- Name of Applicant Wilbur J. & Eugene Slaba Phone No. (605) 384-5138
Post Office Address Route 1 Wagner State South Dakota 57380
(Street, RR, or Box) (Town) (Zip Code)
If a corporation show date and place of incorporation _____
- Method of accomplishing work (contract, employment of others, or by direct labor) contract
- Name of diversion work Wilbur J. & Eugene Slaba Well #2
- Amount of water claimed (cubic feet per second) 2.2
- Source of water supply one well (deep aquifer)
- Location of point of diversion 1370 feet South & 1370 feet East of NW corner of Section 8,
T96N, R63W SE 1/4 NW 1/4

County Charles Mix

- Annual period or periods during which water is to be used April thru September
- Use to be made of water, (irrigation, industrial, municipal, commercial, recreation, etc.) irrigation
- For irrigation use, 160 Total number of acres to be irrigated 160

List below each forty-acre subdivision, or lot, or fraction thereof and show number of acres to be irrigated in each.

Land Description	No. Acres Irr.
<u>NW 1/4 NW 1/4 8, T96N, R63W</u>	<u>40</u>
<u>NE 1/4 NW 1/4 8, T96N, R63W</u>	<u>40</u>
<u>SW 1/4 NW 1/4 8, T96N, R63W</u>	<u>40</u>
<u>SE 1/4 NW 1/4 8, T96N, R63W</u>	<u>40</u>

Land Description	No. Acres Irr.

Attach sheet if more space is needed

- Time required to complete construction of water supply system 5 years. Additional time required to complete application of water to the proposed beneficial use 2 years.
- Choice of county newspaper for publication of Notice of Intent to Appropriate Water WAGNER POST
- Principal Features of the Proposed Water Supply System.

A. Works proposed to divert water from its natural source.

Pump & Motor

B. Works proposed to transport water to place of use.

Pipe to Center Pivot

C. Works proposed to apply water to beneficial use.

Center Pivot

Estimated Total Cost \$ _____

Attachments: Attach Form 2A if diversion from a well or dugout, or if storage of water, is proposed. Attach map. (see instructions concerning preparation.)

STATE OF SOUTH DAKOTA)
County Charles Mix)ss.I, Wilbur J. & Eugene Slaba the applicant, certify that I have read the foregoing application and have examined the attached map and that the matters therein stated are true and that I intend, and am able to complete the necessary construction.Signed Wilbur J. & Eugene SlabaSubscribed and sworn to before me this 8th day of May, 1980Karen Wernsmann
Notary Public (or other qualified officer)

WATER RIGHT APPLICATION APPROVAL

The Water Management Board hereby approves Water Right Application No. 4526-3

WILBUR J. & EUGENE SLABA

(Applicant)

RR #1, WAGNER

(Post Office Address)

SOUTH DAKOTA

(State)

57380

With the following qualifications.

The irrigation well approved under this Permit will be located near domestic wells and other irrigation wells which may obtain water from the same aquifer. The irrigation well owner, under this permit, shall control his irrigation withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in irrigation wells having prior water rights.

This Permit is approved subject to the irrigation water use questionnaire being submitted each year.

Lands covered under this Permit are also covered under Permit No. 2218-3. Combinations of diversions under the two permits shall not exceed the Statutory limit of 1 c.f.s. for each 70 acres of land to be irrigated.

Date of first receipt of application MAY 8, 1980

Date of return to applicant for correction, amendments or changes required _____, 19____

Date of receipt of corrected application _____, 19____

Approved JULY 24, 1980 Recorded in Book 21 Page 211

WATER RIGHT PERMIT NO. 4526-3

The Water Management Board hereby grants and issues this Water Right Permit No. 4526-3 authorizing the construction of the water use system and the putting of water to beneficial use as stated in the Application and as qualified in the Water Right Application approval, subject, however, to the following limitations and conditions:

1. The date from which applicant may claim right is MAY 8, 1980
2. The equivalent of at least one-fifth of the work above specified is to be completed on or before JANUARY 24, 1983
3. The whole of said work is to be completed on or before JULY 24, 1985
4. The limit of time from proof of beneficial use of water appropriated in accordance herewith is JULY 24, 1987
5. The water appropriated shall be used for the purpose of IRRIGATION

6. The prior right of all persons who, by compliance with the laws of the State of South Dakota, have acquired a right to the use of water must not be injuriously affected by this appropriation.

7. The amount of the appropriation herein granted shall not exceed 2.2 cubic feet per second; neither shall it exceed the capacity of the above described water supply system, nor shall it exceed the amount of water needed for beneficial uses served, and if for irrigation purposes said appropriation must be limited to not more than 2 acre feet per acre per year and be limited to not more than one-seventieth (1/70) of one cubic foot of water per second of time for each acre of land to which water is actually and beneficially applied

for irrigation on or before JULY 24, 1987; said water to be used during the following described annual period: APRIL THRU SEPTEMBER

Witness my hand this 28th day of JULY, 1980

THE WATER MANAGEMENT BOARD

By: John Ketch
Chief Engineer, Water Rights

Certificate of Construction Issued _____, 19____

Water License Issued _____, 19____

SARGENT IRRIGATION CO.

Broken Bow
308-872-6451

Gothenburg
308-537-3025

Bassett
462-684-3323

Grant
308-352-4370

TEST WELL LOG

To: Mr. J. Edgar Hoover

Date: 12/1/78

Address: 1111 1st St. N. W.

1891/1892 10/10/1891 10/10/1891 10/10/1891

0	20	1000
20	40	1100
40	60	1200
60	80	1300
80	100	1400
100	120	1500
120	140	1600
140	160	1700
160	180	1800
180	200	1900
200	220	2000
220	240	2100
240	260	2200
260	280	2300
280	300	2400
300	320	2500
320	340	2600
340	360	2700
360	380	2800
380	400	2900
400	420	3000
420	440	3100
440	460	3200
460	480	3300
480	500	3400

Form 2A - Wells, Dugouts or Water Storage Dams (Supplement to Form 2)

12. Principal Features of the Proposed Water Supply System (continued).

D. Well Information

- (1) Drill Hole, Diameter 32", Depth _____
- (2) Casing, Type Plastic (wood, concrete, steel, etc), Diameter 16", Thickness _____
- (3) Screen, Type Johnson, Diameter 16", Length 50'
- (4) Gravel Pack, Thickness 7", Length of gravel pack 235'

E. Dugout Information or Estimates

- (1) Surface dimensions, _____, Depth _____

F. Fill out for Either a Well or a Dugout.

- (1) Water Bearing Materials. (Attach a copy of test well log)

Depth to top of water bearing material 40'

Depth to bottom of water bearing material 235'

Depth to water (ground surface to water level) 40'

- (2) Distance to nearest existing household or livestock watering well.


On same owner's property 170 rds.

On property owned by others 170 rds.

G. Water Storage Dams

If the proposed water use system contains one or more water storage dams, please show in the space below, the height, length, maximum water depth, surface area, drainage area, storage capacity, dam slope, dimensions, location and size of outlet works, of each storage dam. The location of each water storage dam should be shown on the water right map.

Normal
Water
Surface



1. Freeboard _____

2. Crest width _____

3. Height of Dam _____

4. Outlet dimensions:

Pipe diameter _____

Spillway width _____

X & Y slope:

Upstream _____

Downstream _____

Surface area of impoundment _____


Drainage area above dam _____

William J. Laka Eugene J. Laka
Signature Applicant

RECEIVED

FEB 20 1975

DEPT. OF NATURAL
RESOURCE DEVELOPMENT



February 11, 1975

Ms. Katharine Slaba
Wagner, SD 57380

Dear Ms. Slaba:

We have now received the WI-1 form relating to your application for irrigation in NW 1/4 Sec 8 T96N R63W.

I am returning herewith the original copy of the water analysis which is yours to keep and my earlier letter to you, as well as a copy of Extension Circular 654. The approximate quality for irrigation purposes of the water sample you submitted is indicated by the encircled red cross on the outside back cover. You will note that it falls near the outer extreme of "High Salinity - Medium Sodium" water. This means that it has both a hazard for salinity or total salt accumulation in the root zone of plants and somewhat of a hazard for the dispersion of soil clays. Such dispersion results in difficult tillage operations, cloddiness, poor structure, lack of easy emergency by germinating plants and poor root exploitation of the soil. We certainly hope that such will not happen but you should be fully aware that there is a danger of this with your soil. We have waters very similar to this in several parts of the state which have caused fairly severe dispersion problems within ten years of the beginning of their use.

I recommend that if you develop this water source for irrigation you apply it infrequently and in rather large amounts. In other words, something like 2 1/2 - 3 inches at a time would be a minimum application. Such application slows down the tendency for salt and sodium accumulation in the root zone. An infrequent large amount is much better for the soil than frequent small amounts, such as an inch or 1 1/2 inches. There are several reasons for this, but I will mention only one. That is that when you have the soil rooting zone fully filled with water there are greater chances for natural rainfall which might occur after or between irrigation and displacing the salt and sodium downward. This is, of course, depending upon chance and it is possible to be more certain of this taking place by late fall irrigations which fill the soil profile with water and then getting some displacement of salt and sodium downward by the natural precipitation which we experience most fall, winter and spring periods when evaporation is much less than our precipitation.

Need WA on SW 1/4 (100000)

Cont. . . /2.

Ms. Katherine Slaba

February 11, 1975

Page 2.

A copy of this letter and the WI-1 form and a copy of the water analysis are being forwarded to the State Conservation Commission.

Sincerely yours,

L. O. Fine

L. O. Fine
Water Quality Lab

LOF:MRB

Inclosures

CC: State Conservation Commission
Arnold Rieckman, Charles Mix County Agent
Darral Pahl

STATE CONSERVATION COMMISSION
SUPPORTING INFORMATION
FOR APPROPRIATION OF GROUND WATER IN ACCORDANCE
WITH SDCL 46-6-3 AS AMENDED
(This Form Required for Proposed Well Irrigation Only)

FOR COMMISSION USE (C)

Irrigation System: _____

Water Quality: _____

Soils Capability: _____

Approved: [Signature] 8-8-84
211/2/55

Disapproved: _____

NAME: Katherine Siegel

ADDRESS: Wagoner St 29

COUNTY: Charles Mix

LEGAL DESCRIPTION

1. WELL LOCATION: Center NW 1/4 Sec 8-96-63

2. AREA TO BE IRRIGATED: NW 1/4 Sec 8-96-63

TYPE OF IRRIGATION

3. GRAVITY

SPRINKLER (Indicate Type): Center Pivot

4. CROPS TO BE IRRIGATED: Corn

LAND CAPABILITY FOR IRRIGATION

5. PERCENTAGE OF SLOPE: 0-4% Center 1/4 Sec 8-96-63

6. PHYSICAL SOILS CLASSIFICATION FOR IRRIGATION: Silt loam

Shallow, well sorted, silty, calcareous, high

Silt loam Intake Rate 0.5 (66% 1.15)

WATER QUALITY (TO BE COMPLETED BY COMMISSION)

7. SAMPLE NO.: 75-053

8. SALINITY: EC = 2075 micromhos/cm (high)

9. SODIUM: SAR = 7.84 (medium)

I do hereby certify that a chemical analysis of the ground water to be
acquired for irrigation from South Dakota State University and:

the land capability for irrigation information has been acquired from

Soil Conservation office, Lake Center, S. D.

and:

that the legal description for the location of the well and land to be
irrigated is true and correct.

Netherland State

Subscribed and sworn before me this

15 day of June 1975.

[Signature]

NOTARY PUBLIC
STATE OF SOUTH DAKOTA

(Title)

REPORT OF ANALYSIS
Water Quality Laboratory
Water Resources Research Institute
South Dakota State University
Brookings, South Dakota 57006

Sheet 240

Submitted by: Katharine Klaba
 Address: Wagner, S.D. 57380

Date Rec'd: January 27, 1975
 Sample No.: 75-053
 Identification: 6011-
Na, Dec. 8, T 9611, 3 63

WATER ANALYSIS

Calcium (Ca)	120	ppm*	6.00	me/l**
Magnesium (Mg)	24	ppm	1.27	me/l
Sodium (Na)	360	ppm	15.66	me/l
Potassium (K)	25	ppm	0.65	me/l
Sulfate (SO ₄)	612	ppm	12.74	me/l
Nitrate (as N)		ppm		me/l
Chloride (Cl)	170	ppm	4.76	me/l
Bicarbonate (HCO ₃)	254	ppm	4.16	me/l
Carbonate (CO ₃)		ppm		me/l
Iron (Fe)		ppm		me/l
Fluoride (F)		ppm		me/l
Hardness (EDTA as CaCO ₃)		ppm		me/l
Alkalinity (Methyl Orange)	208	ppm (as CaCO ₃)		B.P.G.***
Alkalinity (Phenolphthalein)	0	ppm (as CaCO ₃)		
Electrical Conductivity	2075	micromhos per cm at 25° C.		
Sodium Adsorption Ratio	7.84			
Sodium	64.49	% of cations		
Residual sodium carbonate	0.00	me/l		
pH	7.35			

*ppm=parts per million

**me/l=milliequivalents per liter

***B.P.G.=grains per gallon

COMMENTS: Total cations 24.28 me/l
 Total anions 21.66 me/l

By: Shirley Hutton

Service Performed	Amount Due
IRRIGATION ANALYSIS	6.00

Make checks payable to: Water Quality Laboratory

Cut along dotted line and return the lower portion with payment

Sample No. 75-053

Amount Enclosed \$

Signed

No. 4526-3

Publish first publication, on or before June 12, 1980

NOTICE OF HEARING ON
APPLICATION TO APPROPRIATE WATER

Pierre, South Dakota 57501

June 11, 1980

Notice is hereby given that Wilbur & Eugene Slaba whose post office address is Wagner, South Dakota, has made an application in accordance with the provisions of SDCL 46-1-1 thru 46-1-9, 46-1-14; 46-2-9 thru 46-2-11, 46-2-13; 46-5-1 thru 46-5-8; 46-5-10 thru 46-5-22, 46-5-41; 46-6-3, 46-6-3.1, 46-6-5, 46-6-6.1, 46-6-10, 46-6-14 and Board Rules ARSD 52:01:01:01 thru 52:01:01:13, for a permit to appropriate for beneficial use 2.2 cubic feet of water per second of time from groundwater (one well) through the Wilbur & Eugene Slaba Well #2 the point(s) of diversion of which is (see map) to be located in the approximate center of the NW 1/4

of Section 6, Twp. 25N, Range 63W. Said water to be used for the purpose of providing irrigation on portions of the following described land:

NW 1/4, Section 8, T26N, R63W

This Application No. 4526-3 will be considered by the Water Management Board at Meeting Room #1, Knapp Building Church & Illinois, Pierre SD upon the 24th day of July, 1980 at 10 A.M. The Board is authorized to make a determination on this application at the hearing. All interested persons may appear and be heard. Any person who may be affected by a Board decision who desires to present evidence or cross-examine witnesses according to SDCL 1-26 may notify the Board in writing prior to the hearing or orally at the hearing.

This hearing is an adversary proceeding. Any person has the right to be present or to be represented by a lawyer. These and other due process rights will be forfeited if they are not exercised at the hearing. Decisions of the Board may be appealed to the Courts as provided by law.

Any handicapped person wishing to attend this hearing can contact the Water Rights Division, DWR, Joe Foss Building, Pierre SD, prior to the hearing date for assistance to assure access to the hearing.

WATER MANAGEMENT BOARD

cc: Wilbur J. & Eugene Slaba
PR #1
Wagner SD 57380

BETTY WESTZUND
Water Rights Specialist

WNR-806A-7/79
GROUNDWATER

Form 8 - Proof of Publication - Notice of
Intent to Appropriate Water

No. 4526-3

PROOF OF PUBLICATION

STATE OF SOUTH DAKOTA)
County Charles Mix) ss.

I, John Faugher hereby
certify that the annexed printed copy of Notice of Intent to Appropriate

Water was taken from the Wagner Pool

A newspaper which during the whole time of publication of said notice
herein after stated, has been and is printed and published in the _____

city of Wagner

County of Charles Mix and State of South Dakota;
that the said notice was published in said newspaper on the following
two dates:

June 19, 1980

June 26, 1980

John Faugher
(Signature)

Public
(Title)

6-26-80
(Date Signed)

Public notice
NOTICE OF HEARING ON AP-
PLICATION TO APPROPRIATE
WATER. Notice is hereby given that
Wilbur J. and Eugene Slaba
whose post office address is
Wagner, South Dakota, has
made an application in
accordance with the provisions
of SDCL 46-1-1 thru 46-1-9, 46-1-
14, 46-2-9 thru 46-2-11, 46-2-13,
46-5-1 thru 46-5-8, 46-5-10 thru
46-5-22, 46-5-41, 46-6-3, 46-6-3.1,
46-6-5, 46-6-6.1, 46-6-10, 46-6-
14, and Board Rules ARSD
52-01-01.01 thru 52-01-01.13, for
a permit to appropriate for
beneficial use 2.2 cubic feet of
water per second of time from
groundwater (one well) through
the Wilbur and Eugene Slaba
Well #2, the point of diversion
of which is to be located at the
approximate center of the
NW 1/4 of Section 8, Twp. 36N,
Range 63W. Said water to be
used for the purpose of
providing irrigation on portions
of the following described
land: NW 1/4, Section 8, T96N,
R63W.
This Application No. 4526-3
will be considered by the Water



RECEIPT

WATER RIGHTS COMMISSION
State of South Dakota

No 4 7039

PIERRE, September 13, 1979

RECEIVED OF Slaba Brothers, Wilbur J. Slaba, Wagner, SD 57386

the following amount in fees for services rendered as provided for by law:

FUND 290

Fee for Application for Permit to Appropriate Water No. 4526-3 (examination, processing, recording and filing)	150	00
Fee for inspecting Construction, and issuing Cert. of Construction No.		
Fee for inspecting Beneficial Use, and issuing Water License No.		
Fee for issuing Location Certificate-Dry Draw, No.		
Fee for filling		
Fee for certified copy of		
Fee for Print copy of map		
Fee for Certifying		
Fee for (any other work as provided by law)		
TOTAL	150	00

WATER RIGHTS COMMISSION

By John Hatch
Chief Engineer, Executive Officer
JOHN HATCH gy 84

RECEIPT

Division of Water Rights

No 4 9715

South Dakota Department of Water and Natural Resources

Pierre,

July 23

1994

RECEIVED OF Wilbur J. Slaba, RR#1, Box 163, Wagner, SD 57380

the following amount in fees for services rendered as provided for by law:

Fee for Application for Permit No. _____ to Appropriate Water, to construct works and to put water to beneficial use _____	
Fee for Application for Permit No. _____ to Appropriate Water for Future Use _____	
Fee to retain Future Use Permit No. _____ after period of seven years _____	
Fee for Inspecting Constructed Works, confirming beneficial use and issuing Water License No. _____	2 50
Fee for Filing Transfer Form 4526-3 _____	
Fee for Filing Extension Request _____	
Fee for Certified Copy of _____	
Fee for Print Copy of Map _____	
Fee for Certifying _____	
Fee for _____	
(Any Other Work Provided by Law)	
Total	2 50

By

Chief Engineer

JOHN HATCHER

NO. 4526-3

NOTICE OF TRANSFER OF WATER PERMIT

TO: Water Rights
Foss Building
Pierre, SD 57501

Date: July 23, 1984

This is to notify you that the title to the lands described as follows:

NW4 section 8 T96N-R63W

formerly owned by Wilbur & Eugene Slaba

has been transferred to Wilbur Slaba SD#1 Box 163 Wagner SD

(please include complete mailing address)
together with any rights to the beneficial use of water thereon as evidenced by

Water Right Permit No. 4526-3 as provided for in SDCL 46-5-32 and 46-5-33.

You are therefore hereby requested to file this "Notice of Transfer of Water Permit" in its appropriate file at the Div. of Water Rights, Water Management Board as evidence of the change of ownership.

A fee of Two Dollars and Fifty Cents (\$2.50) is hereto attached to cover filing fees as required under SDCL 46-2-13.

STATE OF SOUTH DAKOTA)

County of Hughes) ss.

I, Wilbur Slaba being first duly sworn on my oath depose and say:
That my relation to the above described undertaking is that of Owner; that I have read the above foregoing statement, and I know of my own personal knowledge that the information herein stated is true.

Wilbur Slaba
(Signed)

Subscribed and sworn to before me this 23 Day of July, 1984.

Kevin C. Larsen
(Notary Public)
Nat. Resources Eng.
Water Rights Division

WNR-820-9/83

Notice of Transfer of Water Permit



4526-3

DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3181

SEP 6 1995

5811-3

Wilbur J. Slaba
RR 1, Box 163
Wagner, SD 57380

Dear Mr. Slaba:

Enclosed is Water License No. 5811-3. This is the final water right document completing your process of obtaining a Water Right. Enclosed is Receipt No. 414527 in the amount of \$50.00 which you paid for the inspection and issuance of the Water License.

For your information SDCL 46-6-27 requires that if the owner of an existing well, such as the well authorized by Water Right No. 5811-3, constructs a replacement well and does not plan to use the old well, the old well is considered abandoned and must be plugged. Also, any well that is being used or is not considered abandoned must be valved and controlled, if flowing, or sealed and capped so that no leaking occurs either underground or at the surface.

As long as you use the water beneficially, as stated in the Water License, the State Water Laws provide that you have a continuing right to use the water. If you have any questions, please contact our office.

Very truly yours,

JOHN HATCH, Chief Engineer
Water Rights Division
(605) 773-3352

rd
enclosures

NOTE: The applicable portions of Water Permit No. 4526-3 have been incorporated into this Water License No. 5811-3.