

WATER PERMIT NO. 6397-3

Name of Applicant: SD Department of Transportation

Address: PO Box 568, Vermillion SD 57069

Phone: 605 624-6835

Amount of Water Claimed: 0.1 cfs (45 gpm)

Total Acres: NA

Source of Water Supply: groundwater (1 well)

Water to be used for: institutional

County: Union

Type of Waste Disposal System:

Location: off I-29 near Junction City (8 miles northwest of Elk Point)

PRIORITY

Date Received: 2-18-03

Application/License Fee: \$NA

Corrected Application Received:

Period of Annual Use: January 1 – December 31

Remarks: replace evaporation loss in wastewater lagoon at Junction City shop

Diversion Point: SE ¼ NE ¼ Sec 18-T92N-R50W

Land to be Irrigated: NA

Depth of Well: 200

Well Driller: :

Remarks:


Type of Map: topo

Prepared by: Ronald D Peterson, PE

Reviewed and the Number Assigned on: 2-18-03

By: Karen Schlaak

Notice of Hearing - date to intervene: _____



**SOUTH DAKOTA
WATER PERMIT NO. 6397-3**

Date of first receipt of application February 18, 2003.

The Chief Engineer, on behalf of the Water Management Board, issues Water Permit No. 6397-3 to SD Department of Transportation, PO Box 568, Vermillion SD 57069 authorizing the construction of the water use system and the placing of water to beneficial use subject to the following limitations, conditions and qualifications:

1. Water Permit No. 6397-3 appropriates 0.1 cubic feet of water per second (45 gallons per minute) from one well (Lower Vermillion: Missouri Aquifer) 200 feet deep located in the SE ¼ NE ¼ Section 18-T92N-R50W. The water is to replace evaporation loss in a wastewater lagoon at the Junction City transportation shop
2. The water appropriated shall be used for the purpose of institutional use and may not exceed the amount of water needed for beneficial use.
3. The water is to be used during the following described annual period: January 1 – December 31.
4. The date of approval of Permit No. 6397-3 is May 5, 2003.
5. The date from which applicant may claim right is February 18, 2003.
6. One-fifth of the construction is to be completed on or before November 5, 2005.
7. All construction is to be completed on or before May 5, 2008.
8. Water is to be put to beneficial use on or before May 5, 2012.
9. Water rights obtained in compliance with the laws of the State of South Dakota may not be unlawfully impaired by this appropriation.

QUALIFICATIONS

1. The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
2. The well authorized by Permit No. 6397-3 shall be constructed by a licensed well driller and construction of the well and installation of the pump shall comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.

WATER MANAGEMENT BOARD

By: Garland Erbele

Garland Erbele, Chief Engineer
Water Rights Program
Department of Environment and Natural Resources

JUN 13 2003

date



FORM 2: Application for uses other than irrigation
(type or print)

Mail to: Water Rights Program Joe Foss Building 523 E. Capitol Pierre, SD 57501-3181 (605) 773-3352	No. <u>6397-3</u>	(office use only) Hydrologic Unit <u>10170203</u>
	Basin <u>Sioux River</u>	
	Newspaper <u>Leader Courier, Elk Point</u>	

RECEIVED
FEB 18 2003
WATER RIGHTS
PROGRAM

Application For Permit To Appropriate Water Within The State Of South Dakota

Check use(s) of water:

☐ Municipal	☐ Suburban Housing	☐ Recreational	☒ Institutional
☐ Rural Water System	☐ Commercial	☐ Fish & Wildlife	☐ Geothermal Heat
☐ Domestic (over 18 gpm)	☐ Industrial	☐ Other _____	

Type of Application:
(check one)

☒ New ☐ Vested Right (Use predates Mar 2, 1955) ☐ Future Use Reservation
☐ Place to Beneficial Use Water Reserved by Future Use Permit No. _____
☐ Amendment/Correction to Permit No. _____

Description of amendment/correction: (i.e. change diversion point(s), add diversion point(s), change use, etc.)

- Name of Applicant So. Dak D.O.T. Phone 624-6835
(check one) ☒ Owner ☐ Tenant/lessee
Mailing Address PO Box 508, Vermillion SD 57069 State _____
(Street, RR, or Box and City) (Zip Code)
- Amount of water claimed 0.1 *CFS or 45 **GPM ***AF
(*Cubic Feet per Second) (**Gallons per Minute) (**Acre Feet - storage capacity of dam/dugout or annual use if applicable)
- Source of water supply well, Lower Vermillion-Missouri Aquifer
- Location of point of diversion (example - 3 wells in SW1/4 NE1/4 section 12-T104N-R53W) County Union
1 well in Twp 92 N, Range 50 W, Section 18, SE 8 NE 1/4
- County or counties where water will be used Union
- Annual period during which water is to be used year round Jan 1 - Dec 31
- Give a description of the project. When available include any preliminary engineering report or other reports or information that will help explain the project. (Attach sheet if more space is needed)
Replace EVAPORATION loss in WASTEWATER lagoon

STATE OF SOUTH DAKOTA)
County of Clay) SS

Attachments: Attach Form 2A if diversion is from a well or dugout, or if storage of water is proposed. Attach map and any other technical information. (see instructions)

I, Ronald Peterson, the applicant, certify that I have read this application, have examined the attached map and that the matters stated are true and that I intend, and am able to complete the necessary construction.

Applicant's signature Ronald Peterson

Subscribed and sworn to before me this 13th day of February 2003

William Helges

Notary Public signature

Commission expires Sept 10, 2008

(type or print in ink)

1. Well Information - Proposed Construction

- a) Drill Hole Diameter 9" Depth 200'
- b) Casing Type PVC Diameter 5" Thickness 1/4" (SDR 21)
- c) Screen Type PVC Diameter 5" Thickness 1/4" (SDR 21)
- d) Gravel Pack 1/16" - 1/4" Length of Gravel Pack 25'
- e) Depth to Top of Water Bearing Material 110'
- f) Depth to Water (ground surface to water level) 85'
- g) Distance to nearest existing domestic well:
- On applicants property None On property owned by others 3500'

2. Wastewater Disposal System Information

- a) Type of System (i.e. septic tank, drain field) _____
- b) System Capacity (gallons) _____ Year Constructed _____
- c) Connected to the City of _____ Sanitary System


3. Dugout Information

- a) Surface Dimensions _____ Depth _____
- b) Depth to water (ground surface to water level) _____

4. Water Storage Dams

If the proposed water use system contains one or more storage dams, please furnish the information requested below for each dam. The locations of the dams need to be shown on the map submitted with the application.

- a) If a private engineering firm or government agency was involved in the design of this dam, please give their name and address:



- b) Freeboard _____
- c) Crest Width _____
Crest Length _____
- d) Height _____
- e) Primary Outlet Capacity _____
If pipe, diameter _____
- f) Secondary Spillway Capacity _____
Spillway Width _____
- g) X & Y Slope _____
Upstream _____
Downstream _____
- h) Surface Area of Impoundment _____
- i) Storage _____ Acre Feet
- j) Drainage Area Above Dam _____ Acres



x Proposed Well Location

Junction City

B R U L E

Sandpits

BR 1177

CLAY CO
UNION CO

Slough

REPORT ON WATER PERMIT APPLICATION NO. 6397-3
For South Dakota Department of Transportation
March 27, 2003

Application No. 6397-3 proposes to appropriate 0.1 cfs (45 gpm) from one well approximately 200 feet deep located in the SE ¼ NE ¼ of section 18, T92N R50W in Union County. The water is to replace evaporation loss in a wastewater lagoon at the Junction City Transportation Shop.

AQUIFER – LOWER VERMILLION MISSOURI (LVM)

The Lower Vermillion Missouri aquifer is a buried outwash (sand and gravel) that is under confined or artesian conditions in this area. The aquifer underlies 24,800 acres and contains an estimated 372,000 acre-feet of recoverable water in storage in Union County (Hedges, 1982). The aquifer extends into Clay County to the west and blends into the Missouri Elk Point aquifer to the south. Ground water movement is southerly in the aquifer (Niehus, 1994). Even though technically the aquifer is under artesian conditions, the water level behavior in the observation wells completed into the Lower Vermillion Missouri mimic water table conditions.

No test well was completed for this application; however, there is sufficient information available from the Clay and Union County Studies and area domestic, irrigation and observation well drilling to determine water availability from the aquifer.


The Water Rights Program monitors an observation well UN-77I completed into the Lower Vermillion Missouri aquifer and located about two miles north of this application. The water level record indicates that the aquifer is capable of sustaining additional withdrawals (Water Rights, 2003). A hydrograph for this observation well is included with this report.

REVIEW OF EXISTING WATER PERMITS/RIGHTS

The nearest existing water right is No. 2896-3 which is located about 1 ½ miles northeast of this application. Interference is not a concern. This request is for a small amount of water at a relatively small rate. Drawdown created by pumping at this rate in this aquifer is not significant.

CONCLUSIONS

1. Water is available from the Lower Vermillion Missouri aquifer.
2. The aquifer appears to be under confined conditions, however, the water levels respond as if the aquifer is under water table conditions. Drawdown is not significant and interference is not a concern.
3. This well must be constructed in accordance with SD Well Construction Standards.



James A Goodman
Natural Resources Engineer



**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.state.sd.us/denr

**RECOMMENDATION OF CHIEF ENGINEER FOR WATER PERMIT
APPLICATION NO. 6397-3, SD Department of Transportation**

Pursuant to SDCL 46-2A-2, the following is the recommendation of the Chief Engineer, Water Rights Program, Department of Environment and Natural Resources concerning Water Permit Application No. SD Department of Transportation, c/o Ronald Peterson, PO Box 568, Vermillion SD 57069.

The Chief Engineer is recommending APPROVAL of Application No. 6397-3 because 1) there is reasonable probability that there is unappropriated water available for the applicant's proposed use, 2) the proposed diversion can be developed without unlawful impairment of existing rights, 3) the proposed use is a beneficial use and 4) it is in the public interest with the following qualifications:

The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.

The well authorized by Permit No. 6397-3 shall be constructed by a licensed well driller and construction of the well and installation of the pump shall comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.

See report on application for additional information.

Garland Erbele, Chief Engineer
April 1, 2003

PROOF OF PUBLICATION

STATE OF SOUTH DAKOTA)
) SSCounty of Union)I, Susan Odsoncertify that the attached printed Notice was
takenfrom the Leader-Courierprinted and published in Elk PointCounty of Union and

state of South Dakota. The notice was published

in the newspaper on the following two dates:

April 17, 2003April 24, 2003Cost of Printing 37.88Susan Odson

(Signature)

Affidavits Coordinator

(Title)

April 24, 2003

(Date Signed)

NOTICE OF APPLICATION
NO. 6397-3 TO
APPROPRIATE WATER

Notice is given that the South Dakota Department of Transportation, PO Box 568, Vermillion, SD 57069 has filed an application for a water permit to appropriate 0-1 cubic feet of water per second (45 gallons per minute) from one well (Lower Vermillion: Missouri Aquifer) 200 feet deep located in the SE 1/4 NE 1/4 Section 18-T92N-R50W. The water is to replace evaporation loss in a wastewater lagoon at the Junction City transportation shop.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application No. 6397-3 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water and 4) it is in the public interest. In accordance with SDCL 46-2A-23, the Chief Engineer will act on the application, as recommended, unless a petition is filed opposing the application or the applicant files a petition contesting the Chief Engineer's recommendation. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled and the Water Management Board will consider the application. Notice of the hearing will be given to the applicant and any person filing a petition.

Any person interested in opposing or supporting this application or recommendation must file a written petition with BOTH the applicant and Chief Engineer. The applicant must file a petition if contesting the Chief Engineer's recommendation. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E. Capitol, Pierre, SD 57501 (605 773-3352) and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by May 5, 2003.

The petition may be informal, but must include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. Contact Eric Gronlund at the above Water Rights Program address to request copies of information pertaining to this application.

Steven M. Pirner, Secretary, Department of Environment and Natural Resources.

Publish April 17 and 24, 2003

16-8 - (d)

RECEIVED

APR 28 2003

WATER RIGHTS
PROGRAM



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.state.sd.us/denr

April 1, 2003

Leader Courier
PO Box 310
Elk Point SD 57025-0310

ATTENTION: Legal Public Notice

Enclosed is a Notice of Hearing on Application No. 6397-3 to Appropriate Water to be published twice. Please publish the first notice on April 10, 2003 with the second publication 7 days later.

The applicant must verify to you that the notice is to be published, before you make the first publication. **Please BILL the APPLICANT for the cost of publication.** The APPLICANT is SD Department of Transportation, PO Box 568, Vermillion SD 57069 (Ph # 605-624-6835).

Please send the Water Rights Program the first publication immediately. The publication is checked for accuracy so any corrections can be made in the second publication. You may use the form below or fax a copy of the first publication. Any fax should be sent to the attention of Karen Schlaak at (605) 773-4068. Publication errors can invalidate the public notice.

After the second publication, **please send us an affidavit or use the enclosed Proof of Publication form.** The applicant pays the cost of publication, but the Water Rights Program records require an affidavit or Proof of Publication. Delays in receiving the affidavit can be costly to the applicant.

Sincerely,

Eric Gronlund
Natural Resources Engineer
605 773-3352

enclosures

-----CUT HERE-----

No. 6397-3

TO: Eric Gronlund
Water Rights Program
Joe Foss Building
Pierre SD 57501-3181

Date _____

We are in receipt of your letter of April 1, 2003 enclosing Notice of Hearing to Appropriate Water by Application No. 6397-3 which was first published in our issue of _____. **ENCLOSED IS A COPY OF THIS FIRST PUBLICATION.**

Name

Newspaper

Instruction to Newspaper - Publish first Notice on April 10, 2003 with the second publication 7 days later. The applicant is responsible for payment.

NOTICE OF APPLICATION NO. 6397-3 to Appropriate Water

Notice is given that the South Dakota Department of Transportation, PO Box 568, Vermillion SD 57069 has filed an application for a water permit to appropriate 0.1 cubic feet of water per second (45 gallons per minute) from one well (Lower Vermillion: Missouri Aquifer) 200 feet deep located in the SE ¼ NE ¼ Section 18-T92N-R50W. The water is to replace evaporation loss in a wastewater lagoon at the Junction City transportation shop.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application No. 6397-3 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water, and 4) it is in the public interest. In accordance with SDCL 46-2A-23, the Chief Engineer will act on the application, as recommended, unless a petition is filed opposing the application or the applicant files a petition contesting the Chief Engineer's recommendation. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled and the Water Management Board will consider the application. Notice of the hearing will be given to the applicant and any person filing a petition.

Any person interested in opposing or supporting this application or recommendation must file a written petition with BOTH the applicant and Chief Engineer. The applicant must file a petition if contesting the Chief Engineer's recommendation. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by April 28, 2003.

The petition may be informal, but must include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. Contact Eric Gronlund at the above Water Rights Program address to request copies of information pertaining to this application. Steven M. Pirner, Secretary, Department of Environment and Natural Resources.



**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182

www.state.sd.us/denr

**NOTE: TO BE SURE OF PUBLICATION ON
THE CORRECT DATES, CONTACT
THE NEWSPAPER RIGHT AWAY.**

April 1, 2003

SD Department of Transportation
%Ronald Peterson
PO Box 568
Vermillion SD 57069

Dear Mr. Peterson:

Water Permit Application No. 6397-3 for institutional use has been examined and found to comply with the South Dakota Water Laws and applicable rules. A notice of hearing has been sent to the Publisher of the Leader Courier printed at Elk Point, SD (Ph # 605-356-2632). You will need to contact the newspaper and authorize publication of this notice. For your information, a copy of the notice, the recommendation of the Chief Engineer and a report on the application are enclosed. Please review the notice prior to publication and notify this office, if you have any corrections or questions.

Be sure to contact the above newspaper to authorize publication of your Notice of Hearing and to arrange for payment. Early contact with the paper can eliminate delays. Upon receiving authorization, the publisher has been instructed to publish your notice once each week for two consecutive weeks with the last publication to occur twenty days before the board meeting. The newspaper has also been instructed to send us the Proof of Publication. We must receive Proof of Publication before action can be taken on the application.

Sincerely,


Eric Gronlund
Natural Resources Engineer
(605) 773-3352

enclosures

NOTE: If you plan to contest any part of the Chief Engineer's recommendation, you must file a petition pursuant to the procedures outlined in the attached notice of hearing. The Water Management Board will then consider your concerns during a hearing on the application.



JUN 13 2003

DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.state.sd.us/denr

SD Department of Transportation
Ronald Peterson
PO Box 568
Vermillion SD 57069

Dear Mr. Peterson:

Enclosed is Water Permit No. 6397-3 authorizing construction of your water diversion system and beneficial use of the water, not exceeding the limits as specified in the Water Permit.

Form 10, *Notice of Completion of Works and Application of Water to Beneficial Use*, is enclosed. Please return this completed form after you have finished the system and have put the water to beneficial use. An investigation can then be scheduled so the water license may be issued, thus completing the acquisition of a water right.

An informational sheet *Common Water Right Questions?* is also enclosed. This sheet is intended to answer some of the questions associated with obtaining and keeping a water right.

Sincerely,

Garland Erbele, Chief Engineer
Water Rights Program
(605) 773-3352

enclosures

NOTICE OF COMPLETION OF WORKS AND
APPLICATION OF WATER TO BENEFICIAL USE

Date 6/18/2003

TO: Water Rights Program, DENR
523 E. Capitol
Pierre, SD 57501-3181

RECEIVED

JUN 20 2003

WATER RIGHTS
PROGRAM

FROM: Ron Peterson, Area Engr., SDDOT
(name)
1306 W. 31st St.
(address)
Yankton, SD 57078 (605) 668-2929 Ext. 13
(city, state, zip) (phone)


I have completed the construction of the water use system and I have put the water to beneficial use to the maximum extent it is going to be used.


Water Permit No. 6397-3 states that the water use system is to be constructed by
May 5, 2008, and water is to be put to beneficial use by May 5, 2012
(date) (date)

The water use system was completed on Apr. 11, 2003
(date)

Applying the water to beneficial use was completed on Apr. 11, 2003
(date)

You may schedule an investigation so that the water license may be issued.


(signature)



Lagoon Information:

- 1) Maximum Depth 11 feet
- 2) Average Depth 8 feet
- 3) Surface Area 0.5 ac.
- 4) Approx. storage 4 ac-ft

B. Works used to transport water to place of use:

$\frac{3}{4}$ " garden type hose.

C. Works used to apply water to beneficial use:

Waste water lagoon. The water is to replace evaporative losses in the lagoon.

D. Compliance with Permit Requirements:

- 1) Permit qualifications being abided by yes
- 2) Exceptions to compliance are: none

The system is in good condition with the point(s) of diversion located as follows: 1980' S and 100' W from the NE corner Section 18-T92N-R50W (42.788056/-96.78646). The works are capable of diverting and conveying to the place of use 0.033 cu. ft. per second of water which is to be used for institutional use. Water has been put to beneficial use to the maximum extent as follows:

The water is to replace evaporative losses in the lagoon at the Junction City transportation shop.

The license should be issued for .033 cfs.

All structures, wells and lands on map yes

Comments or other permit(s) associated with the project:


Lynn Beck

Natural Resources Engineer Specialist
DENR, Water Rights Program

Date report completed: September 21, 2006

WATER RIGHT NO. 6397-3
SD Department of Transportation
September 21, 2006

R50W



SCALE

0 165 330 660 990 1,320 Feet

Lynn Beck

Lynn Beck
Natural Resources Engineer
DENR - Water Rights Program
September 21, 2006





**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.state.sd.us/denr

NOV 13 2008

6397-3

South Dakota Dept of Transportation
PO Box 568
Vermillion SD 57069

Dear Sir:

Enclosed is Water License No. 6397-3. This is the final water right document completing your process of obtaining a Water Right.

For your information SDCL 46-6-27 requires that if the owner of an existing well, such as the well authorized by Water Right No. 6397-3, constructs a replacement well and does not plan to use the old well, the old well is considered abandoned and must be plugged. Also, any well that is being used or is not considered abandoned must be valved and controlled, if flowing, or sealed and capped so that no leaking occurs either underground or at the surface.

As long as you use the water beneficially, as stated in the Water License, the State Water Laws provide that you have a continuing right to use the water. If you have any questions, please contact our office.

Sincerely,

Garland Erbele, Chief Engineer
Water Rights Program
(605) 773-3352

enclosures

STATE OF SOUTH DAKOTA

WATER LICENSE NO. 6397-3

(1) South Dakota Department of Transportation, PO Box 568, Vermillion SD 57069 made Application No. 6397-3, February 18, 2003 for a water permit to divert 0.1 cubic feet of water per second from groundwater (one well), Union County, South Dakota for industrial purposes. Permit No. 6397-3, with a priority date of February 18, 2003 was approved May 5, 2003 and issued to the applicant for diversion of water with construction of the described water supply system to be completed on or before May 5, 2008 and for the application to beneficial use of water on or before May 5, 2012.


The permit holder submitted a *Notice of Completion of Works and Application of Water to Beneficial Use* on June 30, 2003. The *Notice* stated the diversion system was completed on April 11, 2003 and the water placed to beneficial use on April 11, 2003.

(2) The water supply system has been completed and water applied to beneficial use in accordance with South Dakota State Law. Pursuant to South Dakota Codified Law 46-5-30.1, the holder and/or owner of Water Right No. 6397-3 is issued a license, bearing a priority date of February 18, 2003 to appropriate 0.033 cubic feet of water per second from groundwater (one well) for industrial use to replace evaporation loss in a wastewater lagoon at the Junction City transportation shop.

The diversion point is located: 1,980 feet south and 100 feet west from the northeast corner of Section 18-T92N-R50W (SE ¼ NE ¼).

(3) This license is subject to South Dakota Water Law, any limitations or conditions listed in Water Permit No. 6397-3 including the following now applicable qualifications:

- The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
- The well authorized by Permit No. 6397-3 shall be constructed by a licensed well driller and construction of the well and installation of the pump shall comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.



Garland Erbele, Chief Engineer
Water Rights Program
Department of Environment and Natural Resources

NOV 13 2008

date

