

WATER PERMIT NO. 6984-3

Name of Applicant: **Dorothy M Schnose**

Address: **45932 286th St, Davis SD 57021** Phone: **605 238-5517**

Amount of Water Claimed: **2.22 cfs** Total Acres: **162 acres**

Source of Water Supply: **groundwater (one well)**

Water to be used for: **irrigation** County: **TU**

Type of Waste Disposal System:

Location: **½ miles southeast of Davis**

PRIORITY Date Received: **2-25-08** Application/License Fee: **\$300**

Corrected Application Received: Period of Annual Use: **April 1 –October 31**

Remarks:

Diversion Point: **center SW ¼ Sec 3-T97N-R52W**

Land to be Irrigated: **SW ¼ Sec 3-T97N-R52W**

Depth of Well: **160**

Well Driller:

Remarks:


Type of Map: **aerial**

Prepared by: **Kyle Herbenson, NRCS**

Reviewed and the Number Assigned on: **2-25-08**

By: **Karen Schlaak**

Notice of Hearing - date to intervene: _____



FORM 2: Application for irrigation in South Dakota
(type or print)

Mail to: Water Rights Program Joe Foss Building 523 E. Capitol Pierre, SD 57501-3181 (605) 773-3352	No. <u>16984-3</u> (office use only) Hydrologic Unit <u>10170102</u>
	Basin <u>Vermillion River</u>
	Newspaper <u>Viborg Ent. / Hurley Leader P.O.B. x398</u>
	<u>605-786-7827</u> <u>Viborg 57090</u>

RECEIVED
FEB 25 2008
WATER RIGHTS
PROGRAM

Application For Permit To Appropriate Water For Irrigation

Type of Application: ☒ New ☐ Vested Right ☐ Amendment/Correction to Permit No. _____

(Use predates Mar 2, 1955)

Description of amendment/correction: (i.e. change diversion point(s), add diversion point(s), change use, etc.)

1. Name of Applicant Dorothy M. Schnose Phone 605-238-5517
(check one) ☒ Owner ☐ Tenant/lessee
Mailing Address 45932 286th St. Davis State SD. 57021
(Street, RR, or Box and City) (Zip Code)

2. Amount of water claimed 2.22*CFS or 1000**GPM ***AF Total Acreage 162
(*Cubic Feet per Second) (**Gallons per Minute) (***)Acre Feet - storage capacity of dam/dugout or annual use if applicable

3. Source of water supply Well

4. Location of point of diversion (example - 3 wells in SW1/4 NE1/4 section 12-T104N-R53W) County Turner

1 well in SW.1/4 Section 3-T97N-R52W (approximate center)

5. County or counties where water will be used Turner

6. Annual period during which water is to be used April 1- Oct. 31

7. List below each forty acre division, or lot, or fraction thereof and show number of acres to be irrigated in each.
(Attach sheet if more space is needed)

Land Description	Acres	Land Description	Acres
NE.1/4 SW. 1/4 Sec. 3-T97N-R52W	40		
NW.1/4 SW.1/4 Sec. 3-T97N-R52W	40		
SW.1/4 SW. 1/4 Sec. 3-T97N-R52W	42		
SE.1/4 SW.1/4 Sec. 3-T97N-R52W	40		

8. Give a description of the project. (Attach sheet if more space is needed)

Gailyn Hagena 309 S. Blaine St. Lennox, SD. 57039 Phone: 605-647-22230 Tenant

One well to supply irrigation water to one center pivot.

STATE OF SOUTH DAKOTA) SS
County of Turner

Attachments: Attach Form 2A if diversion is from a well or dugout, or if storage of water is proposed. Attach map and any other technical information. (see instructions)

I, Dorothy M. Schnose, the applicant, certify that I have read this application, have examined the attached map and that the matters stated are true and that I intend, and am able to complete the necessary construction.

Applicant's signature Dorothy M. Schnose

Subscribed and sworn to before me this 19 day of February 2008

Rita C. Temple
Notary Public signature

SOUTH DAKOTA
WATER PERMIT NO. 6984-3

Date of first receipt of application February 25, 2008.

The Chief Engineer, on behalf of the Water Management Board, issues Water Permit No. 6984-3 to Dorothy M Schnose, 45932 286th St, Davis SD 57021 authorizing the construction of the water use system and the placing of water to beneficial use subject to the following limitations, conditions and qualifications:

1. Water Permit No. 6984-3 appropriates 2.22 cubic feet of water per second from one well to be completed into the Upper Vermillion:Missouri Aquifer (approximately 160-200 feet deep) located in the approximate center of the SW 1/4 Section 3 to irrigate 162 acres located in the SW 1/4 Section 3; all in T97N-R52W.
2. The amount of the appropriation may not exceed 2 acre feet annually for each acre of land to which water is actually and beneficially applied for irrigation. The water is to be used during the following described annual period: April 1 – October 31.
3. The date from which applicant may claim right is February 25, 2008.
4. The date of approval of Permit No. 6984-3 is May 5, 2008.
5. One-fifth of the construction is to be completed on or before November 5, 2010.
6. All construction is to be completed on or before May 5, 2013.
7. Water is to be put to beneficial use on or before May 5, 2017.
8. Water rights obtained in compliance with the laws of the State of South Dakota may not be unlawfully impaired by this appropriation.

QUALIFICATIONS

1. The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
2. The well authorized by Permit No. 6984-3 shall be constructed by a licensed well driller and construction of the well and installation of the pump shall comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.
3. This Permit is approved subject to the irrigation water use questionnaire being submitted each year.

WATER MANAGEMENT BOARD

By: Garland Erbele

Garland Erbele, Chief Engineer
Water Rights Program
Department of Environment and Natural Resources

MAY 15 2008

date



(type or print in ink)

1. Well Information - Proposed Construction

- a) Drill Hole Diameter 20" Depth 160'-200'
- b) Casing Type PVC Diameter 16" Thickness .762"
- c) Screen Type PVC Diameter 16" Thickness .762"
- d) Gravel Pack Red Flint #60 Length of Gravel Pack _____
- e) Depth to Top of Water Bearing Material _____
- f) Depth to Water (ground surface to water level) _____
- g) Distance to nearest existing domestic well:
On applicants property _____ On property owned by others _____

2. Wastewater Disposal System Information N/A

- a) Type of System (i.e. septic tank, drain field) _____
- b) System Capacity (gallons) _____ Year Constructed _____
- c) Connected to the City of _____ Sanitary System


3. Dugout Information N/A

- a) Surface Dimensions _____ Depth _____
- b) Depth to water (ground surface to water level) _____

4. Water Storage Dams N/A

If the proposed water use system contains one or more storage dams, please furnish the information requested below for each dam. The locations of the dams need to be shown on the map submitted with the application.

- a) If a private engineering firm or government agency was involved in the design of this dam, please give their name and address:



- b) Freeboard _____
- c) Crest Width _____
Crest Length _____
- d) Height _____
- e) Primary Outlet Capacity _____
If pipe, diameter _____
- f) Secondary Spillway Capacity _____
Spillway Width _____
- g) X & Y Slope _____
Upstream _____
Downstream _____
- h) Surface Area of Impoundment _____
- i) Storage _____ Acre Feet
- j) Drainage Area Above Dam _____ Acres

We plan on one test well followed by one well with 16" PVC casing and screen to 200? feet of depth in the same hole.

An updated Form 2A will be forwarded to your office as soon as a test well is completed as soon as the weather warms for drilling. If your office requires a water sample, that will also be done at that time.

The Newspaper for publishing would be the "Centerville Journal", 721 Bdwy. St., Centerville, S.D. 57014 Phone: 605-563-2351.

The well is to be for the land owner: Dorothy M. Schmooze
LLC

45932 286 th St.
Davis, S.D. 57021
Phone: 605-238-5517
Cell: 605-929-5696
Cell is best because
of local phone service

Tenant: GD Hagen Farms

Gailyn Hagen
309 S. Blaine St.
Lennox, S.D. 57039
Phone: 605-647-2230
Cell: 605-212 - 6029
gdhagen@iw.net

4
N



United States Department of Agriculture
Farm Service Agency

1:8,724


Gailyn Wagner
Farm Operator


Turner County, SD

3-97N-52W

March 08, 2007

Dorothy M. Schnose
Farm owner -





RECEIPT

WATER RIGHTS PROGRAM

South Dakota Department of Environment and Natural Resources

Date 2/25, 20 08

RECEIVED OF Dorothy M Schnose 45932 286th St Davis SD 57021

The following amount in fees for services rendered as provided for by law:

Fee for Application for Permit No. <u>6984-3</u> to Appropriate Water, to construct and to put water to beneficial use	250	00
Fee for Application for Permit No. _____ to Appropriate Water for Future use		
Fee to retain Future Use Permit No. _____ after period of seven years.		
Fee for Inspecting Constructed Works, confirming beneficial use and issuing Water License No. <u>6984-3</u>	50	00
Fee for Filing Transfer Form _____		
Fee for _____		
Fee for Issuing New Well Driller's License No. _____ for C.Y. _____		
Fee for Renewal of Well Driller's License No. _____ for C.Y. _____		
Fee for Issuing Well Pump Installer's License No. _____ for C.Y. _____		
Fee for Renewal of Well Pump Installer's License No. _____ for C.Y. _____		
(Any Other Work Provided by Law)	TOTAL	300 00

No.

03550

By

Garland Erbe
Chief Engineer



**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.state.sd.us/denr

**RECOMMENDATION OF CHIEF ENGINEER FOR WATER PERMIT
APPLICATION NO. 6984-3, Dorothy M. Schnose**

Pursuant to SDCL 46-2A-2, the following is the recommendation of the Chief Engineer, Water Rights Program, Department of Environment and Natural Resources concerning Water Permit Application No. 6984-3, Dorothy M. Schnose, 45932 286th Street, Davis SD 57021.

The Chief Engineer is recommending APPROVAL of Application No. 6984-3 because 1) there is reasonable probability that there is unappropriated water available for the applicant's proposed use, 2) the proposed diversion can be developed without unlawful impairment of existing rights, 3) the proposed use is a beneficial use and 4) it is in the public interest with the following qualifications:

1. The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
2. The well authorized by Permit No. 6984-3 shall be constructed by a licensed well driller and construction of the well and installation of the pump shall comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.
3. This Permit is approved subject to the irrigation water use questionnaire being submitted each year.

See report on application for additional information.

Garland Erbele, Chief Engineer
April 9, 2008

REPORT ON WATER PERMIT NO. 6984-3
For Dorothy M Schnose
April 7, 2008

Application No. 6984-3 proposes to appropriate 2.22 cfs (1,000 gpm) from one well approximately 200 feet deep located in the center of the SW $\frac{1}{4}$ of section 3 to irrigate 162 acres located in the SW $\frac{1}{4}$ of section 3; all in T97N R52W in Turner County.

AQUIFER – UPPER VERMILLION MISSOURI (UVM)

The Upper Vermillion Missouri is a buried outwash (sand and gravel) under artesian conditions at this site. The aquifer underlies 207 square miles and contains an estimated 1.8 million acre-feet of water in storage in Turner and Hutchinson Counties (Lindgren, 1990). By far the largest amount of water in storage is in Turner County. The aquifer extends into McCook County to the north, Lincoln County to the east and into Clay County to the south. Ground water movement is from north to south in the area of this application (Lindgren, 1990).

No test holes were drilled for this application. The depth estimated by the applicant should mean a production well would be completed into the Upper Vermillion Missouri aquifer. This area is also underlain by the Parker Centerville aquifer and this permit would not allow production from that aquifer. The Upper Vermillion Missouri aquifer could be over 80 feet in thickness or a total depth of about 200 to 220 feet at this site (Niehus, 1994). The estimate of 200 feet by the applicant would penetrate into the Upper Vermillion Missouri aquifer but may not go all the way through the formation. Also at this site the Parker Centerville aquifer should be 40 to 50 feet thick and lying above the Lower Vermillion Missouri aquifer with 40 to 50 feet of till (clay) separating the two aquifers. A high capacity well should be completed through the entire formation in order to obtain the best well possible.


The Water Rights Program monitors nine observation wells completed into the Upper Vermillion Missouri and the Parker Centerville aquifer and within three miles of this application. The observation wells TU-77X, TU-77Y, TU-77L and TU-77I are all completed into the Upper Vermillion Missouri aquifer and within two miles of this application. Water levels for these wells show good response to climatic conditions. Water levels rise during wet years (recharge) and gradually decline during dry years. Also the effects of pumping of nearby irrigation wells show seasonal fluctuation of the artesian head pressure of the aquifer. In general, the water level record indicates that the aquifer is capable of sustaining additional withdrawals (Water Rights, 2008). Hydrographs for these four observation wells are included with this report.

REVIEW OF EXISTING WATER PERMITS/RIGHTS

The nearest irrigation well that obtains water from the Upper Vermillion Missouri aquifer, Water Right No. 2660-3 (1.11 cfs, 1 acres) is located about one mile to the southwest of this proposed well. There are other permits/rights in the area that obtain water from the shallower Parker Centerville aquifer. There does not appear to be a hydrologic connection between the Parker Centerville and Upper Vermillion Missouri aquifer in this area. Interference is not a concern. At this distance between wells drawdown is not expected to be significant. This is verified by the observation well hydrographs.

CONCLUSIONS

1. Water is available from the Upper Vermillion Missouri aquifer.
2. The aquifer is under artesian conditions at this site. Drawdown will be created by pumping. This is not expected to be significant nor cause any adverse effects upon prior water rights. Interference is not a concern.
3. The well authorized by this application must be constructed in accordance with SD Well Construction Standards.
4. The well at this site must be completed into the Upper Vermillion Missouri aquifer only. The overlying Parker Centerville aquifer must be isolated from the underlying aquifer. The two aquifers must be separated by grout in the irrigation well to minimize any potential leakage through the well bore.




James A Goodman
Natural Resources Engineer


BIBLIOGRAPHY

- Lindgren, R.J., D.S. Hansen, 1990, Water Resources of Hutchinson and Turner Counties, South Dakota, Water-Resources Investigations Report 90-4093, USGS, Huron, SD, 57350.
- Niehus, C.A., 1994, Water Resources of Lincoln and Union Counties, South Dakota, Water-Resources Investigations Report 93-4195, USGS, Rapid City, SD, 57702.
- Water Rights, 2008, Unpublished Observation Well Data for Turner and Lincoln Counties, SD DENR, DES, Water Rights Program, Pierre, SD, 57501.


WATER RIGHTS' OBSERVATION WELL TU-771




WATER RIGHTS' OBSERVATION WELL TU-77L



**WATER RIGHTS' OBSERVATION WELL
TU-77Y**



WATER RIGHTS' OBSERVATION WELL TU-77X



RECEIVED

MAY 14 2008

WATER RIGHTS
PROGRAM**AFFIDAVIT OF PUBLICATION**

STATE OF SOUTH DAKOTA)

:SS

COUNTY OF TURNER)

Allyson M. Hill, being first duly sworn, on oath says the VIBORG ENTERPRISE is a WEEKLY newspaper published in VIBORG in said county of TURNER, State of South Dakota; and that she is authorized to and does make this affidavit on behalf of said VIBORG ENTERPRISE; that affiant has personal knowledge of all facts stated in this affidavit; that said newspaper is a legal newspaper as defined by SDCL 17-2-2.1 through 17-2-2.4 inclusive as amended, has a bona fide circulation of at least two hundred copies WEEKLY, has been published in the English language within said county and has been admitted to the United States mail under the second class mailing privilege, for at last one year continuously next prior to the publication of the notice herein mentioned and was and is printed wholly or in part in an office maintained at said place of publication; that said notice, a printed copy of which taken from the paper in which the same was published is hereto attached and is made part of this affidavit, was published in said newspaper

2 time(s) as follows: that the first publication of said

notice in said newspaper aforesaid was on Thursday

the 17th day of April, 2008,

and that the succeeding publications were severally

on Thursday, the 24th day of April, 2008;

on Thursday, the ____ day of _____, 2008;

on Thursday, the ____ day of _____, 2008;

on Thursday, the ____ day of _____, 2008;

Affiant further says that the full amount of the fees charged for the publication of said notice inures to the benefit of the publishers of said newspaper; that no agreement of understanding for the division thereof has been made with any other person; that no part thereof has been agreed to be paid to any person whomsoever; and that the fees charged for the publication thereof are:

DOLLARS (\$ 35³³)


(x) _____, Allyson M. Hill

Subscribed and sworn to before me this 30th day of

April, 2008

Notary Public

My commission expires 11/14/2012

**NOTICE OF APPLICATION NO. 6984-3 to
Appropriate Water**

Notice is given that Dorothy M Schnose, 45932 286th St, Davis SD 57021 has filed an application for a water permit to appropriate 2.22 cubic feet of water per second from one well to be completed into the Upper Vermillion:Missouri Aquifer (approximately 160-200 feet deep) located in the approximate center of the SW 1/4 Section 3 to irrigate 162 acres located in the SW 1/4 Section 3; all in T97N-R52W.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application No. 6984-3 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water, and 4) it is in the public interest. In accordance with SDCL 46-2A-23, the Chief Engineer will act on this application, as recommended, unless a petition is filed opposing the application or the applicant files a petition contesting the Chief Engineer's recommendation. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled and the Water Management Board will consider this application. Notice of the hearing will be given to the applicant and any person filing a petition.

Any person interested in opposing or supporting this application or recommendation must file a written petition with BOTH the applicant and Chief Engineer. The applicant must file a petition if contesting the Chief Engineer's recommendation. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by May 5, 2008.

The petition may be informal, but must include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. Contact Eric Gronlund at the above Water Rights Program address to request copies of information pertaining to this application. Steven M. Pirner, Secretary, Department of Environment and Natural Resources.



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.state.sd.us/denr

April 9, 2008

Viborg Enterprise/Hurley Leader
PO Box 398
Viborg SD 57070

ATTENTION: Legal Public Notice

Enclosed is a Notice on Application No. 6984-3 to Appropriate Water to be published twice. Please publish the first notice on April 17, 2008 with the second publication 7 days later. The text of the notice can be e-mailed to your paper by contacting Karen Schlaak at (605) 773-3352.

The applicant must verify to you that the notice is to be published, before you make the first publication. **Please BILL the APPLICANT for the cost of publication.** The APPLICANT is Dorothy M Schnose, 45932 286th St, Davis SD 57021 (Ph # 605-238-5517).

Please send the Water Rights Program the first publication immediately. The publication is checked for accuracy so any corrections can be made in the second publication. You may use the form below or fax a copy of the first publication. Any fax should be sent to the attention of Karen Schlaak at (605) 773-4068. Publication errors can invalidate the public notice.

After the second publication, **please send us an affidavit or use the enclosed Proof of Publication form.** The applicant pays the cost of publication, but the Water Rights Program records require an affidavit or Proof of Publication. Delays in receiving the affidavit can be costly to the applicant.

Sincerely,

Eric Gronlund /KS

Eric Gronlund
Natural Resources Engineer
605 773-3352

enclosures

-----CUT HERE-----

No. 6984-3

TO: Eric Gronlund
Water Rights Program
Joe Foss Building
Pierre SD 57501-3181

Date _____

We are in receipt of your letter of April 9, 2008 enclosing Notice to Appropriate Water by Application No. 6984-3 which was first published in our issue of _____. ENCLOSED IS A COPY OF THIS FIRST PUBLICATION.

Name

Newspaper



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.state.sd.us/denr

NOTE: TO BE SURE OF PUBLICATION ON
THE CORRECT DATES, CONTACT
THE NEWSPAPER RIGHT AWAY.

April 9, 2008

Dorothy M Schnose
45932 286th St
Davis SD 57021

Dear Ms. Schnose:

Water Permit Application No. 6984-3 for irrigation use has been examined and found to comply with the South Dakota Water Laws and applicable rules. A notice has been sent to the Publisher of the Viborg Enterprise/Hurley Leader printed at Viborg SD (Ph # 605-786-7827). You will need to contact the newspaper and authorize publication of this notice. For your information, a copy of the notice, the recommendation of the Chief Engineer and report on the application are enclosed. Please review the notice prior to publication and notify this office, if you have any corrections or questions.

Be sure to contact the above newspaper to authorize publication of your Notice and to arrange for payment. Early contact with the paper can eliminate delays. Upon receiving authorization, the publisher has been instructed to publish your notice once each week for two consecutive weeks. The newspaper has also been instructed to send us the Proof of Publication. We must receive Proof of Publication before action can be taken on the application.

Sincerely,

Eric Gronlund / KS

Eric Gronlund
Natural Resources Engineer
(605) 773-3352

c: Gailyn Hagen

enclosures

NOTE: If you plan to contest any part of the Chief Engineer's recommendation, you must file a petition pursuant to the procedures outlined in the attached notice of hearing. The Water Management Board will then consider your concerns during a hearing on the application.

Instruction to Newspaper - Publish first Notice on April 17, 2008 with the second publication 7 days later. The applicant is responsible for payment.

NOTICE OF APPLICATION NO. 6984-3 to Appropriate Water

Notice is given that Dorothy M Schnose, 45932 286th St, Davis SD 57021 has filed an application for a water permit to appropriate 2.22 cubic feet of water per second from one well to be completed into the Upper Vermillion:Missouri Aquifer (approximately 160-200 feet deep) located in the approximate center of the SW ¼ Section 3 to irrigate 162 acres located in the SW ¼ Section 3; all in T97N-R52W.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application No. 6984-3 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water, and 4) it is in the public interest. In accordance with SDCL 46-2A-23, the Chief Engineer will act on this application, as recommended, unless a petition is filed opposing the application or the applicant files a petition contesting the Chief Engineer's recommendation. If a petition opposing the application or contesting the recommendation is filed, then a hearing will be scheduled and the Water Management Board will consider this application. Notice of the hearing will be given to the applicant and any person filing a petition.

Any person interested in opposing or supporting this application or recommendation must file a written petition with BOTH the applicant and Chief Engineer. The applicant must file a petition if contesting the Chief Engineer's recommendation. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by May 5, 2008.

The petition may be informal, but must include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. Contact Eric Gronlund at the above Water Rights Program address to request copies of information pertaining to this application. Steven M. Pirner, Secretary, Department of Environment and Natural Resources.



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182
www.state.sd.us/denr

MAY 15 2008

Dorothy M Schnose
45932 286th St
Davis SD 57021

Dear Ms. Schnose:

Enclosed is Water Permit No. 6984-3 authorizing construction of your water diversion system and beneficial use of the water, not exceeding the limits as specified in the Water Permit.

Form 10, *Notice of Completion of Works and Application of Water to Beneficial Use*, is enclosed. Please return this completed form after you have finished the system and have put the water to beneficial use. An investigation can then be scheduled so the water license may be issued, thus completing the acquisition of a water right.

An informational sheet ? *Common Water Right Questions?* is also enclosed. This sheet is intended to answer some of the questions associated with obtaining and keeping a water right.

Sincerely,

Garland Erbele, Chief Engineer
Water Rights Program
(605) 773-3352

enclosures

Dewell, Amanda

From: Dewell, Amanda
Sent: Wednesday, October 30, 2024 3:47 PM
To: hagegg309@hotmail.com
Subject: FW: [EXT] 6984-3 IQ Reported Use in 2024, No, acres irrigated

To the operator of Water Permit No. 6984-3,

The Water Rights Program is in receipt of the 2024 Irrigation Questionnaire you submitted online for Water Permit No. 6984-3, which is still held in the name of Dorthy M Schnose. Our records indicate that Ms. Schnose has passed away and that the land was held in the estate, not yet settled.

With this email I wish to inquire whether the estate has been settled and new ownership of the property (160 acres – SW ¼ Section 3, T97N, R52W) assigned? Transfer of ownership would simply require completion of a single form and payment of a \$50 processing fee.

Please advise on the proper course of action. Thank you,

Amanda Dewell

DANR - Water Rights Program
 Permitting Administrator
 Main Phone: 605 773-3352
 Website: danr.sd.gov



From: Caspio <noreply@caspio.app>
Sent: Tuesday, October 29, 2024 9:22 PM
To: Duvall, Ron <Ron.Duvall@state.sd.us>; Dewell, Amanda <Amanda.Dewell@state.sd.us>
Subject: [EXT] 6984-3 IQ Reported Use in 2024, No, acres irrigated

Permit Holder:
 LISA SCHNOSE
 DOROTHY M SCHNOSE (ESTATE)
 45932 286TH ST
 DAVIS SD 57021

hagegg309@hotmail.com

If water used, reported in following months:

Month	Crop 1	Crop 2	Crop 3	Crop 4
Mar	CRN, 0	,	,	,