

FORM 2: Application for irrigation in South Dakota
(type or print)

10:00 a.m.

Mail to: PMB 2020 DENR - Water Rights 523 E Capitol Ave Pierre, SD 57501-3182 ph. (605) 773-3352	No. <u>7721-3</u> (office use only) Hydrologic Unit <u>10160006</u>
	Basin <u>James River</u>
	Newspaper <u>Redfield Press</u>
	<u>Plainsman</u>

RECEIVED
FEB - 8 2013
WATER RIGHTS
PROGRAM

Application For Permit To Appropriate Water For Irrigation

Type of Application: ☒ New ☐ Vested Right ☐ Amendment/Correction to Permit No. _____
(Use predates Mar 2, 1955)

Description of amendment/correction: (i.e. change diversion point(s), add diversion point(s), change use, etc.)

1. Name to Appear on Irrigation Permit Terry Wieting
(check one) ☒ Owner ☐ Tenant/lessee ☐ Owner's Legal Agent _____
(name and complete address if different than above name)

Mailing Address 870 Beachave Huron SD 57350
(Address) (City) (State) (Zip Code)

Home Phon _____ ell _____ Email _____

2. Amount of water claimed 1.33 *CFS or **GPM ***AF Total Acreage 100
(*Cubic Feet per Second) (**Gallons per Minute) (**Acre Feet - storage capacity of dam/dugout or annual use if applicable)

3. Source of water supply Tulare Western Spink/Hitchcock

4. Location of point of diversion 1 well located in the center of the SW 1/4 sec 18 114N-63W
(example - 3 wells in SW1/4 NE1/4 section 12-T104N-R53W)

County Spink

5. County or counties where water will be used Spink

6. Annual period during which water is to be used May-September 30

7. List below each forty acre division, or lot, or fraction thereof and show number of acres to be irrigated in each.
(Attach sheet if more space is needed)

Land Description	Acres	Land Description	Acres
NW 1/4 of the SW 1/4 sec 18 114N-63W	40		
NE 1/4 of the SW 1/4 sec 18 114N-63W	40		
N 1/2 SW 1/4 of the SW 1/4 sec 18 114N-63W	10		
N 1/2 SE 1/4 of the SW 1/4 sec 18 114N-63W	10		

8. Give a description of the project. (Attach sheet if more space is needed)

To irrigate 100 acres from one well with a center pivot at 1.78 CFS

I, Gary Marshall, the applicant, certify that I have read this application, have examined the attached map, and that the matters stated are true.

SOUTH DAKOTA
WATER PERMIT NO. 7721-3 FOR IRRIGATION

Date of first receipt of application February 8, 2013.

The Water Management Board approved Water Permit No. 7721-3 on July 11, 2013 for Terry Wieting, 870 Beach Ave NE, Huron SD 57350 authorizing the construction of the water use system and the placing of water to beneficial use subject to the following limitations, conditions and qualifications:

1. Water Permit No. 7721-3 appropriates 1.33 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the SW ¼ Section 18 for irrigation of 100 acres located in the SW 1/4 Section 18; all in T114N-R63W.
2. The amount of the appropriation may not exceed 2 acre feet annually for each acre of land to which water is actually and beneficially applied for irrigation. The water is to be used during the following described annual period: May 1 – September 30.
3. The date from which applicant may claim right is February 8, 2013.
4. One-fifth of the construction is to be completed on or before January 11, 2016.
5. All construction is to be completed on or before July 11, 2018.
6. Water is to be put to beneficial use on or before July 11, 2022.
7. Water rights obtained in compliance with the laws of the State of South Dakota may not be unlawfully impaired by this appropriation.

QUALIFICATIONS

1. The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
2. The well authorized by Permit No. 7721-3 shall be constructed by a licensed well driller and construction of the well and installation of the pump shall comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.
3. This Permit is approved subject to the irrigation water use questionnaire being submitted each year.


WATER MANAGEMENT BOARD

By: *Jeanne Goodman*

Jeanne Goodman, Chief Engineer
Water Rights Program
Department of Environment and Natural Resources

AUG 29 2013

date



Supplemental Information

(type or print)

1. Well Information (check one or both as applicable) ☒ Drilling new well(s) ☐ Using existing well(s)

a) If new wells, how many ____ Have test holes been drilled ☐ Yes ☒ No Drilled by ____
(if yes, please provide copies of logs)

b) If existing wells, how many ____ Provide copy of log(s), if available. Drilled by ____

c) Well Depth 70 Depth to Top of Water Bearing Material 35 Depth to Water from Surface 23

d) Distance to nearest existing domestic well:

On applicant's property _____ On property owned by others 1 mile

2. Wastewater Disposal System Information

a) Type of System (i.e. septic tank, drain field) _____

b) System Capacity (gallons) _____ Year Constructed _____

c) Connected to the City of _____ Sanitary System

3. Dugout Information

a) Surface Dimensions _____ Depth _____

b) Depth to water (ground surface to water level) _____

4. Water Storage Dams

If the proposed water use system contains one or more storage dams, please furnish the information requested below for each dam. The locations of the dams need to be shown on the map submitted with the application.

a) If a private engineering firm or government agency was involved in the design of this dam, please give their name and address:

b) Freeboard _____

c) Crest Width _____

Crest Length _____

d) Height _____

e) Primary Outlet Capacity _____

If pipe, diameter _____

f) Secondary Spillway Capacity _____

Spillway Width _____

g) X & Y Slope (e.g. 3 to 1 is a typical slope)


Upstream _____

Downstream _____

h) Surface Area of Impoundment _____

i) Storage _____ Acre Feet

j) Drainage Area Above Dam _____ Acres





RECEIVED
FEB - 8 2013
WATER RIGHTS
PROGRAM

RECEIPT

WATER RIGHTS PROGRAM

South Dakota Department of Environment and Natural Resources


Date 2/8, 20 13

RECEIVED OF Gary Marshall Marshall Bros 19032 388th Ave Hitchcock SD 57048

The following amount in fees for services rendered as provided for by law:

Fee for Application for Permit No. _____ to Appropriate Water, to construct and to put water to beneficial use	850	00
Fee for Application for Permit No. _____ to Appropriate Water for Future use		
Fee to retain Future Use Permit No. _____ after period of seven years.		
Fee for Inspecting Constructed Works, confirming beneficial use and issuing Water License No. _____	200	00
Fee for Filing Transfer Form _____		
Fee for _____		
Fee for Issuing New Well Driller's License No. _____ for C.Y. _____		
Fee for Renewal of Well Driller's License No. _____ for C.Y. _____		
Fee for Issuing Well Pump Installer's License No. _____ for C.Y. _____		
Fee for Renewal of Well Pump Installer's License No. _____ for C.Y. _____		
(Any Other Work Provided by Law)	TOTAL	1050 00

No. **06114**

By 
Chief Engineer

RECEIVED

APR - 9 2013

WATER RIGHTS
PROGRAM

SD EForm - 0495LD V2

NOTICE OF TRANSFER OF OWNERSHIP

For assistance call (605) 773-3352

Mail to: PMB 2020
DENR - Water Rights Program
523 E Capitol Ave
Pierre, SD 57501-3182

Water Right/Permit No. 7721-3

Date: 4/3/2013

I/We request that Water Right/Permit No. _____ formerly owned by:

Marshall Bros C/O Gary Marshall be transferred to:

New Owner Name: Terry Wieting

Address: 870 Beach Ave Ne

City, State, Zip Huron ☒ Sd ☒ 57350 Telephone No. 605-554-0207

Title to the following described land(s)/property has been transferred as described above:


'SW 1/4 Sec 18 114-63

☒ I understand that the validity of Water Right/Permit No. _____ has not been determined by this transfer action. If I have any questions on validity, I understand that only the Water Management Board has the authority to determine if a water right/permit is valid (see note below.)

You are requested to file this "Notice of Transfer" in the appropriate file with the Water Rights Program, as evidence of the change of ownership.

A fee of Fifty Dollars (\$50.00) is included to cover the filing fee as required by SDCL 46-2-13.

I, Terry Wieting, the new owner, certify that the above information is true and correct.


(signed by new owner)

NOTE: Water permits may be cancelled for nonconstruction after the five year construction period has expired. Once a water permit is developed and the water used, the permit becomes a right. A water right may be lost for three reasons:

1. Abandonment - no intent to use water and use is abandoned.
2. Forfeiture - no use of water for three year period without legal excuse.
3. For a third violation of a condition of a water permit/right.

RECEIPT

WATER RIGHTS PROGRAM

South Dakota Department of Environment and Natural Resources

Date 4/9, 20 13

RECEIVED OF Terry Wieting 870 Beach Ave NE Huron SD 57350

The following amount in fees for services rendered as provided for by law:

Fee for Application for Permit No. _____ to Appropriate Water, to construct and to put water to beneficial use	50	00
Fee for Application for Permit No. _____ to Appropriate Water for Future use		
Fee to retain Future Use Permit No. _____ after period of seven years.		
Fee for Inspecting Constructed Works, confirming beneficial use and issuing Water License No. _____		
Fee for Filing Transfer Form <u>7721-3</u>		
Fee for _____		
Fee for issuing New Well Driller's License No. _____ for C.Y. _____		
Fee for Renewal of Well Driller's License No. _____ for C.Y. _____	50	00
Fee for Issuing Well Pump Installer's License No. _____ for C.Y. _____		
Fee for Renewal of Well Pump Installer's License No. _____ for C.Y. _____		
(Any Other Work Provided by Law)	TOTAL	50 00

No. 06293

By *James Goodman*
Chief Engineer



**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182

denr.sd.gov

April 9, 2013

Terry Wieting
870 Beach Ave NE
Huron SD 57350

Dear Mr. Wieting:

Thank you for following up on the ownership change for Water Permit Application Nos. 7717-3, 7718-3, 7720-3 and 7721-3. The transfers have been completed. The applications formerly listed in the name of Marshall Brothers are now listed in your name.

Enclosed are the receipts for the transfers as well as the check for \$500.00 which is not required. If I can answer any questions for you, please contact me.

Sincerely,

Karen Schlaak
Water Rights Program
(605) 773-3352
email: karen.schlaak@state.sd.us

enclosures



**DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES**

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182

denr.sd.gov

**RECOMMENDATION OF CHIEF ENGINEER FOR WATER PERMIT APPLICATION
NO. 7721-3, Terry Wieting**

Pursuant to SDCL 46-2A-2, the following is the recommendation of the Chief Engineer, Water Rights Program, Department of Environment and Natural Resources concerning Water Permit Application No. 7721-3, Terry Wieting, 870 Beach Ave NE, Huron SD 57350.

The Chief Engineer is recommending APPROVAL of Application No. 7721-3 because 1) there is reasonable probability that there is unappropriated water available for the applicant's proposed use, 2) the proposed diversion can be developed without unlawful impairment of existing rights, 3) the proposed use is a beneficial use and 4) it is in the public interest with the following qualifications:

1. The well approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
2. The well authorized by Permit No. 7721-3 shall be constructed by a licensed well driller and construction of the well and installation of the pump shall comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28.
3. This Permit is approved subject to the irrigation water use questionnaire being submitted each year.

See report on application for additional information.

Jeanne Goodman, Chief Engineer
May 28, 2013

REPORT TO THE CHIEF ENGINEER
ON

WATER PERMIT APPLICATION NO. 7685-3
MICHAEL WATSON
WATER PERMIT APPLICATION NO. 7716-3
DENIS AND CRAIG SLEPIKAS
WATER PERMIT APPLICATION NO. 7719-3
MARSHALL BROTHERS
WATER PERMIT APPLICATION NOS. 7717-3, 7718-3, 7720-3 & 7721-3
TERRY WIETING
WATER PERMIT APPLICATION NOS. 7722-3, 7723-3 & 7724-3
BRENT AND LELAND KLEINSSASER
WATER PERMIT APPLICATION NOS. 7726-3, 7727-3, 7753-3, 7754-3 & 7759-3
OSCAR, INC.
WATER PERMIT APPLICATION NOS. 7725-3, 7752-3, 7755-3, 7756-3 & 7757-3
LENNY PETERSON
WATER PERMIT APPLICATION NOS. 7751-3 & 7758-3
BRAD PETERSON
WATER PERMIT APPLICATION NOS. 7731-3 & 7732-3
RIVERSIDE HUTTERIAN BRETHREN
WATER PERMIT APPLICATION NOS. 7733-3, 7734-3, 7735-3 & 7736-3
VANBUSKIRK FARMS
WATER PERMIT APPLICATION NOS. 7737-3, 7738-3, 7739-3, 7740-3, 7742-3, 7743-3,
7744-3, 7745-3 & 7746-3
BIXLER FARMS
WATER PERMIT APPLICATION NO. 7790-3,
MARTIN J. ANDERSON
WATER PERMIT APPLICATION NO. 7799-3,
RATHJEN FARMS
WATER PERMIT APPLICATION NO. 7822-3 & 7823-3
DARIN BINGER

APRIL 13, 2013

Water Permit Application No. 7685-3 proposes to appropriate water from one well completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.67 cubic feet of water per second (cfs). Water will be diverted from either an existing well authorized by Water Right No. 6175-3, located in the center of the NE¼ Section 11, T114N-R63W, or a new well to be located in the NW¼ SE¼ Section 11, T114N-R63W. This application proposes to irrigate 75 acres located in the N½ SE¼, SW¼ SE¼ Section 11, Section 11, T114N-R63W.

Water Permit Application No. 7716-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.28 cfs. Water is to be diverted from one well approximately 88 feet deep, located in the

approximate center of the NE ¼ Section 20, T112N-R61W. This application proposes to irrigate 160 acres located in the NE¼ Section 20, T112N-R61W.

Water Permit Application No. 7719-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 70 feet deep, located in the approximate center of the NW¼ Section 4, T113N-R62W. This application proposes to irrigate 135 acres located in the NE¼ Section 4, T113N-R62W.

Water Permit Application No. 7717-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 70 feet deep, located in the approximate center of the NE ¼ Section 10, T113N-R64W. This application proposes to irrigate 135 acres located in the NE¼ Section 10, T113N-R64W.

Water Permit Application No. 7718-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 70 feet deep, located in the approximate center of the SE ¼ Section 9, T113N-R64W. This application proposes to irrigate 135 acres located in the SE¼ Section 9, T113N-R64W.

Water Permit Application No. 7720-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 70 feet deep, located in the approximate center of the NE ¼ Section 25, T114N-R64W. This application proposes to irrigate 135 acres located in the NE¼ Section 25, T114N-R64W.

Water Permit Application No. 7721-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.33 cfs. Water is to be diverted from one well approximately 70 feet deep, located in the approximate center of the SW ¼ Section 18, T114N-R63W. This application proposes to irrigate 100 acres located in the SW¼ Section 18, T114N-R63W.

Water Permit Application No. 7722-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 80 feet deep, located in the approximate center of the NE ¼ Section 4, T111N-R61W. This application proposes to irrigate 155 acres located in the NE¼ Section 4, T111N-R61W.

Water Permit Application No. 7723-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 3.56 cfs. Water is to be diverted from two wells approximately 80 feet deep, located in the approximate centers of the NW¼ Section 3, T111N-R61W and the SW ¼ Section 3, T111N-R61W. This application proposes to irrigate 300 acres located in the W½ Section 3, T111N-R61W.

Water Permit Application No. 7724-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 3.56 cfs. Water is to be diverted from two wells approximately 80 feet deep, located in the approximate centers of the SW¼ Section 4, T111N-R61W and the SE ¼ Section 4, T111N-R61W. This application proposes to irrigate 300 acres located in the S 1/2 Section 4, T111N-R61W.

Water Permit Application No. 7726-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.28 cfs. Water is to be diverted from one well approximately 60-100 feet deep, located in the approximate center of the SW ¼ Section 16, T114N-R62W. This application proposes to irrigate 160 acres located in the NE¼ Section 34, T114N-R62W.

Water Permit Application No. 7727-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.28 cfs. Water is to be diverted from one well approximately 60-100 feet deep, located in the approximate center of the NW ¼ Section 34, T113N-R64W. This application proposes to irrigate 160 acres located in the NW¼ Section 16, T113N-R64W.

Water Permit Application No. 7753-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.50 cfs. Water is to be diverted from one well approximately 60-100 feet deep, located in the approximate center of the SE¼ Section 26, T114N-R64W. This application proposes to irrigate 105 acres located in the SE ¼ Section 26, T114N-R64W.

Water Permit Application No. 7754-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.14 cfs. Water is to be diverted from one well approximately 60-100 feet deep, located in the S½ NW¼ Section 27, T115N-R63W. This application proposes to irrigate 80 acres located in the S½ NW¼ Section 27, T115N-R63W.

Water Permit Application No. 7759-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 4.57 cfs. Water is to be diverted from two wells approximately 60-100 feet deep, located in the approximate centers of the SW¼ Section 19, T114N-R63W and the SE ¼ Section 19, T114N-R63W. This application proposes to irrigate 320 acres located in the S½ Section 19, T114N-R63W.

Water Permit Application No. 7725-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 4.57 cfs. Water is to be diverted from two wells approximately 60-100 feet deep, located in the approximate centers of the SW¼ Section 7, T113N-R63W and the SE ¼ Section 7, T113N-R63W. This application proposes to irrigate 320 acres located in the S½ Section 7, T113N-R63W.

Water Permit Application No. 7752-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 4.57 cfs. Water is to be diverted from two wells approximately 60-100 feet deep, located in the approximate centers of the NE¼ Section 26, T113N-R63W and the SE ¼ Section 26, T113N-R63W. This application proposes to irrigate 320 acres located in the E½ Section 26, T113N-R63W.

Water Permit Application No. 7755-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.28 cfs. Water is to be diverted from one well approximately 60-100 feet deep, located in the approximate center of the NW¼ Section 17, T113N-R63W. This application proposes to irrigate 160 acres located in the NW¼ Section 17, T113N-R63W.

Water Permit Application No. 7756-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.28 cfs. Water is to be diverted from one well approximately 60-100 feet deep, located in the approximate center of the SW¼ Section 21, T114N-R63W. This application proposes to irrigate 160 acres located in the SW¼ Section 21, T114N-R63W.

Water Permit Application No. 7757-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.28 cfs. Water is to be diverted from one well approximately 60-100 feet deep, located in the approximate center of the SW¼ Section 22, T114N-R63W. This application proposes to irrigate 160 acres located in the SW¼ Section 22, T114N-R63W.

Water Permit Application No. 7751-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.28 cfs. Water is to be diverted from one well approximately 60-100 feet deep, located in the approximate center of the NW¼ Section 11, T113N-R64W. This application proposes to irrigate 160 acres located in the NW¼ Section 11, T113N-R64W.

Water Permit Application No. 7758-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 4.57 cfs. Water is to be diverted from two wells approximately 60-100 feet deep, located in the approximate centers of the NW¼ Section 30, T114N-R63W and NE¼ Section 30, T114N-R63W. This application proposes to irrigate 320 acres located in the N½ Section 30, T114N-R63W.

Water Permit Application No. 7731-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 3.86 cfs. Water is to be diverted from two wells approximately 85 feet deep, located in the approximate centers of the NW¼ Section 1, T113N-R62W and SW¼ Section 1, T113N-R62W. This application proposes to irrigate 270 acres located in the W½ Section 1, T113N-R62W.

Water Permit Application No. 7732-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.93

cfs. Water is to be diverted from one well approximately 80 feet deep, located in the SW¼ SE¼ Section 21, T112N-R61W. This application proposes to irrigate 135 acres located in the NE¼ Section 21, T112N-R61W.

Water Permit Application No. 7733-3 proposes to appropriate water from four wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 7.77 cfs. Water is to be diverted from four wells approximately 110 feet deep, located in the approximate centers of the SE¼ Section 4, T113N-R63W and SW¼ Section 4, T113N-R63W; and the approximate centers of the NE¼ Section 5, T113N-R63W and SE¼ Section 5, T113N-R63W. This application proposes to irrigate 544 acres located in the S½ Section 4, T113N-R63W and the E½ Section 5, T113N-R63W.

Water Permit Application No. 7734-3 proposes to appropriate water from five wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 14.0 cfs. Water is to be diverted from five wells approximately 110 feet deep, located in: 1) the approximate center of the NW¼ Section 32, T114N-R63W; 2) the approximate center of Section 31, T114N-R63W; 3) the approximate center of the SW¼ Section 30, T114N-R63W; 4) the approximate center of the NE¼ Section 36, T114N-R64W. This application proposes to irrigate 982 acres located in the NW¼ Section 32, T114N-R63W, Section 31, T114N-R64W, the SW¼ Section 30, T114N-R63W and the NE¼ Section 36, T114N-R64W.

Water Permit Application No. 7735-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.94 cfs. Water is to be diverted from one well approximately 110 feet deep, located in the approximate center of the NE¼ Section 36, T113N-R64W. This application proposes to irrigate 136 acres located in the NE¼ Section 36, T113N-R64W.

Water Permit Application No. 7736-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.94 cfs. Water is to be diverted from one well approximately 110 feet deep, located in the approximate center of the NW¼ Section 33, T114N-R63W. This application proposes to irrigate 136 acres located in the NW¼ Section 33, T114N-R63W.

Water Permit Application No. 7737-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.20 cfs. Water is to be diverted from two wells approximately 60 feet deep, located in the approximate centers of the SE¼ Section 25, T115N-R63W and SW¼ Section 25, T115N-R63W. This application proposes to irrigate 200 acres located in the S½ Section 25, T115N-R63W.

Water Permit Application No. 7738-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 70 feet deep, located in the approximate center of the SW¼ Section 18, T114N-R62W. This application proposes to irrigate 150 acres located in the SW¼ Section 18, T114N-R62W.

Water Permit Application No. 7739-3 proposes to appropriate water from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 3.56 cfs. Water is to be diverted from two wells approximately 60 feet deep, located in the approximate centers of the SE¼ Section 24, T114N-R63W and NE¼ Section 24, T114N-R63W. This application proposes to irrigate 320 acres located in the E½ Section 24, T114N-R63W.

Water Permit Application No. 7740-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 60 feet deep, located in the approximate center of the SW¼ Section 24, T115N-R63W. This application proposes to irrigate 150 acres located in the SW¼ Section 24, T115N-R63W.

Water Permit Application No. 7742-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 60 feet deep, located in the approximate center of the NE¼ Section 14, T115N-R63W. This application proposes to irrigate 160 acres located in the NE¼ Section 14, T115N-R63W.

Water Permit Application No. 7743-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 60 feet deep, located in the approximate center of the SW¼ Section 23, T114N-R63W. This application proposes to irrigate 160 acres located in the SW¼ Section 23, T114N-R63W.

Water Permit Application No. 7744-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 60 feet deep, located in the approximate center of the SE¼ Section 22, T114N-R63W. This application proposes to irrigate 160 acres located in the SE¼ Section 22, T114N-R63W.

Water Permit Application No. 7745-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 65 feet deep, located in the approximate center of the NW¼ Section 3, T114N-R63W. This application proposes to irrigate 160 acres located in the NW¼ Section 3, T114N-R63W.

Water Permit Application No. 7746-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.78 cfs. Water is to be diverted from one well approximately 60 feet deep, located in the approximate center of the NW¼ Section 6, T114N-R62W. This application proposes to irrigate 160 acres located in the NW¼, W ½ NE¼, N½SW¼ Section 6, T114N-R62W.

Water Permit Application No. 7790-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 1.86 cfs. Water is to be diverted from one well approximately 85 feet deep, located in the NW¼ SE¼

Section 18, T113N-R62W. This application proposes to irrigate 132 acres located in the SW¼, W ½ SE¼, Section 18, T113N-R62W.

Water Permit Application No. 7799-3 proposes to irrigate 36 new acres using a well authorized by Water Right No. 3172-3. Water Right No. 3172-3 authorizes a diversion rate of 1.78 cfs from a well 65 feet deep, completed into the Tulare: Western Spink/Hitchcock aquifer, located in the center of the NW¼ Section 20, T114N-R62W for the irrigation of 136 acres located in the NW¼ Section 20, T114N-R62W. This application proposes to irrigate 36 additional acres located in the N½ NW¼ and the N½ SW¼ Section 20, T114N-R62W from the existing well. This application, if approved, does not authorize any increase in the developed diversion rate. This application also clarifies the location of the existing 136 acres irrigated to include the N½ SW¼ Section 20, T114N-R62W.

Water Permit Application No. 7822-3 proposes to appropriate water from one well to be completed into the Tulare: Western Spink/Hitchcock aquifer at a maximum diversion rate of 2.00 cfs. Water is to be diverted from one well approximately 155 feet deep, located in the approximate center of the NE¼ Section 35, T115N-R65W. This application proposes to irrigate 135 acres located in the NE¼ Section 35, T115N-R65W.

Water Permit Application No. 7823-3 proposes to irrigate 25 new acres using a well authorized by Water Right No. 6142-3. Water Right No. 6142-3 authorizes a diversion rate of 2.22 cfs from a well completed into the Tulare: Hitchcock Aquifer, located in the NW¼ SE¼ Section 27, T115N-R65W for the irrigation of 240 acres located in the E½ Section 27, T115N-R65W. This application proposes to irrigate 25 additional acres located in the SE¼ Section 27, T115N-R65W from the existing well. This application, if approved, does not authorize any increase in the developed diversion rate.

AQUIFER: TULARE: WESTERN SPINK/HITCHCOCK

At the December 2002 Water Management Board Hearing, the Board determined that the Western Spink and Hitchcock management units of the Tulare aquifer would be considered collectively for water management purposes. At that hearing the Board deferred a number of permit applications for a five year period ending in December 2007. The Board was concerned that the aquifer may be fully appropriated based upon projected use (Goodman, 2007). A total of 37 applications proposing to irrigate 6,527 acres were deferred. At the December 2007 Water Management Board meeting the Board denied all of the deferred applications and deemed the aquifer fully appropriated. The Board found (Finding of Fact No. 41) that "The applicants wish to maintain a priority date based on the date they filed their applications, but there is no provision in the statutes to allow this."

Between 2002 and 2011 there were a number of water permit applications proposing appropriations from the Tulare: Western Spink/Hitchcock aquifer that were denied or withdrawn.

Six applications to appropriate water from the Tulare: Western Spink/Hitchcock aquifer (No. 7288-3, No. 7289-3, No. 7290-3, No. 7291-3, No. 7292-3 and No. 7293-3) were filed with the DENR-Water Rights Program in December 2011. Based on a DENR-Water Rights staff analysis

of the aquifer (Buhler, 2012a) and a stipulation between parties, Water Permit Application No. 7288-3 was withdrawn, and the appropriation requests of the five remaining applications were reduced. Following a July 11, 2012, hearing, the Water Management Board approved water permit applications totaling an amount of water approximately equal to the probable quantity of water remaining unappropriated from the aquifer based on the best information available at the time.

Three water permit applications proposing appropriations from the Tulare: Western Spink/Hitchcock aquifer (No. 7373-3, No. 7378-3 and No. 7379-3) were received in June 2012. The Chief Engineer recommended deferral of Water Permit Application No. 7373-3 and recommended denial of Application Nos. 7378-3 and 7379-3. Application Nos. 7378-3 and 7379-3 were ultimately withdrawn from consideration pursuant to SDCL 46-2A-3.

Twelve more water permit applications proposing appropriations from the Tulare: Western Spink/Hitchcock aquifer were received in December 2012. A January 2013, DENR-Water Rights Staff analysis of the Tulare: Western Spink/Hitchcock aquifer (Buhler, 2013) (see Appendix A), determined that unappropriated water was available from the aquifer to irrigate an additional 3,877 acres. At the March 2013, Water Management Board Meeting, the Board approved Water Permits No. 7373-3 authorizing the irrigation of 160 acres. The other twelve applications to authorize 1,971 acres were approved on May 2, 2013.

Between February 6, 2013, and April 10, 2013, there were 41 water permit applications submitted to the DENR-Water Rights Program proposing to irrigate additional acreage. These applications are shown in Table 1.

APPLICATION NO.	APPLICANT	RECIEVED	ACRES	RUNNING ACREAGE TOTAL
7685-3	MICHAEL WATSON	2/6/13	75	75
7716-3	DENIS AND CRAIG SLEPIKAS	2/8/13 8:30 AM	160	235
7717-3	TERRY WIETING	2/8/13 10:00 AM	135	370
7718-3	TERRY WIETING	2/8/13 10:00 AM	135	505
7719-3	MARSHALL BROTHERS	2/8/13 10:00 AM	135	640
7720-3	TERRY WIETING	2/8/13 10:00 AM	135	775
7721-3	TERRY WIETING.	2/8/13 10:00 AM	100	875
7722-3	BRENT/LELAND KLEINSSASER	2/8/13 11:35 AM	155	1030
7723-3	BRENT/LELAND KLEINSSASER	2/8/13 11:35 AM	300	1330
7724-3	BRENT/LELAND KLEINSSASER	2/8/13 11:35 AM	300	1630
7725-3	LENNY PETERSON	2/8/13 10:50 PM	320	1950
7751-3	BRAD PETERSON	2/8/13 10:50 PM	160	2110
7752-3	LENNY PETERSON	2/8/13 10:50 PM	320	2430
7753-3	OSCAR INC	2/8/13 10:50 PM	105	2535
7754-3	OSCAR INC	2/8/13 10:50 PM	80	2615
7755-3	LENNY PETERSON	2/8/13 10:50 PM	160	2775
7756-3	LENNY PETERSON	2/8/13 10:50 PM	160	2935
7757-3	LENNY PETERSON	2/8/13 10:50 PM	160	3095
7726-3	OSCAR INC	2/8/13 11:00 PM	160	3255
7758-3	BRAD PETERSON	2/8/13 11:00 PM	320	3575
7759-3	OSCAR INC	2/8/13 11:00 PM	320	3895
7727-3	OSCAR INC	2/10/13 3:09 PM	160	4055
7731-3	RIVERSIDE COLONY	2/11/13	270	4325
7732-3	RIVERSIDE COLONY	2/11/13	135	4460
7733-3	VAN BUSKIRK FARMS LLP	2/15/13 12:15 PM	544	5004
7734-3	VAN BUSKIRK FARMS LLP	2/15/13 12:15 PM	982	5986
7735-3	VAN BUSKIRK FARMS LLP	2/15/13 12:15 PM	136	6122
7736-3	VAN BUSKIRK FARMS LLP	2/15/13 12:15 PM	136	6258
7737-3	BIXLER FARMS	2/19/13 3:30 PM	200	6458
7738-3	BIXLER FARMS	2/19/13 3:30 PM	150	6608
7739-3	BIXLER FARMS	2/19/13 3:30 PM	320	6928
7740-3	BIXLER FARMS	2/19/13 3:30 PM	150	7078
7742-3	BIXLER FARMS	2/19/13 3:30 PM	160	7238
7743-3	BIXLER FARMS	2/19/13 3:30 PM	160	7398
7744-3	BIXLER FARMS	2/19/13 3:30 PM	160	7558
7745-3	BIXLER FARMS	2/19/13 3:30 PM	160	7718
7746-3	BIXLER FARMS	2/19/13 3:30 PM	160	7878
7790-3	MARTIN J ANDERSON	3/13/2013	132	8010
7799-3	RATHJEN FARMS	3/19/13	36	8046
7822-3	DARIN BINGER	4/10/13	135	8181
7823-3	DARIN BINGER	4/10/13	25	8206

Table 1. Pending water permit applications proposing to appropriate water from the Tulare: Western Spink/Hitchcock aquifer

Based on the best information reasonably available, unappropriated water is available from the Tulare: Western Spink/Hitchcock aquifer to irrigate an additional 1,746 acres at the historic average irrigation application rate for the aquifer of 9.32 inches per year (Buhler, 2012).

There is a reasonable probability that unappropriated water is available from the Tulare: Western Spink/Hitchcock aquifer to support the appropriations proposed by Water Permit Application Nos. 7685-3, 7716-3, 7717-3, 7718-3, 7719-3, 7720-3, 7721-3, 7722-3, 7723-3 and 7724-3 that propose to irrigate a total of 1,630 acres.

The best available information indicates that approval of any of the permit applications received after Water Permit Application No. 7724-3 would cause the estimated average annual withdrawal from the Tulare: Western Spink /Hitchcock aquifer to exceed the estimated average annual recharge to the aquifer. South Dakota Codified Law (SDCL) 46-6-3.1 requires that "No application to appropriate groundwater may be approved, if, according to the best information reasonably available, it is probable that the quantity of water withdrawn annually from a groundwater source will exceed the quantity of the average estimated annual recharge of water to the groundwater source." Therefore, pursuant to SDCL 46-2A-9, additional permits to appropriate water cannot be issued from the Tulare: Western Spink/Hitchcock aquifer since there is not a reasonable probability that there is unappropriated water available from the aquifer.

EXISTING WATER RIGHTS:

There have been 310 water permit applications to appropriate water from the Tulare: Western Spink/Hitchcock aquifer. The status of these applications is shown in table 2.

STATUS	NUMBER
CANCELLED	77
DENIED	37
INCORPORATED	46
LICENSED	129
PERMITTED	25
WITHDRAWN	9

Table 2. Status of Water Permit Applications filed from the Tulare: Western Spink/Hitchcock aquifer.

Where the aquifer is under unconfined conditions, drawdown created by pumping is not significant and does not extend very far from the individual production well (see Figure 9). Where the aquifer is under confined conditions water level fluctuations are more pronounced (see Figure 2). Well interference has never been a problem in this aquifer (Goodman, 2002).




Figure 1. DENR-Water Rights' observation well completed into the unconfined portion of the Tulare:Western Spink/Hitchcock aquifer




Figure 2. DENR-Water Rights' observation well completed into the confined portion of the Tulare:Western Spink/Hitchcock aquifer

Regardless, these permits, if approved should contain the standard permit qualification for most groundwater permits/rights which states:

"The well approved under this permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights".

CONCLUSIONS:

1. Based on the historic average irrigation application rate from the Tulare: Western Spink/Hitchcock aquifer (9.32 inches per year), and the current appropriations, there is a reasonable probability that unappropriated water is available to irrigate an additional 1,746 acres.
2. Water Permit Application Nos. 7685-3, 7716-3, 7717-3, 7718-3, 7719-3, 7720-3, 7721-3, 7722-3, 7723-3 and 7724-3 that propose to irrigate a total of 1,630 acres.
3. With approval of Water Permit Application Nos. 7685-3, 7716-3, 7717-3, 7718-3, 7719-3, 7720-3, 7721-3, 7722-3, 7723-3 and 7724-3, the amount of unappropriated water available from the Tulare: Western Spink/Hitchcock aquifer would be sufficient to irrigate 116 acres at the historic average irrigation application rate for the aquifer.
4. Additional irrigation withdrawals are not expected to impair existing users.



Ken Buhler
SD DENR-Water Rights Program

REFERENCES:

- Buhler, K.A., 2012, Report on Water Permit Application No. 7289-3, Bixler Farms; Nos. 7290-3 and 7291-3, Lee Gatzke; No. 7293-3, Jeffery Gatzke; and No. 7292-3, Allen Gatzke; April 25, 2012: SD DENR-Water Rights Program
- Buhler, K.A., 2013, Report to the Chief Engineer on Water Permit Application No. 7373-3, Terry Wieting, Water Permit Application No. 7551-3, Wayne Binger, and Water Permit Application Nos. 7570-3, 7571-3, 7572-3, 7573-3, 7574-3, 7575-3, 7637-3, 7638-3, 7639-3 & 7640-3, Bary Marshall- Marshall Bros., Water Permit Application No. 7620-3, Oscar Inc.; January 30, 2013: SD DENR-Water Rights Program
- Goodman, J.A., 2002, Report on Water Permit Nos 6330-3, 6331-3, 6332-3, 6336-3, 6337-3, 6338-3, 6339-3, 6340-3, 6343-3, 6344-3, 6345-3, 6346-3, 6348-3, 6353-3 for Water From the Tulare Hitchcock Aquifer and Water Permit Nos. 6333-3, 6334-3, 6347-3, 6351-3, 6352-3 for Water From the Tulare Western Spink Aquifer, September 10, 2002: SD DENR-Water Rights Program
- Goodman, J.A., 2007, Report on Deferred Water Permit Applications from the Tulare Hitchcock and Tulare Western Spink Aquifers in Spink, Hand and Beadle Counties, SD: December 5, 2007 Water Management Board Minutes, SD Department of Environment and Natural Resources-Water Rights Program,

APPENDIX A

REPORT TO THE CHIEF ENGINEER
ON

WATER PERMIT APPLICATION NO. 7373-3
TERRY WIETING

WATER PERMIT APPLICATION NO. 7551-3
WAYNE BINGER

WATER PERMIT APPLICATION NOS. 7570-3, 7571-3, 7572-3, 7573-3, 7574-3, 7575-3,
7637-3, 7638-3, 7639-3, & 7640-3
GARY MARSHALL-MARSHALL BROS.

WATER PERMIT APPLICATION NO. 7620-3
OSCAR INC.

JANUARY 30, 2013

Water Permit Application No. 7373-3 proposes to appropriate water at a maximum diversion rate of 1.78 cubic feet of water per second (cfs) from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer. The wells are to be located in the S $\frac{1}{2}$ SW $\frac{1}{4}$ Section 16, T113N-R62W and are expected to be approximately 75 feet deep. This application proposes to irrigate 160 acres located in the SW $\frac{1}{4}$ Section 16, T113N-R62W.

Water Permit Application No. 7551-3 proposes to irrigate 90 additional acres from the well authorized by Water Right No. 470A-3. This application proposes to irrigate 90 acres located in the NE $\frac{1}{4}$, N $\frac{1}{2}$ SE $\frac{1}{4}$ Section 36, T115N-R65W from the existing well with no increase to the developed diversion rate. Water Right No. 470A-3 authorizes 1.56 cubic feet of water per second (cfs) from one well completed into the Tulare: Western Spink/Hitchcock aquifer (130 feet deep) located in the NE $\frac{1}{4}$ SE $\frac{1}{4}$ Section 36 for irrigation of 136 acres located in the SE $\frac{1}{4}$ Section 36, T115N-R65W.

Water Permit Application No. 7570-3 proposes to appropriate water at a maximum diversion rate of 3.56 cfs from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer. The wells are to be located in the center of the NW $\frac{1}{4}$ and the center of the SW $\frac{1}{4}$ Section 1, T113N-R64W and are expected to be approximately 80 feet deep. This application proposes to irrigate 280 acres located in the W $\frac{1}{2}$ Section 1, T113N-R64W.

Water Permit Application No. 7571-3 proposes to appropriate water at a maximum diversion rate of 1.78 cfs from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer. The wells are to be located near the center of the SE $\frac{1}{4}$ Section 4, T113N-R64W and are expected to be approximately 80 feet deep. This application proposes to irrigate 160 acres located in the SE $\frac{1}{4}$ Section 4, T113N-R64W.

Water Permit Application No. 7572-3 proposes to appropriate water at a maximum diversion rate of 1.78 cubic feet of water per second (cfs) from a well to be completed into the Tulare: Western Spink/Hitchcock aquifer. The well is to be located in the center of the SW $\frac{1}{4}$ Section 34,

T114N-R64W and is expected to be approximately 80 feet deep. This application proposes to irrigate 140 acres located in the SW 1/4 Section 34, T114N-R64W.

Water Permit Application No. 7573-3 proposes to appropriate water at a maximum diversion rate of 1.78 cfs from a well to be completed into the Tulare: Western Spink/Hitchcock aquifer. The well is to be located near the center of the NW¼ Section 27, T114N-R63W and is expected to be 80 feet deep. This application proposes to irrigate 160 acres located in the NW¼ Section 27, T114N-R63W.

Water Permit Application No. 7574-3 proposes to appropriate water at a maximum diversion rate of 1.78 cfs from a well to be completed into the Tulare: Western Spink/Hitchcock aquifer. The well is to be located in the center of the NE¼ Section 35, T114N-R64W and is expected to be approximately 80 feet deep. This application proposes to irrigate 160 acres located in the NE¼ Section 35, T114N-R64W.

Water Permit Application No. 7575-3 proposes to appropriate water at a maximum diversion rate of 3.56 cfs from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer. The wells are to be located in the centers of the SW¼ and SE¼ Section 36, T114N-R64W and are expected to be approximately 80 feet deep. This application proposes to irrigate 280 acres located in the S½ Section 36, T114N-R64W.

Water Permit Application No. 7637-3 proposes to appropriate water at a maximum diversion rate of 1.78 cfs from a well to be completed into the Tulare: Western Spink/Hitchcock aquifer. The well is to be located in the center of the SE¼ Section 25, T114N-R64W and is expected to be approximately 80 feet deep. This application proposes to irrigate 135 acres located in the SE¼ Section 25, T114N-R64W.

Water Permit Application No. 7638-3 proposes to appropriate water at a maximum diversion rate of 1.78 cfs from a well to be completed into the Tulare: Western Spink/Hitchcock aquifer. The well is to be located in the center of the SE¼ Section 18, T114N-R63W and is expected to be approximately 80 feet deep. This application proposes to irrigate 135 acres located in the SE 1/4 Section 18, T114N-R63W.

Water Permit Application No. 7639-3 proposes to appropriate water at a maximum diversion rate of 1.78 cfs from a well to be completed into the Tulare: Western Spink/Hitchcock aquifer. The well is to be located in the center of the NW ¼ Section 3, T114N-R64W and is expected to be approximately 80 feet deep. This application proposes to irrigate 135 acres located in the NW¼ Section 3, T114N-R64W.

Water Permit Application No 7640-3 proposes to appropriate water at a maximum diversion rate of 1.78 cfs from two wells to be completed into the Tulare: Western Spink/Hitchcock aquifer. The wells are to be located near the center of the SW¼ Section 8, T113N-R62W and are expected to be approximately 80 feet deep. This application proposes to irrigate 160 acres located in the SW ¼ Section 8, T113N-R62W.

Water Permit Application No. 7620-3 proposes to appropriate water at a maximum diversion rate of 1.94 cfs from a well to be completed into the Tulare: Western Spink/Hitchcock aquifer. The well is to be located in the center of the NE¼ Section 32, T115N-R63W and is expected to be approximately 60 feet deep. This application proposes to irrigate 136 acres located in the NE¼ Section 32, T115N-R63W.

AQUIFER: TULARE: WESTERN SPINK/HITCHCOCK

The Tulare: Western Spink/Hitchcock aquifer was basically considered fully appropriated in 2002 and the amount of development in the aquifer has not changed appreciably since 2003. A number of water permit applications were denied or withdrawn between 2002 and 2011. Six applications to appropriate water from the Tulare: Western Spink/Hitchcock aquifer (No. 7288-3, No. 7289-3, No. 7290-3, No. 7291-3, No. 7292-3 and No. 7293-3) were filed with the DENR-Water Rights Program in December 2011. Based on a DENR-Water Rights staff analysis of the aquifer (Buhler, 2012a) and a stipulation between parties, Water Permit Application No. 7288-3 was withdrawn and the appropriation requests of the five remaining applications were reduced. Following a July 11, 2012 hearing, the Water Management Board approved water permit applications totaling an amount of water approximately equal to the probable quantity of water remaining unappropriated from the aquifer.

Water Permit Application No. 7373-3, Terry Wieting, was received June 14, 2012, and Water Permit Application Nos. 7378-3 and 7379-3, Riverside Hutterian Brethren, were received June 29, 2012. Water Permit Application Nos. 7373-3, 7378-3 and 7379-3 proposed to irrigate an additional 565 acres from the Tulare: Western Spink/Hitchcock aquifer. Based on the 1979-2011 average annual irrigation application rate for the aquifer (i.e. 9.32 inches per acre per year) (Buhler, 2012a), the average annual withdrawal associated with these applications would be 438.8 acre-feet per year.

Based on the April 2012 analysis of the aquifer, the Chief Engineer recommended denial of Water Permit Application Nos. 7378-3 and 7379-3 because the best available information indicated that approval of these applications would cause the estimated average annual withdrawal from the Tulare: Western Spink/Hitchcock aquifer to exceed the estimated average recharge to the aquifer. South Dakota Codified Law (SDCL) 46-6-3.1 requires that "No application to appropriate groundwater may be approved if, according to the best information reasonably available, it is probable that the quantity of water withdrawn annually from a groundwater source will exceed the quantity of the average estimated annual recharge of water to the groundwater source." The applicant did not oppose the Chief Engineer's recommendation and pursuant to SDCL 46-2A-3 the applications were withdrawn from consideration.

The Chief Engineer recommended deferral of Water Permit Application No. 7373-3 pending the resolution of an existing water right (No. 282-3, Renae Veskrina Morog) appropriating water from the Tulare: Western Spink/Hitchcock aquifer that was scheduled for cancellation at the October 3, 2012 Water Management Board meeting. The water right was eventually cancelled due to forfeiture. The Chief Engineer has subsequently determined that since the availability of unappropriated water from an aquifer is based on actual use, the use or in this case nonuse of Water Right No. 282-3 was already considered when analyzing the availability of water from the Tulare: Western Spink/Hitchcock aquifer. Therefore, cancellation of the water right did not result in additional unappropriated water available from the aquifer.

At the time, the April 2012 analysis seemed plausible; however comparison of it with a similar analysis conducted later for the Tulare East James aquifer identified potential inconsistencies between the two analyses. The April 2012 analysis of the Tulare: Western Spink/Hitchcock aquifer appears to have been overly conservative. Two of the fundamental assumptions used in the analysis resulted in an extremely diminished volume of water that was available for

appropriation from the aquifer: 1) In computing the maximum number of acres that could be irrigated from the aquifer based on the average annual recharge and the average annual irrigation application rate, the analysis assumed the irrigation of 100 percent of permitted acreage when in fact, for various reasons, only a fraction of permitted acres are irrigated each year; and 2) In computing the amount that the average annual recharge to the aquifer has exceeded average annual discharge from the aquifer based on observation well data, the portion of the aquifer that was considered under unconfined conditions was estimated based primarily on 1984 data (Kuiper, 1984) which resulted in an overly contracted area.

AQUIFER CHARACTERISTICS:

Although additional data and closer scrutiny of the existing data will allow for improvements to the general deliniation of the Tulare: Western Spink/Hitchcock aquifer, alterations to the “Aquifer Characteristics” section of the April 2012 report to the Chief Engineer (Buhler, 2012a) are not warranted at this time. However, a cursory review of the data suggests that the areal extent of the aquifer as described in the report may have been optimistic.

SDCL 46-2A-9

Pursuant to SDCL 46-2A-9, a permit to appropriate water may be issued only if there is reasonable probability that there is unappropriated water available for the applicant's proposed use, that the proposed diversion can be developed without unlawful impairment of existing rights and that the proposed use is a beneficial use and in the public interest.

WATER AVAILABILITY:

The probability of unappropriated water being available from the Tulare: Western Spink/Hitchcock aquifer can be evaluated by considering SDCL 46-6-3.1 which requires “No application to appropriate groundwater may be approved if, according to the best information reasonably available, it is probable that the quantity of water withdrawn annually from a groundwater source will exceed the quantity of the average estimated annual recharge of water to the groundwater source.”

In applying SDCL 46-6-3.1, the Sixth Judicial Circuit Court ruled in 2005 that if the Water Management Board uses average annual recharge, then it should also use average annual withdrawals to determine if unappropriated water is available from the aquifer (*Hines v. South Dakota Dept. of Environ. and Nat'l. Resources, Hughes County 04-37* (Memorandum Decision, April 29, 2005)).

The availability of unappropriated water from the Tulare: Western Spink/Hitchcock aquifer was evaluated based on observation well data and through consideration of hydrologic budgets for the aquifer.

OBSERVATION WELL DATA:

The analysis of observation well data provides a qualitative means of assessing the aquifer and provides the best information available to evaluate the Tulare: Western Spink/Hitchcock aquifer. In addition, Administrative Rule of South Dakota Section 74:02:05:07 requires that “the Water Management Board shall rely upon the record of observation well measurements to determine

that the quantity of water withdrawn annually from the aquifer does not exceed the estimated average annual recharge to the aquifer.”

The DENR-Water Rights Program monitors 48 observation wells completed into the Tulare: Western Spink/Hitchcock aquifer. The analysis of the DENR-Water Rights Program observation well data provides the best information reasonably available to evaluate withdrawals from an aquifer as compared with recharge to the aquifer. Observation well data showing a steady, continual decline of the aquifer’s water level or artesian pressure could indicate that withdrawals from an aquifer were exceeding recharge. In addition, water level fluctuations in an aquifer dominated by the influences of well withdrawals, or a change in the configuration of the potentiometric surface could indicate that well withdrawals are a significant component in the system relative to recharge and/or natural discharge. Examination of the observation well data to consider long term water level trends, any influences of well withdrawals and the configuration of the potentiometric surface of the aquifer are discussed below.

Observation well water level trends:

A rising water level indicates that recharge to the aquifer exceeds withdrawals from the aquifer and conversely a declining water level is indicative of withdrawals exceeding recharge. An equation for this relationship is:

$$\Delta S = R - D$$

Where: ΔS = change in the volume of water in storage in the aquifer

R = Recharge

D = Discharge

The observation well data for the Tulare: Western Spink/Hitchcock aquifer has documented upward trending water levels throughout the aquifer. The average slope of linear trend lines for observation well hydrographs over the time period of January 2003 through October 2012 has been (+0.284 feet per year). The upward trending water levels indicate recharge to the Tulare: Western Spink/Hitchcock aquifer has been greater than the total of the discharges from the aquifer over the period of record.

An analysis of observation well hydrographs was used to quantify the change in volume of water in storage in the aquifer (i.e. the amount that recharge to the aquifer has exceeded discharge from the aquifer). The analysis involved identifying observation wells completed into the unconfined portion of the Tulare: Western Spink/Hitchcock aquifer and determining the annual change of the water level in each well. The amount of water represented by a change in water level was determined by multiplying the water level change by the aquifer’s specific yield (0.15) (Kuiper, 1984). The average change in storage was applied over the portion of the aquifer that is under unconfined conditions to determine the volume in acre-feet per year of the change in storage. In equation form:

$$\Delta V_{avg} = \Delta W_{at Lev_{avg}} * S_y * A$$

Where:

ΔV_{avg} = Average change in volume (ac-ft/yr)

Wat Lev_{avg} = Average change in water level (ft/yr)

S_y = Specific Yield

A = Area (acres)

The average annual change in water level (Wat Lev_{avg}) in the Tulare: Western Spink/Hitchcock aquifer was determined through examination of DENR-Water Rights' observation well data. Five observation wells were used to analyze the Tulare: Western Spink/Hitchcock aquifer since they were the only ones that were in portions of the aquifer that remained unconfined for the entire period of record (Water Year 2003 through Water Year 2012) and the wells were determined to accurately reflect aquifer conditions. The results of the analysis are shown in Table 1.

ANNUAL WATER LEVEL CHANGE (ft)						
	SP-79F	SP-78B	SP-80B	SP-82E	SP-82G	AVE
2003	-0.32	-0.69	-1.12	-0.82	-0.87	-0.764
2004	0.62	-0.5	-0.79	0.45	-0.65	-0.174
2005	-0.18	-0.18	0.23	1.54	0.3	0.342
2006	0.16	-0.1	0.08	-1.09	0.35	-0.12
2007	1.67	1.81	2.21	2.77	2.2	2.132
2008	0.56	0	0.37	1.1	1.1	0.626
2009	0.32	0.99	1.02	-0.3	0.66	0.538
2010	1.23	2.46	1.58	0.7	1.44	1.482
2011	3.5	0.55	2.3	0	-0.7	1.13
2012	-3.1	-1.2	-2	-1.8	-2.1	-2.04
AVE	0.4460	0.3140	0.3880	0.2550	0.1730	0.3152

Table 1. Water Level change per year per observation well (Water Rights, 2013a).

To determine the area (A) of the Tulare: Western Spink/Hitchcock aquifer that was under unconfined conditions, ESRI @ArcMap™10.0 was used to generate a Triangulated Irregular Network (TIN) of the aquifer's potentiometric surface using October 2012 observation well readings. The TIN was converted to a raster file using a Natural Neighbors interpolation method. A second TIN was created using the elevation of the upper most aquifer material encountered in test holes drilled by the DENR-Geological Survey and DENR-Water Rights Program observation wells within the areal extent of the aquifer as defined in the April 2012 aquifer analysis. This TIN was also converted to a raster file using a Natural Neighbors interpolation method. ESRI @ArcMap™10.0 raster calculator was used to subtract the potentiometric surface raster from the "first aquifer material" raster and generate a raster where aquifer material occurred above the potentiometric surface. DENR-Geological Survey test holes(Lithologic Logs), DENR-Water Rights Program observation wells (Water Rights, 2013a), domestic wells (Water Rights, 2013b), and irrigation wells (Water Rights, 2013c) within and adjacent to this resultant raster were examined to determine if the aquifer material that was above the Tulare: Western Spink/Hitchcock potentiometric surface was actually part of the aquifer. Based on this analysis, the unconfined portion of the Tulare: Western Spink aquifer was determined to be 76,978 acres (see figure 1).




Figure 1. Areal extent of the Tulare: Western Spink/Hitchcock aquifer and the unconfined areas of the aquifer.

Substituting the values from above for the equation $\Delta V_{avg} = \Delta W_{at Lev_{avg}} * S_y * A$,

$$\Delta V_{avg} = 0.3152 \text{ ft/yr} * 0.15 * 76,978 \text{ acres}$$

$$\Delta V_{avg} = 3,639.5 \text{ ac-ft/yr}$$

Therefore, the observation well data indicates that the annual recharge to the aquifer exceeded discharge from the aquifer by an average of 3,640 acre-feet per year for the period since development has been static (2003-2012).

Water level fluctuations due to well withdrawals:

Observation well data documents that the development that has occurred from the Tulare: Western Spink/Hitchcock aquifer has had an inconsequential effect on the aquifer over the long term. Figures 2-6 show hydrographs for DENR-Water Rights Program observation wells completed into the aquifer and Figure 7 shows the location of these wells. The water level records for the observation wells document that climatic conditions greatly mask the temporal effects of well withdrawals. Therefore, recharge to and natural discharge from the Tulare: Western Spink/Hitchcock aquifer significantly exceeds pumping. Recognizing that natural

discharge from the aquifer can be captured for pumping. The hydrographs document that there is unappropriated water available from the aquifer to support these appropriations.




Figure 2. Hydrograph of DENR-Water Rights Program observation well completed into the Tulare: Western Spink/Hitchcock aquifer.




Figure 3. Hydrograph of DENR-Water Rights Program observation well completed into the Tulare: Western Spink/Hitchcock aquifer.




Figure 4. Hydrograph of DENR-Water Rights Program observation well completed into the Tulare: Western Spink/Hitchcock aquifer.




Figure 5. Hydrograph of DENR-Water Rights Program observation well completed into the Tulare: Western Spink/Hitchcock aquifer.




Figure 6. Hydrograph of DENR-Water Rights Program observation well completed into the Tulare: Western Spink/Hitchcock aquifer.




Figure 7. Location of DENR-Water Rights Program observation wells completed into the Tulare: Western Spink aquifer and wells shown in Figures 2-6.

Potentiometric Surface:

The potentiometric surface of the Tulare: Western Spink/Hitchcock aquifer was determined for two time periods based on the observation well measurements for October 1987 and for October 2012. A map showing the two potentiometric surfaces is shown in Figure 8. It is clear that although there are some nuances in the potentiometric surfaces, the surface is essentially unchanged; indicating that discharge is not exceeding recharge and unappropriated water is available from the aquifer.




Figure 8. Comparison of the potentiometric surface of the Tulare: Western Spink/Hitchcock aquifer (October 1987 versus October 2012)

Regional flow net analysis using observation well data:

The recharge potential of the Tulare: Western Spink/Hitchcock aquifer was evaluated by interpreting a regional flow net analysis based on the September 2012 water level data from the DENR-Water Rights' Observation Well Network. A flow net analysis is a calculation of the amount of water flowing through the aquifer according to the equation:

$$Q = TIL$$

Where:

Q= flow in gallons per day

T= Transmissivity in gallons per day per foot

I= Hydraulic gradient in feet per mile

L= Cross sectional length in miles

The average hydraulic conductivity for the Tulare: Western Spink/Hitchcock aquifer was estimated based on the specific capacities of the 30 irrigation wells completed into the aquifer for which the data to allow these calculations was available (Water Rights, 2013b; Water Rights, 2013c). Transmissivity was calculated at each well using the wells' specific capacity ("Transmissivity from Specific Capacity"), and the transmissivity was divided by the aquifer

thickness at the well to determine an average hydraulic conductivity for the aquifer. The average hydraulic conductivity was calculated to be 1,982 gallons per day per square foot (gpd/ft²). The average transmissivity of the Tulare: Western Spink/Hitchcock aquifer of a cross section through which all of the flow of the aquifer must flow was determined by multiplying the average thickness of the cross section (36.3 feet) times the average hydraulic conductivity for the aquifer (1,982 gallons per day per square foot) to be 71,950 gallons per day per foot.

The hydraulic gradient for the Tulare: Western Spink/Hitchcock aquifer was estimated to average 4.26 feet per mile based on data from the DENR-Water Rights' Observation Well Network.

The cross section length of the Tulare: Western Spink/Hitchcock aquifer was determined to be approximately 25 miles based on the current aquifer delineation.

The amount of water moving through the Tulare: East James aquifer is estimated as follows:

$$\begin{aligned} Q &= ((71,950 \text{ gpd/ft}) \times (4.26 \text{ ft/mile}) \times (25 \text{ miles})) / (325,851 \text{ gallons/ac-ft}) \\ &= 23.5 \text{ ac-ft/day} \\ &= \underline{8,583 \text{ ac-ft/yr}} \end{aligned}$$

In order to sustain this estimated volume of groundwater moving through the aquifer, the recharge rate in inches per acre per year based on an area of the aquifer of approximately 263,000 acres would be 0.39 inches. This recharge rate cannot be considered "average annual recharge" since it used only 2012 data, and likely can be viewed as a minimum recharge rate; however the estimate does show the reasonableness of the average annual recharge estimate from Kuiper (1984).

HYDROLOGIC BUDGETS:

SDCL 46-6-3.1 and the availability of unappropriated water from the Tulare: Western Spink/Hitchcock aquifer can be evaluated by considering a hydrologic budget for the aquifer which compares the recharge to and discharge from the aquifer.

Recharge to the Tulare: Western Spink/Hitchcock aquifer occurs primarily through infiltration of precipitation where the outwash is at or near ground surface. The best information reasonably available to estimate the average annual recharge to the aquifer is from the groundwater flow model developed by Kuiper (1984). The model incorporated an average recharge rate throughout the aquifer although recharge generally occurs only in unconfined areas. The average annual recharge to the aquifer based on the groundwater flow model ranged from 0.41-1.66 inches per year with a "best fit" reflecting various simulations of 0.83 inches per year (Kuiper, 1984). Considering an areal extent of the Tulare: Western Spink/Hitchcock aquifer equal to 263,016 acres and applying a 0.83 inches per year recharge rate, the average annual recharge to the Tulare: Western Spink/Hitchcock aquifer is estimated to total 18,192 acre-feet per year.

Withdrawals from the Tulare: Western Spink/Hitchcock occur through natural discharge, domestic use and uses from appropriative rights/permits. Essentially all of the well withdrawals from the aquifer are for irrigation use. For the period of 1979 through 2011, irrigation pumpage

from the aquifer is shown in Table 2, and the average irrigation application rate over this period was 9.32 inches per acre per year (Buhler, 2012a).

REPORTED IRRIGATION PUMPING (1979-2011)	ACRE-FEET PER YEAR
Maximum	19397.25
Minimum	2200.29
Average	9725.6

Table 2. Reported irrigation pumping from the Tulare: Western Spink/Hitchcock aquifer for 1979-2011 (Buhler, 2012a)

Since 1979-2012 was a time period that included new development from the aquifer, the average irrigation pumpage for this time period is likely low. However, the average application rate for this time period can be considered reflective of the irrigation practices in the aquifer.

The time period of 2003-2011 reflects fully developed conditions in the aquifer. Irrigation pumpage for this time period is shown in Table 3. The average application rate for the 2003-2011 time period was 8.71 inches per year. The application rate for 2003-2011 likely is more reflective of the climatic conditions over the relatively short (nine year) period than actual irrigation practices in the aquifer.

REPORTED IRRIGATION PUMPING (2003-2011)	ACRE-FEET PER YEAR
Maximum	19397.25
Minimum	3007.9
Average	12286.8

Table 3. Reported irrigation pumping from the Tulare: Western Spink/Hitchcock aquifer for 2003-2011 (Water Rights, 2004-2012)

Two methods were used to evaluate the availability of unappropriated water with separate hydrologic budgets: 1) comparing estimated average annual recharge to the aquifer with the average annual reported well withdrawals over the time period the aquifer was fully developed; and 2) comparing the number of acres that can be irrigated based on the estimated average annual recharge to the aquifer to the number of acres currently authorized for irrigation by water rights/permits.

Irrigation Questionnaire Method:

The amount of unappropriated water that is available from the Tulare: Western Spink/Hitchcock aquifer was estimated by comparing the estimated average annual recharge rate to the average annual well withdrawal from 2003-2011. Since average annual recharge is estimated to be 18,192 ac-ft/yr and the average annual pumping was reported to be 12,286.8 ac-ft/yr, an average of 5,905 acre-feet of unappropriated water is available from the Tulare: Western Spink/Hitchcock aquifer based on this methodology.

Recharge to Acres Method:

The amount of unappropriated water that is available from the Tulare: Western Spink/Hitchcock aquifer was also estimated by comparing the maximum number of acres that could be irrigated from the aquifer based on the estimated average annual recharge and the average irrigation application rate, to the number of acres that are currently authorized for irrigation. The volume of water associated with the potential additional irrigable acres was converted to acre-feet per year based on the average irrigation application rate.

The maximum average annual irrigation withdrawal based on a recharge of 18,192 acre-feet per year and an application rate of 9.32 inches per year would allow for the irrigation of 23,423 acres. There are currently 23,648.8 acres authorized for irrigation from the aquifer with water rights/permits. Since 2003, the average percentage of authorized acres that have been irrigated annually ranged from a maximum of 85.58% to a minimum of 31.17% with an average of 69.02%. This irrigated to authorized percentage agrees fairly well with the same percentages calculated for Tulare: East James aquifer (i.e. Maximum=88.41%, Minimum=39.49%, Average=65.34%) (Buhler, 2012b), for the fully developed time period for that aquifer (1979-2011). Since on average, only 69.02% of authorized acres are irrigated annually, the number of acres that can be expected to be irrigated under current authorization is 23,648.8 acres *69.02% or 16,322.4 acres. The difference between maximum allowable acres (23,423 acres) and expected irrigation acreage currently authorized (16,322.4 acres) shows that an additional 7,100 acres could be irrigated from the Tulare: Western Spink/Hitchcock aquifer. Assuming an average application rate of 9.32 inches per year applied to 7,100 acres equates to 5,514 ac-ft/yr.

In another format, the “recharge to acres method” compares the average acreage reported irrigated annually from 2003-2011 (15763.6 acres) plus 69.02% of the 810 acres added in 2012 (559.1 acres) with the maximum number that can be irrigated based on the recharge rate (23,423 acres) or 23,423 acres – (15763.6+559.1) = 7,100 acres.

WATER AVAILABILITY SUMMARY:

The DENR-Water Rights Program observation well data indicates that unappropriated water is available from the Tulare: Western Spink/Hitchcock aquifer. Analysis of the observation well data shows that from 2003-2012, recharge to the Tulare: Western Spink/Hitchcock aquifer has exceed discharge from the aquifer by an estimated 3,640 acre-feet per year. A comparison of the average annual pumpage reported from the aquifer from 2003-2011 with the estimated average annual recharge to the aquifer suggests that recharge exceeds pumping by 5,905 acre-feet. Comparing the number of acres that can be irrigated based on the average annual recharge rate suggests that recharge exceeds withdrawals from the aquifer by 5,514 ac-ft/yr.

The difference between the observation well method and budgeting methods for determining the amount of unappropriated water that is available from the aquifer is likely due to a number of factors. Budgeting methods resulted in greater amounts of unappropriated water available from the aquifer however: a) Irrigation questionnaire data is not available for 2012 at this time and it is likely that the 2012 data will increase the averages for the number of acres irrigated, amount of water pumped and the percentage of irrigated to permitted acres. Higher current use averages will reduce the amount of water available based on budgets; b) Budgeting methods are all dependent upon self-reporting by-way of annual irrigation questionnaires. Errors in the reporting

and/or interpretation of the irrigation questionnaires would influence the results; and c) the average annual growing season precipitation in this area for 2003-2011 was 21.19 inches per year, compared to the 20 year average growing season precipitation of 18.35 inches per year (Mathiowetz, 2012). The averages for the number of acres irrigated, amount of water pumped and the percentage of irrigated to permitted acres are likely low due to climatic conditions. Consequently, estimates based on budgets for the amount of water remaining available for appropriation and/or the number of additional acres that can be irrigated are likely too high. The observation well method: a) does reflect 2012 climatic conditions and b) is less influenced by short term trends, for example, the average water level fluctuation for observation wells was +0.315 feet per year for 2003-2012, compared with a +0.261 feet per year average for water years 1983-2012.

For the reasons listed above, and the fact that Administrative Rule of South Dakota Section 74:02:05:07 requires that “the Water Management Board shall rely upon the record of observation well measurements to determine that the quantity of water withdrawn annually from the aquifer does not exceed the estimated average annual recharge to the aquifer” the amount of unappropriated water available from the Tulare: Western Spink Hitchcock aquifer is estimated to be 3,640 acre-feet per year. Based on the historic average annual irrigation application rate of 9.32 inches per year, on average an additional 4,686 acres can be irrigated from the Tulare: Western Spink/Hitchcock aquifer.

EXISTING WATER RIGHTS:

There have been 310 water permit applications to appropriate water from the Tulare: Western Spink/Hitchcock aquifer. The status of these applications is shown in table 4.

STATUS	NUMBER
CANCELLED	77
DENIED	37
INCORPORATED	46
LICENSED	129
PERMITTED	13
WITHDRAWN	8

Table 4. Status of Water Permit Applications filed from the Tulare: Western Spink/Hitchcock aquifer .

Where the aquifer is under unconfined conditions, drawdown created by pumping is not significant and does not extend very far from the individual production well (see figure 9). Where the aquifer is under confined conditions water level fluctuations are more pronounced (see figure 10). Well interference has never been a problem in this aquifer (Goodman, 2002).




Figure 9. DENR-Water Rights' observation well completed into the unconfined portion of the Tulare:Western Spink/Hitchcock aquifer




Figure 10. DENR-Water Rights' observation well completed into the confined portion of the Tulare:Western Spink/Hitchcock aquifer

Regardless, these permits, if approved should contain the standard permit qualification for most groundwater permits/rights which states:

“The well approved under this permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights”.

CONCLUSIONS:

1. The best information currently available indicates the Tulare: Western Spink/Hitchcock aquifer underlies approximately 263,016 acres of Beadle, Spink, and Hand Counties.
2. The best information currently available identifies an average annual recharge rate to the Tulare: Western Spink/Hitchcock aquifer as 0.83 inches per year.
3. The volume of average annual recharge to the Tulare: Western Spink/Hitchcock aquifer based on an area of 263,016 acres and a recharge rate of 0.83 inches per year is approximately 18,192 acre-feet per year.
4. The average annual irrigation application rate for the Tulare: Western Spink/Hitchcock aquifer from 1979-2011 has been 9.32 inches per year.
5. The maximum **average** annual irrigation withdrawal based on a recharge of 18,192 acre-feet per year and an application rate of 9.32 inches per year would allow for the irrigation of 23,423 acres.
6. The best information available to determine the amount of unappropriated water available from the Tulare: Western Spink/Hitchcock aquifer is through analysis of observation well data.
7. The analysis of DENR-Water Rights' observation well data identifies that the over the period of record of 2003- 2011, average annual recharge to the aquifer has exceeded the average annual withdrawals from the aquifer by approximately 3,640 ac-ft/yr acre-feet per year.
8. The observation well data indicates that another 4,686 acres could have been irrigated over the time period of 2003- 2011, at an average application rate of 9.32 inches per year.
9. Since 810 additional acres were authorized in 2012, the actual number of additional acres that can be irrigated from the Tulare: Western Spink/Hitchcock aquifer is 3,877 acres.
10. The permit applications described on pages 1-3 of this report propose to irrigate a total of 2,131 acres.
11. Additional irrigation withdrawals are not expected to impair existing users.

Ken Buhler
SD DENR-Water Rights Program

REFERENCES:

- Buhler, K.A., 2012a, Report on Water Permit Application No. 7289-3, Bixler Farms; Nos. 7290-3 and 7291-3, Lee Gatzke; No. 7293-3, Jeffery Gatzke; and No. 7292-3, Allen Gatzke; April 25, 2012: SD DENR-Water Rights Program
- Buhler, K.A., 2012b, Report to the Chief Engineer on Water Permit Application No. 7295-3, William F. St. Clair; No. 7316-3, Van Buskirk Farms LLP; No. 7348-3, Michael Sentell; No. 7364-3, Wipf Acres LP; No. 7365-3, Huron Colony; No. 7366-3, Huron Colony; No. 7367-3, Huron Colony; No. 7368-3 Huron Colony; No. 7369-3 Huron Colony; and No. 7370-3 Huron Colony; August 23, 2012: SD DENR-Water Rights Program

Circuit Court of South Dakota, Sixth Judicial Circuit, 2005, April 29, 2005 Memorandum Decision re: HU04-37 Hines v. SD Department of Environment and Natural Resources

Goodman, J.A., 2002, Report on Water Permit Nos 6330-3, 6331-3, 6332-3, 6336-3, 6337-3, 6338-3, 6339-3, 6340-3, 6343-3, 6344-3, 6345-3, 6346-3, 6348-3, 6353-3 for Water From the Tulare Hitchcock Aquifer and Water Permit Nos. 6333-3, 6334-3, 6347-3, 6351-3, 6352-3 for Water From the Tulare Western Spink Aquifer, September 10, 2002: SD DENR-Water Rights Program

Kuiper, L.K. 1984, Appraisal of the Water Resources of The Eastern Part of the Tulare Aquifer, Beadle, hand, and Spink Counties, South Dakota: U.S. Geological Survey Water-Resources Investigations Report 84-4078, 52 p.

Mathiowetz, A.W. 2012. Unpublished data. Pierre, SD.: South Dakota Department of Environment and Natural Resources Water Rights Programs.

“Transmissivity from Specific Capacity.” Aquifer Test Forum sponsored by HydroSOLVE, Inc. 28 January.2013< <http://www.aqtesolv.com/forum/transcap.asp>

Water Rights, 2004-2012, Irrigation Questionnaire Summaries 2003-2011, SD DENR-Water Rights Program, Joe Foss Bldg, Pierre, SD.

Water Rights, 2013a, Observation Well Files, SD DENR-Water Rights Program, Joe Foss Bldg, Pierre, SD.

Water Rights, 2013b, Water Well Completion Reports, SD DENR-Water Rights Program, Joe Foss Bldg, Pierre, SD.

Water Rights, 2013c, Water Right/Permit Files, SD DENR-Water Rights Program, Joe Foss Bldg, Pierre, SD.

PRINTER'S AFFIDAVIT

STATE OF SOUTH DAKOTA,
COUNTY OF BEADLE: ss.

RECEIVED


JUN 27 2013

WATER RIGHTS
PROGRAM

I, ELDON JACOBS, being duly sworn on oath, say that THE PLAINSMAN is a daily paper published at Huron, Beadle County, South Dakota, and that said newspaper has a bona fide circulation of at least 250 copies daily; that said newspaper has been published within said county for fifty-two consecutive weeks immediately prior to this date, that said newspaper is printed in whole or in part, in an office maintained at said place of publication; that I am Legal Advertising Coordinator of said newspaper and know the facts herein state. The annexed notice headed:

SD ENVIRONMENTAL & NATURAL - WATER RIGHTS - WIETING

was published for one day, in said newspaper, and not in any supplement of the said newspaper, the publication was of the 12TH day JUNE 2013 That the full SEVENTY-SEVEN & 99/000 dollars insures to the benefit of the publisher of said newspaper; that no agreement or understanding for the division thereof has been made with any other person, and that no part thereof has been agreed to be paid to any person whom so ever.



Subscribed and sworn to before me this 30TH day of JUNE 2013.


Notary Public, South Dakota

My term expires 10/25/2017

Legal # 818

F.P. 08-12-13

**NOTICE OF HEARING
on Application
No. 7721-3 to
Appropriate Water**

Notice is given that Terry Wieting, 870 Beach Ave NE, Huron SD 57350 has filed Application No. 7721-3 to appropriate 1.33 cubic feet of water per second from one well to be completed into the Tulare: Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the SW 1/4 Section 18 for irrigation of 100 acres located in the SW 1/4 Section 18; all in T114N-R63W.

SDCL 46-2A-4(10) provides that "if the applicant does not contest the recommendation of the Chief Engineer and no petition to oppose the application is received, the Chief Engineer shall act on the application pursuant to the Chief Engineer's recommendation and no hearing may be held before the board, unless the Chief Engineer makes a finding that an application, even if uncontested, presents important issues of public policy or public interest that should be heard by the board." In this case, the Chief Engineer finds that these applications presents important issues of public interest that should be heard by the Water Management Board.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application No. 7721-3 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water, and 4) it is in the public interest.

The Water Management Board will consider the application at 3:00 p.m. on July 10, 2013 in the Matthew Training Center, Joe Foss Bldg, 523 E. Capitol Ave. Pierre SD. The Chief Engineer's recommendation is not final or binding upon the Board. The Board is authorized to 1) approve, 2) approve with qualifications, 3) defer, or 4) deny this application based on the facts presented at the public hearing.

~~Any interested person~~ who intends to participate in the hearing shall file a petition to oppose or support the application and the petition shall be filed with BOTH the applicant and Chief Engineer. The applicant must also file a petition if opposed to the Chief Engineer's recommendation. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by July 1, 2013. The petition may be informal, but shall be in writing and shall include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. The hearing is an adversary proceeding and any party has the right to be present at the hearing and to be represented by a lawyer. These and other due process rights will be forfeited if they are not exercised at the hearing and decisions of the Board may be appealed to the Circuit Court and State Supreme Court as provided by law.

The July 10, 2013 hearing date will be automatically delayed for at least 20 days upon written request to the Chief Engineer from the applicant or any person who has filed a petition to oppose or support the application. The request for an automatic delay must be filed by July 1, 2013. If an automatic delay is requested, the hearing will be rescheduled for a future Board

meeting and personal notice will be provided to all petitioners regarding the time, date and location.

Contact Eric Gronlund by July 1, 2013 at the above Chief Engineer's address to request copies of the staff report, recommendation, application or other information. Notice is given to individuals with disabilities that this hearing is being held in a physically accessible place. Please notify the Department of Environment and Natural Resources at least 48 hours before the hearing if you have a disability for which special arrangements must be made at the hearing. The telephone number for making arrangements is (605) 773-3352.

Under SDCL 1-26-17(7) notices must state that "if the amount in controversy exceeds \$2,500.00 or if a property right may be terminated, any party to the contested case may require the agency to use the Office of Hearing Examiners by giving notice of the request to the agency no later than ten days after service of a notice of hearing issued pursuant to SDCL 1-26-17." This is a Notice of Hearing, service is being provided by publication, and the applicable date to give notice to the Chief Engineer is June 17,

2013. However, since this particular matter is a water permit application and not a monetary controversy in excess of \$2,500.00 or termination of a property right the Chief Engineer disputes the applicability of this provision and maintains that the hearing must be conducted by the Board.

As applicable, the following provides the legal authority and jurisdiction under which the hearing will be held and the particular statutes and rules pertaining to this application: SDCL 1-26-16 thru 1-26-28; SDCL 46-1-1 thru 46-1-9, 46-1-13 thru 46-1-16; 46-2-3.1, 46-2-9, 46-2-11, 46-2-17; 46-2A-1 thru 46-2A-12, 46-2A-14, 46-2A-15, 46-2A-20, 46-2A-21, 46-2A-23; 46-5-1.1, 46-5-2 thru 46-5-26, 46-5-30.2 thru 46-5-30.4, 46-5-31, 46-5-32 thru 46-5-34.1, 46-5-38 thru 46-5-39, 46-5-46, 46-5-47, 46-5-49; 46-6-1 thru 46-6-3.1, 46-6-6.1, 46-6-10, 46-6-13, 46-6-14, 46-6-21, 46-6-26; and Board Rules ARSD 74:02:01:01 thru 74:02:01:25.02; 74:02:01:35.01.

Steven M. Pirner,
Secretary, Department
of Environment and
Natural Resources.

No. 818 (adv.)

Published once at the
total approximate cost of
\$74.33.

Affidavit of Publication RECEIVED

STATE OF SOUTH DAKOTA,
County of Spink: ss.

JUN - 7 2013

WATER RIGHTS
PROGRAM


I, Mark E. Davis, of said County & State, being first duly sworn on oath, say that THE REDFIELD PRESS is a legal weekly newspaper as defined in Sec. 65.0508 South Dakota Code 1939, as amended by Chapter 298 of the Session of Laws of 1939, printed and published in the English language in the City of Redfield, in said County and State, by THE REDFIELD PRESS, and has been such newspaper during the time hereinafter mentioned, and that I Mark E. Davis, the undersigned, am Publisher of said newspaper in charge of the advertising department thereof, and have personal knowledge of all the facts stated in this affidavit, and that the legal or official notice entitled:

#363 Notice

A printed copy of which is hereto attached, was printed and published in said newspaper in 1 issue, to wit: The first publication being made on June 5th, that Sixty-five and .10/100 Dollars, insures to the benefit of the publisher of THE REDFIELD PRESS, that no agreement or understanding for the division thereof has been made with any other person, and that no part thereof has been agreed to be paid to any person whomsoever.



Subscribed and sworn to before me this 5th day of June, 2013.


Notary Public, South Dakota

My commission expires 04/06/2016.

Notice

#363

NOTICE OF HEARING ON APPLICATION NOS. 7717-3, 7718-3, 7720-3 AND 7721-3 TO APPROPRIATE WATER.

Notice is given that Terry Wieting, 870 Beach Ave NE, Huron SD 57350 has filed an following applications for water permits.

Application No. 7717-3 proposes to appropriate 1.78 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the NE 1/4 Section 10 for irrigation of 135 acres located in the NE 1/4 Section 10; all in T113N-R64W.

Application No. 7718-3 proposes to appropriate 1.78 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the SE 1/4 Section 9 for irrigation of 135 acres located in the SE 1/4 Section 9; all in T113N-R64W.

Application No. 7720-3 proposes to appropriate 1.78 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the NE 1/4 Section 25 for irrigation of 135 acres located in the NE 1/4 Section 25; all in T114N-R64W.

Application No. 7721-3 proposes to appropriate 1.33 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the SW 1/4 Section 18 for irrigation of 100 acres located in the SW 1/4 Section 18; all in T114N-R63W.

SDCL 46-2A-4(10) provides that "if the applicant does not contest the recommendation of the Chief Engineer and no petition to oppose the application is received, the Chief Engineer shall act on the application pursuant to the Chief Engineer's recommendation and no hearing may be held before the board, unless the Chief Engineer makes a finding that an application, even if uncontested, presents important issues of public policy or public interest that should be heard by the board." In this case, the Chief Engineer finds that these applications presents important issues of public interest that should be heard by the Water Management Board.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application Nos. 7717-3, 7718-3, 7720-3 and 7721-3 because 1) unappropriated water is available, 2) existing rights will not be unlawfully

impaired; 3) it is a beneficial use of water, and 4) it is in the public interest.

The Water Management Board will consider these application at 3:00 p.m. on July 10, 2013 in the Matthew Training Center, Joe Foss Bldg, 523 E. Capitol Ave. Pierre SD. The Chief Engineer's recommendations are not final or binding upon the Board. The Board is authorized to 1) approve, 2) approve with qualifications, 3) defer, or 4) deny this application based on the facts presented at the public hearing.

Any interested person who intends to participate in the hearing shall file a petition to oppose or support these applications and the petition shall be filed with BOTH the applicant and Chief Engineer. The applicant must also file a petition if opposed to the Chief Engineer's recommendations. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by July 1, 2013. The petition may be informal, but shall be in writing and shall include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. The hearing is an adversary proceeding and any party has the right to be present at the hearing and to be represented by a lawyer. These and other due process rights will be forfeited if they are not exercised at the hearing and decisions of the Board may be appealed to the Circuit Court and State Supreme Court as provided by law.

The July 10, 2013 hearing date will be automatically delayed for at least 20 days upon written request to the Chief Engineer from the applicant or any person who has filed a petition to oppose or support the application. The request for an automatic delay must be filed by July 1, 2013. If an automatic delay is requested, the hearing will be rescheduled for a future Board meeting and personal notice will be provided to all petitioners regarding the time, date and location.

Contact Eric Gronlund by July 1, 2013 at the above Chief Engineer's address to request copies of the staff report, recommendation, application or other information. Notice is given to individuals with disabilities that this hearing is being held in a physically accessible place. Please notify the Department of Environment and Natural Resources at least 48 hours before the hearing if you have a disability for which special arrangements must be made at the hearing. The telephone number for making arrangements is (605) 773-3352.

Under SDCL 1-26-17(7) notices must state that "if the amount in controversy exceeds \$2,500.00 or if a property right may be terminated, any party to the contested case may require the agency to use the Office of Hearing Examiners by giving notice of the request to the agency no later than ten days after service of a notice of hearing issued pursuant to SDCL 1-26-17." This is a Notice of Hearing, service is being provided by publication, and the applicable date to give notice to the Chief Engineer is June 17, 2013.

However, since this particular matter is a water permit application and not a monetary controversy in excess of \$2,500.00 or termination of a property right the Chief Engineer disputes the applicability of this provision and maintains that the hearing must be conducted by the Board.

As applicable, the following provides the legal authority and jurisdiction under which the hearing will be held and the particular statutes and rules pertaining to this application: SDCL 1-26-16 thru 1-26-28; SDCL 46-1-1 thru 46-1-9; 46-1-13 thru 46-1-16; 46-2-31

AND SIMILAR RULES TO BOTTOM

46-2-9, 46-2-11, 46-2-17; 46-2A-1 thru 46-2A-12, 46-2A-14, 46-2A-15, 46-2A-20, 46-2A-21, 46-2A-23; 46-5-1.1, 46-5-2 thru 46-5-26, 46-5-30.2 thru 46-5-30.4, 46-5-31 46-5-32 thru 46-5-34.1, 46-5-38 thru 46-5-39, 46-5-46, 46-5-47, 46-5-49; 46-6-1 thru 46-6-3.1, 46-6-6.1, 46-6-10, 46-6-13, 46-6-14, 46-6-21, 46-6-26; and Board Rules ARSD 74:02:01:01 thru 74:02:01:25:02; 74:02:01:35:01.

Steven M. Pirner, Secretary
Department of Environment and
Natural Resources
Published at an approximate cost of
\$65.10. (June 5)



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182

denr.sd.gov

May 29, 2013

Plainsman
PO Box 1278
Huron SD 57350

ATTENTION: Legal Public Notice

Enclosed is a Notice on Application Nos. 7717-3, 7718-3, 7720-3 and 7721-3 to Appropriate Water. Please publish the notice once on June 5, 2013. The text of the notice can be e-mailed to your paper by contacting Karen Schlaak at (605) 773-3352.

The applicant must verify to you that the notice is to be published and arrange for payment. **Please BILL the APPLICANT for the cost of publication.** The APPLICANT is Terry Wieting, 870 Beach Ave NE, Huron SD 57350 (Ph # 605-554-0207).

Please send the Water Rights Program an affidavit or the enclosed Proof of Publication form immediately.

The applicant pays the cost of publication, but the Water Rights Program records require an affidavit or Proof of Publication. Delays in receiving the affidavit can be costly to the applicant.

Sincerely,

Eric Gronlund
Natural Resources Engineer
605 773-3352

enclosures

Schlaak, Karen

From: Schlaak, Karen
Sent: Thursday, May 30, 2013 7:56 AM
To: Ruby Crandall (rnewman.plainsman@midconetwork.com)
Subject: Five Notices for June 5th
Attachments: 7685-3public.wmb.docx; 7716-3public.wmb.docx; 7719-3public.wmb.docx;
7717-21-3pluralpublic.wmb.docx; 7722-24-3pluralpublic.wmb.docx

Attached are 5 notices to be published on June 5, 2013. The applicants have been notified to authorize publication and arrange for payment.

No. 7685-3, Michael Watson, 18583 393th Ave, Hitchcock SD 57348 (605 350-1356)

No. 7716-3, Denis & Craig Slepikas, 524 4t St SW, Huron SD 57350 (605 354-2014)

No. 7719-3, Marshall Brothers, c/o Gary Marshall, 19032 388th Ave, Hitchcock SD (605 350-1401)

Nos. 7717-3, 7718-3, 7720-3 and 7721-3, Terry Wieting, 870 Beach AVE NE, Huron SD (605 554-0207)

Nos. 7722-3, 7723-3 and 7724-3, Brent/Leland Kleinsasser, 20188 401st Ave, Huron SD (605 350-2046)

If you have questions, please let me know.

Karen Schlaak

Water Rights Program

Phone: 605 773-3352

Fax: 605 773-4068



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182

denr.sd.gov

May 29, 2013

Redfield Press
PO Box 440
Redfield SD 57469

ATTENTION: Legal Public Notice

Enclosed is a Notice on Application Nos. 7717-3, 7718-3, 7720-3 and 7721-3 to Appropriate Water. Please publish the notice once on June 5, 2013. The text of the notice can be e-mailed to your paper by contacting Karen Schlaak at (605) 773-3352.

The applicant must verify to you that the notice is to be published and arrange for payment. **Please BILL the APPLICANT for the cost of publication.** The APPLICANT is Terry Wieting, 870 Beach Ave NE, Huron SD 57350 (Ph # 605-554-0207).

Please send the Water Rights Program an affidavit or the enclosed Proof of Publication form immediately.

The applicant pays the cost of publication, but the Water Rights Program records require an affidavit or Proof of Publication. Delays in receiving the affidavit can be costly to the applicant.

Sincerely,

Eric Gronlund
Natural Resources Engineer
605 773-3352

enclosures

Schlaak, Karen

From: Schlaak, Karen
Sent: Thursday, May 30, 2013 8:05 AM
To: 'office.redpress@midconetwork.com' (office.redpress@midconetwork.com)
Subject: FW: Five Notices for June 5th
Attachments: 7685-3public.wmb.docx; 7716-3public.wmb.docx; 7719-3public.wmb.docx; 7717-21-3pluralpublic.wmb.docx; 7722-24-3pluralpublic.wmb.docx

Attached are 5 notices to be published on June 5, 2013.

The applicants have been notified to authorize publication and arrange for payment.
No. 7685-3, Michael Watson, 18583 393th Ave, Hitchcock SD 57348 (605 350-1356)
Nos. 7717-3, 7718-3, 7720-3 and 7721-3, Terry Wieting, 870 Beach AVE NE, Huron SD (605 554-0207)

Please bill the Water Rights Program the cost of publication for these three notices:

No. 7716-3, Denis & Craig Slepikas
No. 7719-3, Marshall Brothers
Nos. 7722-3, 7723-3 and 7724-3, Brent/Leland Kleinsasser

If you have questions, please let me know.

Karen Schlaak
Water Rights Program
Phone: 605 773-3352
Fax: 605 773-4068



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182

denr.sd.gov

NOTE: TO BE SURE OF PUBLICATION ON
THE CORRECT DATE, CONTACT
THE NEWSPAPER(S) RIGHT AWAY.

May 29, 2013

Terry Wieting
870 Beach Ave NE
Huron SD 57350

Dear Mr. Wieting:

Water Permit Application Nos. 7717-3, 7718-3, 7720-3 and 7721-3 for irrigation use have been examined and found to comply with the South Dakota Water Laws and applicable rules. A notice has been sent to the Plainsman printed at Huron SD (Ph # 605-352-6401) and the Redfield Press printed at Redfield SD (Ph # 605-472-0822). You will need to contact the newspaper(s) and authorize publication of this notice. For your information, a copy of the notice, the recommendations of the Chief Engineer and reports on the applications are enclosed. Please review the notice prior to publication and notify this office, if you have any corrections or questions.

Be sure to contact the above newspaper(s) to authorize publication of your Notice and to arrange for payment. Early contact with the paper(s) can eliminate delays. Upon receiving authorization from you, the publisher has been instructed to publish your notice. The newspaper(s) has also been instructed to send us the Proof of Publication. We must receive Proof of Publication before action can be taken on the applications.

Sincerely,

Eric Gronlund
Natural Resources Engineer
(605) 773-3352

enclosures

NOTE: If you plan to contest any part of the Chief Engineer's recommendation, you must file a petition pursuant to the procedures outlined in the attached notice of hearing. The Water Management Board will then consider your concerns during a hearing on the applications.

Instruction to Newspaper – Publish the Notice on June 5, 2013. The applicant is responsible for payment. The text of the notice can be e-mailed to your paper by contacting Karen Schlaak at (605) 773-3352 or email: Karen.schlaak@state.sd.us.

NOTICE OF HEARING on Application Nos. 7717-3, 7718-3, 7720-3 and 7721-3 to Appropriate Water

Notice is given that Terry Wieting, 870 Beach Ave NE, Huron SD 57350 has filed an following applications for water permits.

Application No. 7717-3 proposes to appropriate 1.78 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the NE ¼ Section 10 for irrigation of 135 acres located in the NE 1/4 Section 10; all in T113N-R64W.

Application No. 7718-3 proposes to appropriate 1.78 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the SE ¼ Section 9 for irrigation of 135 acres located in the SE 1/4 Section 9; all in T113N-R64W.

Application No. 7720-3 proposes to appropriate 1.78 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the NE ¼ Section 25 for irrigation of 135 acres located in the NE 1/4 Section 25; all in T114N-R64W.

Application No. 7721-3 proposes to appropriate 1.33 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the SW ¼ Section 18 for irrigation of 100 acres located in the SW 1/4 Section 18; all in ~~T113N~~ ^{T114N} R63W.

SDCL 46-2A-4(10) provides that "if the applicant does not contest the recommendation of the Chief Engineer and no petition to oppose the application is received, the Chief Engineer shall act on the application pursuant to the Chief Engineer's recommendation and no hearing may be held before the board, unless the Chief Engineer makes a finding that an application, even if uncontested, presents important issues of public policy or public interest that should be heard by the board." In this case, the Chief Engineer finds that these applications presents important issues of public interest that should be heard by the Water Management Board.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application Nos. 7717-3, 7718-3, 7720-3 and 7721-3 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water, and 4) it is in the public interest.

The Water Management Board will consider these application at 3:00 p.m. on July 10, 2013 in the Matthew Training Center, Joe Foss Bldg, 523 E. Capitol Ave. Pierre SD. The Chief Engineer's recommendations are not final or binding upon the Board. The Board is authorized to 1) approve, 2) approve with qualifications; 3) defer, or 4) deny this application based on the facts presented at the public hearing.

Any interested person who intends to participate in the hearing shall file a petition to oppose or support these applications and the petition shall be filed with BOTH the applicant and Chief Engineer. The applicant must also file a petition if opposed to the Chief Engineer's recommendations. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by July 1, 2013. The petition may be informal, but shall be in writing and shall include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. The hearing is an adversary proceeding and any party has the right to be present at the hearing and to be represented by a lawyer. These and other due process rights will be forfeited if they are not exercised at the hearing and decisions of the Board may be appealed to the Circuit Court and State Supreme Court as provided by law.

The July 10, 2013 hearing date will be automatically delayed for at least 20 days upon written request to the Chief Engineer from the applicant or any person who has filed a petition to oppose or support the application. The request for an automatic delay must be filed by July 1, 2013. If an automatic delay is requested, the hearing will be rescheduled for a future Board meeting and personal notice will be provided to all petitioners regarding the time, date and location.

Contact Eric Gronlund by July 1, 2013 at the above Chief Engineer's address to request copies of the staff report, recommendation, application or other information. Notice is given to individuals with disabilities that this hearing is being held in a physically accessible place. Please notify the Department of Environment and Natural Resources at least 48 hours before the hearing if you have a disability for which special arrangements must be made at the hearing. The telephone number for making arrangements is (605) 773-3352.

Under SDCL 1-26-17(7) notices must state that "if the amount in controversy exceeds \$2,500.00 or if a property right may be terminated, any party to the contested case may require the agency to use the Office of Hearing Examiners by giving notice of the request to the agency no later than ten days after service of a notice of hearing issued pursuant to SDCL 1-26-17." This is a Notice of Hearing, service is being provided by publication, and the applicable date to give notice to the Chief Engineer is June 17, 2013. However, since this particular matter is a water permit application and not a monetary controversy in excess of \$2,500.00 or termination of a property right the Chief Engineer disputes the applicability of this provision and maintains that the hearing must be conducted by the Board.

As applicable, the following provides the legal authority and jurisdiction under which the hearing will be held and the particular statutes and rules pertaining to this application: SDCL 1-26-16 thru 1-26-28; SDCL 46-1-1 thru 46-1-9, 46-1-13 thru 46-1-16; 46-2-3.1, 46-2-9, 46-2-11, 46-2-17; 46-2A-1 thru 46-2A-12, 46-2A-14, 46-2A-15, 46-2A-20, 46-2A-21, 46-2A-23; 46-5-1.1, 46-5-2 thru 46-5-26, 46-5-30.2 thru 46-5-30.4, 46-5-31 46-5-32 thru 46-5-34.1, 46-5-38 thru 46-5-39, 46-5-46, 46-5-47, 46-5-49; 46-6-1 thru 46-6-3.1, 46-6-6.1, 46-6-10, 46-6-13, 46-6-14, 46-6-21, 46-6-26; and Board Rules ARSD 74:02:01:01 thru 74:02:01:25.02; 74:02:01:35.01.

Steven M. Pirner, Secretary, Department of Environment and Natural Resources. Published once at an approximate cost of _____.

Schlaak, Karen

From: Gronlund, Eric
Sent: Wednesday, June 05, 2013 2:48 PM
To: Schlaak, Karen
Cc: twieting@venturecomm.net
Subject: Application No. 7721-3, Terry Wieting
Attachments: 7717-21-3pluralpublic.wmb.docx

Received a call from a gentleman wondering if the legal notice for Application No. 7721-3 was correct because the description in the Huron Plainsman was for the SW ¼ Section 18, T113N, R63W which is property his son farms. I said it should be T114N.

This is an correction I made with the newspapers last Friday. I received confirmation of the amended notice from the Redfield Press but not the Huron Plainsman. Anyway, the publication notice for No. 7721-3 will need to be readvertised for the correct Township designation in I presume only the Huron Plainsman.

I contacted Terry and let him know what occurred.

Karen – I will but the file in your in-basket.

Eric

From: Gronlund, Eric
Sent: Friday, May 31, 2013 2:47 PM
To: office.redpress@midconetwork.com; 'renewman.plainsman@midconetwork.com'; twieting@venturecomm.net
Cc: Schlaak, Karen
Subject: amend public notice for Terry Wieting's water permit applications

Redfield Press, The Plainsman and Mr. Wieting:

Please find the amended notice for Mr. Wieting's water permit applications set to be published on June 5th.

The correction is in the township designation on Application No. 7721-3 from T113N to **T114N**.

Thanks

Eric Gronlund
Water Rights Program, DENR
605 773-3352
Eric.gronlund@state.sd.us

Schlaak, Karen

From: Ruby Crandall <rnewman.plainsman@midconetwork.com>
Sent: Friday, June 07, 2013 10:43 AM
To: Schlaak, Karen
Subject: Re: No. 7721-3, Terry Wieting

I have received your email.
Thank you.

Ruby (Newman) Crandall
Creative Services Supervisor

Plainsman/Payday/Print Shop
49 3rd Street SE
Huron, SD 57350

605-353-7412

1-800-859-3045, ext. 412

fax: 605-353-7422

rnewman.plainsman@midconetwork.com

On Jun 7, 2013, at 10:15 AM, Schlaak, Karen wrote:

Attached is a Notice of Hearing on Application No. 7721-3, Terry Wieting to be published June 12, 2013.

Please the Water Rights Program for the cost of publication.

Karen Schlaak

Water Rights Program

Phone: 605 773-3352

Fax: 605 773-4068

<7721-3pluralpublic.wmb.docx>

NOTICE OF HEARING on Application No. 7721-3 to Appropriate Water

Notice is given that Terry Wieting, 870 Beach Ave NE, Huron SD 57350 has filed Application No. 7721-3 to appropriate 1.33 cubic feet of water per second from one well to be completed into the Tulare:Western Spink Hitchcock Aquifer (70 feet deep) located in the approximate center of the SW ¼ Section 18 for irrigation of 100 acres located in the SW 1/4 Section 18; all in T114N-R63W.

SDCL 46-2A-4(10) provides that “if the applicant does not contest the recommendation of the Chief Engineer and no petition to oppose the application is received, the Chief Engineer shall act on the application pursuant to the Chief Engineer’s recommendation and no hearing may be held before the board, unless the Chief Engineer makes a finding that an application, even if uncontested, presents important issues of public policy or public interest that should be heard by the board.” In this case, the Chief Engineer finds that these applications presents important issues of public interest that should be heard by the Water Management Board.

Pursuant to SDCL 46-2A-2, the Chief Engineer recommends APPROVAL of Application No. 7721-3 because 1) unappropriated water is available, 2) existing rights will not be unlawfully impaired, 3) it is a beneficial use of water, and 4) it is in the public interest.

The Water Management Board will consider the application at 3:00 p.m. on July 10, 2013 in the Matthew Training Center, Joe Foss Bldg, 523 E. Capitol Ave. Pierre SD. The Chief Engineer's recommendation is not final or binding upon the Board. The Board is authorized to 1) approve, 2) approve with qualifications, 3) defer, or 4) deny this application based on the facts presented at the public hearing.

Any interested person who intends to participate in the hearing shall file a petition to oppose or support the application and the petition shall be filed with BOTH the applicant and Chief Engineer. The applicant must also file a petition if opposed to the Chief Engineer's recommendation. The Chief Engineer's address is "Water Rights Program, Foss Building, 523 E Capitol, Pierre SD 57501 (605 773-3352)" and the applicant's mailing address is given above. A petition filed by either an interested person or the applicant must be filed by July 1, 2013. The petition may be informal, but shall be in writing and shall include a statement describing the petitioner's interest in the application, the petitioner's reasons for opposing or supporting the application, and the signature and mailing address of the petitioner or the petitioner's legal counsel, if legal counsel is obtained. The hearing is an adversary proceeding and any party has the right to be present at the hearing and to be represented by a lawyer. These and other due process rights will be forfeited if they are not exercised at the hearing and decisions of the Board may be appealed to the Circuit Court and State Supreme Court as provided by law.

The July 10, 2013 hearing date will be automatically delayed for at least 20 days upon written request to the Chief Engineer from the applicant or any person who has filed a petition to oppose or support the application. The request for an automatic delay must be filed by July 1, 2013. If an automatic delay is requested, the hearing will be rescheduled for a future Board meeting and personal notice will be provided to all petitioners regarding the time, date and location.

Contact Eric Gronlund by July 1, 2013 at the above Chief Engineer’s address to request copies of the staff report, recommendation, application or other information. Notice is given to individuals with disabilities that this hearing is being held in a physically accessible place. Please notify the Department of Environment and Natural Resources at least 48 hours before the hearing if you have a disability for which special arrangements must be made at the hearing. The telephone number for making arrangements is (605) 773-3352.

Under SDCL 1-26-17(7) notices must state that “if the amount in controversy exceeds \$2,500.00 or if a property right may be terminated, any party to the contested case may require the agency to use the Office of Hearing Examiners by giving notice of the request to the agency no later than ten days after service of a notice of hearing

issued pursuant to SDCL 1-26-17.” This is a Notice of Hearing, service is being provided by publication, and the applicable date to give notice to the Chief Engineer is June 17, 2013. However, since this particular matter is a water permit application and not a monetary controversy in excess of \$2,500.00 or termination of a property right the Chief Engineer disputes the applicability of this provision and maintains that the hearing must be conducted by the Board.

As applicable, the following provides the legal authority and jurisdiction under which the hearing will be held and the particular statutes and rules pertaining to this application: SDCL 1-26-16 thru 1-26-28; SDCL 46-1-1 thru 46-1-9, 46-1-13 thru 46-1-16; 46-2-3.1, 46-2-9, 46-2-11, 46-2-17; 46-2A-1 thru 46-2A-12, 46-2A-14, 46-2A-15, 46-2A-20, 46-2A-21, 46-2A-23; 46-5-1.1, 46-5-2 thru 46-5-26, 46-5-30.2 thru 46-5-30.4, 46-5-31 46-5-32 thru 46-5-34.1, 46-5-38 thru 46-5-39, 46-5-46, 46-5-47, 46-5-49; 46-6-1 thru 46-6-3.1, 46-6-6.1, 46-6-10, 46-6-13, 46-6-14, 46-6-21, 46-6-26; and Board Rules ARSD 74:02:01:01 thru 74:02:01:25.02; 74:02:01:35.01.

Steven M. Pirner, Secretary, Department of Environment and Natural Resources. Published once at an approximate cost of _____.

July 1, 2013

PAYMENT REQUEST FORM

PAYEE: Plainsman
PO Box 1278
Huron SD 57350

FROM: DENR Water Rights Program
523 E. Capitol Ave
Pierre, SD 57501-3181

DESCRIPTION OF SERVICE, PRODUCE OR TRANSFER

Pub Notice for 7721-3 (T Weiting) # 818

AMOUNT: \$74.33

FUNDING SOURCE:

GENERAL: X

FEDERAL:

COMMENTS:

AUTHORIZATION:

Gail Jackson 7-1-13

I declare and affirm under the penalties of perjury that this claim is in all things, true and correct. I further agree to comply with the provisions of the Civil Rights Act of 1964 and regulations issued thereunder relating to nondiscrimination in federal assisted programs.



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

PMB 2020
JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182

denr.sd.gov

AUG 29 2013

Terry Wieting
870 Beach Ave
Huron SD 57350

Dear Mr. Wieting:

Enclosed are Water Permit Nos. 7717-3, 7718-3, 7720-3 and 7721-3 authorizing construction of your water diversion systems and beneficial use of the water, not exceeding the limits as specified in the Water Permits.

Form 10's, *Notice of Completion of Works and Application of Water to Beneficial Use*, are enclosed. Please return the completed forms after you have finished the systems and have put the water to beneficial use. An investigation can then be scheduled so the water licenses may be issued, thus completing the acquisition of a water right.

An informational sheet ? *Common Water Right Questions?* is also enclosed. This sheet is intended to answer some of the questions associated with obtaining and keeping a water right.

Sincerely,

Jeanne Goodman, Chief Engineer
Water Rights Program
(605) 773-3352

enclosures

NOTICE OF TRANSFER OF OWNERSHIP

RECEIVED
APR 29 2015
WATER RIGHTS
PROGRAM

To: Chief Engineer
Water Rights Program, DENR
523 E. Capitol
Pierre, SD 57501-3181

No. 7721-3

Date: 4-29-15

I/We request that Water Permit No. 7721-3

formerly owned by: Terry Wieting

be transferred to: (name & address) Gary Marshall, 19032 388th Avenue, Hitchcock SD 57348

Telephone No. 605 350-1401

Title to the following described land(s)/property has been transferred as described above:

100 acres – SW ¼ Section 18, T114N, R63W

I/We understand that the validity of Water Permit No. 7721-3 has not been determined by this transfer action. If I/We have any questions on validity, I/We understand that only the Water Management Board has the authority to determine if a water permit/right is valid (see note).

You are requested to file this "Notice of Transfer" in the appropriate file with the Water Rights Program, as evidence of the change of ownership.

A fee of Fifty Dollars (\$50.00) is required to cover the filing fees as required under SDCL 46-2-13. This form must be signed by the new owner.

I/We Gary Marshall, the new owner, certify that the above information is true and correct.

Gary Marshall
(Signed by new owner)

NOTE: Water permits may be cancelled for nonconstruction after the five year construction period has expired. Once a water permit is developed and the water used, the permit becomes a right. A water right may be lost for three reasons:

1. Abandonment - no intent to use water and use is abandoned.
2. Forfeiture - no use of water for three year period without legal excuse.
3. For a third violation of a condition of a water permit/right.

RECEIPT

WATER RIGHTS PROGRAM

South Dakota Department of Environment and Natural Resources

Date 4/29, 20 15


RECEIVED OF Gary Marshall 19032 388th Ave Hitchcock SD 57348

The following amount in fees for services rendered as provided for by law:

Fee for Application for Permit No. _____ to Appropriate Water, to construct and to put water to beneficial use	50	00
Fee for Application for Permit No. _____ to Appropriate Water for Future use		
Fee to retain Future Use Permit No. _____ after period of seven years.		
Fee for Inspecting Constructed Works, confirming beneficial use and issuing Water License No. _____		
Fee for Filing Transfer Form <u>7721-3</u>		
Fee for _____		
Fee for Issuing New Well Driller's License No. _____ for C.Y. _____		
Fee for Renewal of Well Driller's License No. _____ for C.Y. _____		
Fee for Issuing Well Pump Installer's License No. _____ for C.Y. _____		
Fee for Renewal of Well Pump Installer's License No. _____ for C.Y. _____		
(Any Other Work Provided by Law)	TOTAL	50 00

No. 07371

By


Chief Engineer



DEPARTMENT of ENVIRONMENT
and NATURAL RESOURCES

JOE FOSS BUILDING
523 EAST CAPITOL
PIERRE, SOUTH DAKOTA 57501-3182

denr.sd.gov

May 7, 2015

Gary Marshall
19032 388th Ave
Hitchcock SD 57348

RE: 7721-3, 7720-3, 7719-3, 7640-3, 7639-3, 7638-3, 7637-3, 7575B-3, 7573-3, 7126A-3,
4794-3, 4723-3A, 3054A-3

Dear Mr. Marshall:

I am writing in follow-up to your office visit last week when you submitted ownership changes to the above listed water permits and water rights.

All of the ownership changes with the exception of Water Permit No. 7575B-3 have been completed. The ownership change submitted for portions of Water Permit No. 7575-3 is being processed separately. This is done in part because the permit will need to be divided and reissued to reflect separate ownership (No. 7575A-3 - Terry Marshall and No. 7575B-3 - Gary Marshall).

The receipts for the filing fees are enclosed. If you have any questions, please let me know.

Sincerely,

Genny McMath
Water Rights Program
(605) 773-3352
email: genny.mcmath@state.sd.us

enclosures – receipts for the filing fees

SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

7721-3

Location NE 1/4 SW 1/4 Sec 18 Twp 114 N Rg 63W

County SPINK

North

Please mark well location with an "X"

Well completion Date 12-11-15

1 Mile

Well Owner: Gary Marshall

Business Name: _____

Address1: 19032 388 AVE

Address2: _____

City, State, Zip: HITCHCOCK, SD 57348

WELL LOG:

FORMATION	DEPTH	
	FROM	TO
Top Soil	0	1
Yellow Sand	1	5
Yellow Clay	5	11
Yellow Sand	11	19
Yellow Clay	19	26
Blue Clay Till	26	54
Fine Sand	54	74
Medium Sand	74	86
Medium to Coarse Sand	86	100

Distance from nearest potential pollution source (Septic tank, abandoned well, feed lot, etc.)
2000 ft. from Farm yard (identify source)

PROPOSED USE:

☐ Domestic Stock ☐ Municipal ☐ Business ☐ Test Holes

☒ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING: Forward Rotary

CASING DATA: ☐ Steel ☒ Plastic ☐ Other

If other describe _____

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
50 LB/FT	12 IN	4 FT	85 FT	17.5 IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type Portland Cement No. of Sacks 11 Grout Weight 9.6 Lb/gal From 0 FT To 50 FT

Describe grouting procedure Remmie Line from 50' to surface

SCREEN: ☐ Perforated pipe ☒ Manufactured

Diameter 12 Inches Length 15 Feet

Material stainless steel

Slot Size .060 Set From 85 Feet to 100 Feet

Other information Gravel packed with Red Flint #60 Slot

WAS A PACKER OR SEAL USED? ☐ Yes ☒ No

If so, what material? _____

Describe packer(s) and location _____

DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? chlorine

Lab sample sent to for water quality analysis ☐ No, Why Not? _____

STATIC WATER LEVEL 37 FEET

If flowing, closed in pressure _____ PSI

GPM flow _____ through _____ inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other _____

Reduced flow rate _____ GPM

Can well be completely shut in? _____

WELL TEST DATA:

☒ Pumped Describe: Air

☐ Bailed _____

☐ Other _____

Pumping Level Below Land Surface

_____ Ft. After _____ Hrs. pumped _____ GPM

_____ Ft. After _____ Hrs. pumped _____ GPM

If pump installed, pump rate: _____ GPM

REMARKS Blue clay after 100'

TULARE: Western Spink/Hitchcock

This well was drilled under license # 285

And this report is true and accurate.

Drilling firm: Mani Kowski Well Drilling, Inc

Signature of License Representative: [Signature]

Signature of Well Owner or Equitable Property Holder: _____

Date: 12-12-15

523 E. Capitol Ave., Pierre SD 57501

Please return White Copy to DENR Water Rights


RECEIVED
 DEC 17 2015
 WATER RIGHTS PROGRAM

SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location SW 1/4 SW 1/4 Sec 18 Twp 114 Rg 63County Spink

Please mark well location with an "X"



Well Completion Date

3-30-18

1 Mile

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?

1800 ft. from Feed lot

(identify source)

PROPOSED USE:

☐ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes
☒ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

METHOD OF DRILLING:

Forward Rotary

CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
SDR 21 LB/FT	12 IN	+2 FT	59 FT	17 1/2 IN
LB/FT	IN	FT	FT	IN
LB/FT	IN	FT	FT	IN

GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>Leak-tite</u>	10	9.5 Lb/gal	1 Ft	50 Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

Tremie line pumping from 50' To Surface

SCREEN:

☐ Perforated pipe ☒ Manufactured
 Diameter 12 inches Length 20 Feet
 Material stainless steel
 Slot Size .040 Set From 59 Feet to 79 Feet

Other information

WAS A PACKER OR SEAL USED?

☐ Yes ☒ No

If so, what material?

Describe packer(s) and location

DISINFECTION:

Was well disinfected upon completion?

☒ Yes, How? chlorine
☐ No, Why Not?

Lab to which water

quality sample sent for analysis

Well Owner: Gary Marshall

Business Name:

Address:

City, State, Zip:

870 Beach Ave NEHuron, SD 57350

WELL LOG:

DEPTH

FORMATION

FROM

TO

<u>Top Soil</u>		
<u>Yellow clay</u>	<u>0</u>	<u>9</u>
<u>Fine</u>	<u>8</u>	<u>8</u>
<u>Rock</u>	<u>9</u>	<u>10</u>
<u>Yellow clay</u>	<u>10</u>	<u>16</u>
<u>Blue clay with fine sand</u>	<u>16</u>	<u>50</u>
<u>Medium sand</u>	<u>50</u>	<u>70</u>
<u>Coarse sand</u>	<u>70</u>	<u>75</u>
<u>Coarse to Med Gravel</u>	<u>75</u>	<u>78</u>

STATIC WATER LEVEL

18.9

FEET

If flowing: closed in pressure

PSI

GPM flow

through

Inch pipe

Controlled by

☐ Valve☐ Reducers☐ Other

Reduced flow rate

GPM

Can well be completely shut in?

WELL TEST DATA:

☒ Pumped Describe:☐ Bailed☐ Other

Pumping Level Below Land Surface

39FL. After 1

Hrs. pumped

900

GPM

Ft. After

Hrs. pumped

GPM

If pump installed, pump rate:

GPM

REMARKS

Well by west Pond

This well was drilled under license #

285

and this

report is true and accurate.

Drilling firm:

Manikowski Well Drilling, Inc

Signature of License Representative:

[Signature]

Signature of Well Owner or Equitable Property Holder:

[Signature]

Date:

RECEIVED

APR 06 2018

WATER RIGHTS PROGRAM

**Report of Examination of Works and/or Application of Water to Beneficial Use
For License No. 3054A-3 & Permit Nos. 7721-3, 7638-3, & 7126A-3**

I have this day, June 27, 2024, made a thorough examination of the water use system constructed by Gary Marshall of 870 Beach Ave NE, Huron SD 57350 holder of License No. 3054A-3, bearing the priority of September 14, 1976 authorizing the diversion of 1.21 cu. ft. per second; Permit No. 7126A-3, bearing the priority of September 14, 1976 authorizing the diversion of 0.00 cu. ft. per second; Permit No. 7638-3, bearing the priority of December 19, 2012 authorizing the diversion of 1.78 cu. ft. per second; Permit No. 7721-3, bearing the priority of February 8, 2013 authorizing the diversion of 1.33 cu. ft. per second of the waters of groundwater Tulare: Western Spink Hancock Aquifer for irrigation purposes, in Spink County.

Inspection contact & relationship Terry Weiting, operator

A. Works used to divert the water:

Well Information: Well #1 - NE

- 1) Well Drilling Firm: Gosch Irrigation
- 2) No. of Wells 1
- 3) Depth(s) 95 feet
- 4) Well log is available Y If no, explain in comments

Casing:

- 1) Diameter 16 inches
- 2) Length 49 feet
- 3) Type concrete

Screen:

- 1) Type concrete
- 2) Length 52 feet
- 3) Static water level 44 feet

Pump:

- 1) Make Western Land Roller
- 2) Model E77660
- 3) Size 8M
- 4) Capacity 600 GPM

Motor:

- 1) Make GE
- 2) Model No. GNJ713361
- 3) Horsepower rating 40 hp

Well Information: Well #2 - Middle

- 1) Well Drilling Firm: Manikowski Well Drilling Inc
- 2) No. of Wells 1
- 3) Depth(s) 100 feet
- 4) Well log is available Y If no, explain in comments

Casing:

- 1) Diameter 12 inches
- 2) Length 85 feet
- 3) Type plastic

Screen:

- 4) Type stainless steel
- 5) Length 15 feet
- 6) Static water level 37 feet

Pump:

- 1) Make Grundfos
- 2) Model submersible
- 3) Capacity 600 GPM

Motor:

- 4) Make Grundfos
- 5) Model No. submersible

Well Information: Well #3 - West

- 1) Well Drilling Firm: Manikowski Well Drilling Inc
- 2) No. of Wells 1
- 3) Depth(s) 100 feet
- 4) Well log is available Y If no, explain in comments

Casing:

- 4) Diameter 12 inches
- 5) Length 85 feet
- 6) Type plastic

Screen:

- 7) Type stainless steel
- 8) Length 15 feet
- 9) Static water level 37 feet

Pump:

- 4) Make Grundfos
- 5) Model submersible
- 6) Capacity 600 GPM

Motor:

- 5) Make Grundfos
- 6) Model No. submersible

C. Works used to apply water to beneficial use:

Center pivot: NE 1/4

- 1) Make Zimmatic
- 2) Overall length 1280 feet
- 3) Number of towers 7
- 4) End gun Y
- 5) Capacity 600 GPM

Center pivot: SE 1/4

- 6) Make Valley
- 7) Overall length 1280 feet
- 8) Number of towers 7
- 9) End gun Y
- 10) Capacity 600 GPM

Center pivot: SW 1/4

- 11) Make Zimmatic
- 12) Overall length 1280 feet
- 13) Number of towers 7
- 14) End gun Y
- 15) Capacity 600 GPM

Chemigation Equipment:

- 1) Does chemigate Y
- 2) Main line check valve Y
- 3) Inspection port/air relief Y
- 4) Low pressure drain Y
- 5) Discharge is 20' from source Y
- 6) Interlock type electrical
- 7) Injection pump type piston
- 8) Injection check valve Y
- 9) Injection line check valve or positive displacement pump Y

Comments: none

D. Compliance with Permit Requirements:

- 1) Permit qualifications being abided by Y
- 2) Irrigation Questionnaires checked to determine if permit owner started irrigation by the end of construction period Y
List any extended period of nonuse: none
- 3) Exceptions to compliance are: none

E. Condition and Location:

1. The system is in good condition with the point(s) of diversion located as follows: from the SE corner of Sec 18 T114N-R63W: Well #1 1030 ft W and 4000 ft N, latitude of 44.68740 and longitude of -98.44670 , NE ¼ NE ¼; Well #2 3240 ft W and 2010 ft N, latitude of 44.68195 and longitude of -98.45540 , NE ¼ SW ¼ ; Well #3 4815 ft W and 1850 ft N, latitude of 44.68166 and longitude of -98.46155, NW ¼ SW ¼
2. The works are capable of diverting and conveying to the place of use 4.01 cu. ft. per second of water which is to be used for irrigation. Water has been put to beneficial use to the maximum extent as follows: All land is located in Sec 18 T114N-R63W
NW ¼ NE ¼ - 32.5 ac NE ¼ NE ¼ - 32.5 ac SE ¼ NE ¼ - 32.5 ac SW ¼ NE ¼ - 32.5 ac
NW ¼ SE ¼ - 33.5 ac NE ¼ SE ¼ - 33.5 ac SE ¼ SE ¼ - 33.5 ac SW ¼ SE ¼ - 33.5 ac
NW ¼ SW ¼ - 26.5 ac NE ¼ SW ¼ - 33.5 ac SE ¼ SW ¼ - 18 ac SW ¼ SW ¼ - 2 ac
comprising a total of 344 acres of land and the license should be issued for 4.01 cfs.
3. All structures, wells and lands on map Y
If no, describe: none

F. Comments or other permit(s) associated with the project:

The distribution pipeline connects the three wells to the three pivots, water flow to each pivot is controlled by valves.

Water pumped from the pond (authorized by Permit No. 8215-3) can be blended with well water to supply the pivots.



Mark D Rath
Water Rights Inspector
DANR, Water Rights Program

Date report completed: 07/17/2024

Spink County
SCHEDULED
3054A-3

NOTICE OF WELL CONSTRUCTION

(1) WELL CONSTRUCTION

Location of well: NE 1/4 1/4 Section 18 Township Belmont Range R6341
Well owner Walbert Howell Hitchcock S.D.
Date well drilling completed 8-21-77 Purpose of well irrigation
(domestic, irrigation, municipal, industrial, other)

WELL LOG

Layers, top to top in feet	Description of layer	Depth to top of water producing aquifer	ft.
0-5	top sand	Depth to static water level	ft.
5-23	clay	Name of producing aquifer (if known)	
23-25	reworked gravel	Total depth of drill hole	95'
25-53	blue clay	Depth to bottom of casing	89'
53-90	medium blue sand with clay layers	Casing information: In the space below show kind, size, weight, lengths per diameter, etc., for production casing and surface casing, if used.	
90-95	clay	Concrete	16" X 48" X 2 1/2" wall 640#
Attach sheet if more space is needed		0-51 Plain 51-90 Screen 90-91 Plug	
		Screen information: In the space below show length of screen below bottom of casing, diameter and kind of screen or casing perforations.	
		Concrete 16" X 48" X 2 1/2" wall 640#	
		1/8" outside taper to 3/8" inside by 3"	
		120 open spaces per 48"	
		If a flowing well, flow of completed well	

Shoach Irrigation
Name of Drilling Contractor

(2) PUMP INSTALLATION

Company name and size of pump _____ HP _____
Type of pump _____ Capacity of installed pump _____ G.P.M.
Depth of pump placement _____ ft., Date of pump installation _____

(3) WATER SURFACE MEASURING TUBE

On some wells an air-tight water surface measuring tube is required: See Section 46.408 of Chapter 46.4, MINIMUM WELL CONSTRUCTION STANDARDS.

Show exact vertical length of water surface measuring tube, when installed _____ ft., tube diameter _____, tube material _____

Name of Pump Installation Contractor

Approval of Location Change and/or Additional Diversion Point(s)

NAME: Gary Marshall

COUNTY: Spink

ADDRESS: 870 Beach Ave NE, Huron SD 57350

DATE: July 18, 2024

GENERAL DESCRIPTION OF AUTHORIZED PROJECT:

Gary Marshall held Water Right No. 3054A-3 and Permit Nos. 7126A-3, 7638-3, and 7721-3, all of which are being incorporated into License No. 7721-3.

WR No. 3054A-3 authorized construction of one well, completed into the T:WS-H in the SE $\frac{1}{4}$ NE $\frac{1}{4}$ Section 18, T114N, R63W for the irrigation of 85 acres, at a maximum rate of 1.21 cfs.

WP No. 7638-3 authorized the construction of one well, completed into the T:WS-H in the approx. center SE $\frac{1}{4}$ Section 18, T114N, R63W for the irrigation of 135 acres, at a maximum rate of 1.78 cfs.

WP No. 7721-3 authorized the construction of one well, completed into the T:WS-H in the approx. center SW $\frac{1}{4}$ Section 18, T114N, R63W for the irrigation of 100 acres, at a maximum rate of 1.33 cfs.

AUTHORITY:

Pursuant to SDCL 46-5-13.1, the location of a diversion point may be changed, or additional diversion points may be added, provided the following conditions are met and the potential for interference with other existing diversions is not increased:

Developed water source same as permitted source and no additional water appropriated

The well authorized by WR No. 3054A-3 (Well #1) was drilled in the NE $\frac{1}{4}$ NE $\frac{1}{4}$, the well authorized by WP No. 7638-3 (Well #2) was drilled in the NE $\frac{1}{4}$ SW $\frac{1}{4}$, and the well authorized by WP No. 7721-3 (Well #3) was drilled in the NW $\frac{1}{4}$ SW $\frac{1}{4}$; all in Section 18, T114N, R63W. All three wells were completed into the T:WS-H Aquifer. The combined maximum diversion rate authorized was 4.32 cfs. The system as developed, only diverts 4.01 cfs.

If irrigation, no new land is irrigated

WR No. 3054A-3 and WP Nos. 7126A-3, 7638-3, & 7721-3 authorized the combined irrigation of 365 acres. The system, as developed, only irrigates a combined total of 344 acres.

Review of Existing Diversions

There are four existing water permit/right located within 2 miles of where Mr. Marshall's wells were developed, also authorizing diversion from the T:WS-H Aquifer. The nearest of which is approximately 0.5 miles NW, held by Lee Gatzke (7291-3). It was determined during the review of Permit Nos. 7638-3 & 7721-3 that there was a reasonable probability any well interference due to pumping would not adversely or unlawfully impair existing rights. The same would be expected for the Wells 1, 2, and 3, as developed. No complaints have ever been filed in regard to Section 18, T114N, R63W.

There is one domestic wells in Section 18, T114N, R63W, on property owned by Mr. Marshall. The next nearest domestic well is located in Section 19, T114N, R63W, on property owned by Randy or Russel Cole, according to the Spink County plat book. The location of the domestic wells in the well completion report database maintained by the Water Rights Program is based on the location listed by the driller on the well completion report.

RECOMMENDED ACTION

Based on the above criteria, it is recommended that wells developed for irrigation under Water Right No. 3054A-3 and Permit Nos. 7638-3 & 7721-3, be licensed as developed, and incorporated with Permit No. 7126A-3 into License No. 7721-3.




Amanda Dewell, Permitting Administrator
Water Rights Program

The Chief Engineer makes a finding pursuant SDCL 46-5-13.1 and ARSD 74:02:01:14.01 that:
This change in locations and/or additional diversion point(s) does not increase the potential for adverse effects to existing diversions.



Eric Gronlund, Chief Engineer
Water Rights Program



Diversion Point Location

From the SE corner of
Sec 18 T114N-R63W

**** Well #1****

1030 ft W & 4000 ft N

Lat 44.68740 Long -98.44670

**** Well #2****

3240 ft W & 2010 ft N

Lat 44.68195 Long -98.45540

**** Well #3****

4815 ft W & 1850 ft N

Lat 44.68166 Long -98.46155

**** Pond Pump****

4960 ft W & 1840 ft N

Lat 44.68161 Long -98.46207

Irrigated Land

Sec 18 T114N-R63W

NW1/4 NE 1/4 - 32.5 ac

NE 1/4 NE 1/4 - 32.5 ac

SE1/4 NE 1/4 - 32.5 ac

SW1/4 NE 1/4 - 32.5 ac

NW1/4 SE 1/4 - 33.5 ac

NE 1/4 SE 1/4 - 33.5 ac

SE1/4 SE 1/4 - 33.5 ac

SW1/4 SE 1/4 - 33.5 ac


NW1/4 SW 1/4 - 26.5 ac

NE 1/4 SW 1/4 - 33.5 ac

SE1/4 SW 1/4 - 18 ac

SW1/4 SW 1/4 - 2 ac

TOTAL: 344 acres





**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 E CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

JUL 3 2 2024

7712-3
8215-3

Gary Marshall
870 Beach Ave NE
Huron SD 57350

Dear Mr. Marshall:

Enclosed are Water License Nos. 7712-3 & 8215-3. These are the final water right documents completing your process of obtaining Water Rights. Included with your licenses is a map prepared by the staff engineer who conducted the field investigation.

For your information SDCL 46-6-27 requires that if in the future, the owner of an existing well, constructs a replacement well and does not plan to use the old well, the old well is considered abandoned and must be plugged. Also, any well that is being used or is not considered abandoned must be valved and controlled, if flowing, or sealed and capped so that no leaking occurs either underground or at the surface.

So long as you use the water beneficially, as stated in the Water License, State Water Laws provide that you have a continuing right to use the water. If you have any questions, please contact our office.

Sincerely,

Eric Gronlund, Chief Engineer
Water Rights Program
(605) 773-3352

NOTES: The applicable portions of Water Right No. 3054A-3 and Water Permit Nos. 7126A-3 & 7638-3 have been incorporated into Water Right No. 7721-3.

Water Right Nos. 7721-3 & 8215-3 authorize irrigation of the same acres; one from groundwater (Tulare: Western Spink Hitchcock Aquifer), and one from surface water collected in the storage pond. The wells may not be used to supplement water levels in the storage pond.

enclosures

STATE OF SOUTH DAKOTA
WATER LICENSE NO. 7721-3

(1) Water Right No. 3054A-3, held by Gary Marshall, 870 Beach Ave NE, Huron SD 57350, authorized the diversion of 1.33 cubic feet of water per second (cfs) from groundwater, one well (Tulare: Western Spink Hitchcock Aquifer) for the irrigation of 85 acres.

The applicable portions of Water Right No. 3054A-3 have been incorporated into this license.

Marshall Brothers made Application No. 7126A-3, July 24, 2012, for a water permit to transfer 45 irrigated acres, authorized under Permit No. 7126-3, to a new location in Spink County. Permit No. 7126A-3, with a priority date of September 14, 1976 (established under 7126-3), was approved October 9, 2012, and issued to the applicant for diversion of water with construction of the described water supply system to be completed on or before October 9, 2017, and for the application to beneficial use of water on or before October 9, 2021.

Ownership of Water Permit No. 7126A-3 was transferred to Gary Marshall on April 29, 2015. The applicable portions of Permit No. 7126A-3 have been incorporated into this license.

Gary Marshall made Application No. 7638-3, December 19, 2012, for a water permit to divert 1.78 cubic feet of water per second from groundwater, one well (Tulare: Western Spink Hitchcock Aquifer), Spink County, South Dakota for irrigation purposes. Permit No. 7638-3, with a priority date of December 19, 2012, was approved by the Water Management Board May 2, 2013, and issued to the applicant for diversion of water with construction of the described water supply system to be completed on or before May 2, 2018, and for the application to beneficial use of water on or before May 2, 2022.

The applicable portions of Permit No. 7638-3 have been incorporated into this license.

Terry Wieting made Application No. 7721-3, February 8, 2013, for a water permit to divert 1.33 cubic feet of water per second from groundwater, one well (Tulare: Western Spink Hitchcock Aquifer), Spink County, South Dakota for irrigation purposes. Permit No. 7721-3, with a priority date of February 8, 2013, was approved by the Water Management Board July 11, 2013, and issued to the applicant for diversion of water with construction of the described water supply system to be completed on or before July 11, 2018, and for the application to beneficial use of water on or before July 11, 2022.

Ownership of Water Permit No. 7721-3 was transferred to Gary Marshall on April 29, 2015.

An investigation conducted for licensing purposes found the diversion points, authorized by Water Right No. 3054A-3 and Water Permit Nos. 7638-3 & 7721-3, developed outside of the permitted area. Pursuant to SDCL 46-5-13.1 and ARSD 74:02:01:14.01, the Chief Engineer made a finding that the change in the diversion point locations did not increase the potential for adverse effects to existing diversions.

(2) It is certified that the permit holder has complied with the provisions of South Dakota State Law relating to completion of the construction of the water supply system and is entitled to divert 4.01 cubic feet of water per second for beneficial use. The locations of the diversion points are:

- Well #1: 1,030 ft W & 4,000 ft N of the SE corner Section 18, T114N, R63W (NE ¼ NE ¼)
(Latitude 44.68740 & Longitude -98.44670)
- Well #2: 3,240 ft W & 2,010 ft N of the SE corner Section 18, T114N, R63W (NE ¼ SW ¼)
(Latitude 44.68195 & Longitude -98.45540)
- Well #3: 4,960 ft W & 1,840 ft N of the SE corner Section 18, T114N, R63W (NW ¼ SW ¼)
(Latitude 44.68161 & Longitude -98.46207)

continued

(3) The amount of appropriation may not exceed 2 acre-feet annually for each acre of land to which water is actually and beneficially applied for irrigation. The water is to be used during the following described annual period: April 1 – October 31.

(4) The permit holder has complied with the provisions of South Dakota State Law relating to the application of water to beneficial use to irrigate to following land:

Section 18, T114N, R63W			
NE ¼ NE ¼	32.5 acres	NE ¼ SW ¼	33.5 acres
NW ¼ NE ¼	32.5 acres	NW ¼ SW ¼	26.5 acres
SW ¼ NE ¼	32.5 acres	SW ¼ SW ¼	2 acres
SE ¼ NE1/4	32.5 acres	SE ¼ SW ¼	18 acres
	NE ¼ SE ¼	33.5 acres	
	NW ¼ SE ¼	33.5 acres	
	SW ¼ SE ¼	33.5 acres	
	SE ¼ SE ¼	33.5 acres	
TOTAL: 344 acres			

(5) Pursuant to South Dakota Water Law 46-5-30.1 Gary Marshall, the holder and/or owner of Water Right No. 7721-3 is issued a license to appropriate water, the right to use 4.01 cubic feet of water per second from groundwater, three wells (Tulare: Western Spink Hitchcock Aquifer), with a priority dates outlined in the chart below, from the locations specified in (2) of this license for irrigation purposes.

Priority Dates	Diversion Rates	Irrigated Acres (all in Section 18, T114N, R63W)
September 14, 1976	1.21 cfs	130 acres located in the NE ¼
December 19, 2012	1.78 cfs	134 acres located in the SE ¼
February 8, 2013	1.02 cfs	80 acres located in the SW ¼

This license is subject to South Dakota Water Law, any limitations or conditions listed in Water Right No. 7721-3 and subject to the following qualifications:

1. The wells approved under this Permit will be located near domestic wells and other wells which may obtain water from the same aquifer. The well owner under this Permit shall control his withdrawals so there is not a reduction of needed water supplies in adequate domestic wells or in adequate wells having prior water rights.
2. The wells authorized by Permit No. 7721-3 shall be constructed by a licensed well driller and construction of the well and installation of the pump shall comply with Water Management Board Well Construction Rules, Chapter 74:02:04 with the well casing pressure grouted (bottom to top) pursuant to Section 74:02:04:28. *(Well completion reports for the wells authorized by Water Right No. 3054A-3 and Water Permit Nos. 7638-3 & 7721-3 are on file with the Water Rights Program.)*
3. This Permit is approved subject to the irrigation water use questionnaires being submitted each year.


 Eric Gronlund, Chief Engineer
 Water Rights Program
 Department of Agriculture and Natural Resources

JUL 22 2024
 date

